This cancellation notice is being re-issued March 16, 1987 to provide corrected supersession data. Please replace any previous copies with this updated notification.

FEDERAL SPECIFICATION SHEET

FUSE, CARTRIDGE, HIGH INTERRUPTING CAPACITY,
CLASS K1 (NONCURRENT-LIMITING) 600 VOLTS, 101-200 AMPERES

(DETAIL SPECIFICATION)

This cancellation was approved by the Assistant Administrator, Office of Federal Supply and Services, General Services Administration, for the use of all Federal agencies.

Federal Specification Sheet W-F-1814/44, dated May 23, 1974, has been superseded by W-F-1814/65, Fuses, Cartridge, High-Interrupting Capacity, Classes RK1 and RK5 (Current-Limiting) 600 Volts, 101-200 Amperes, dated October 21, 1982.

TABLE I. Current rating and part number designation.

Government part number	Current rating (amperes)	Superseded by WF1814/65-	
		RK1	
		Instantaneous	Time delay
WF1814/44-001	110	F1110	
-002	125	F1125	
-003	150	F1150	
-004	175	F1175	
-005	200	F1200	
-006	110		D1110
-007	125		D1125
-008	150		D1150
-009	175		D1175
-010	200		D1200

PREPARING ACTIVITY:

DLA - ES

(Project 5920-0433-34)

AMSC N/A

FSC 5920

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:36Z
Check the source to verify that this is the current version before use.