This cancellation notice is being reissued March 16, 1987 to provide corrected supersession data. Please replace any previous copies with this updated notification.

FEDERAL SPECIFICATION SHEET

FUSE, CARTRIDGE, HIGH INTERRUPTING CAPACITY,
CLASS K1 (NONCURRENT-LIMITING) 600 VOLTS, 201-400 AMPERES

(DETAIL SPECIFICATION)

This cancellation was approved by the Assistant Administrator, Office of Federal Supply and Services, General Services Administration, for the use of all Federal agencies.

Federal Specification Sheet W-F-1814/45, dated May 23, 1974, has been superseded by W-F-1814/66, Fuses, Cartridge, High-Interrupting Capacity, Classes RK1 and RK5 (Current-Limiting) 600 Volts, 201-400 Amperes, dated October 21, 1982.

TABLE I. Current rating and part number designation.

Government part number	Current rating (amperes)	Superseded by WF1814/66-	
		RK1	
		Instantaneous	Time delay
WF1814/45-001	225	F1225	
-002	250	F1250	
-003	300	F1300	
-004	350	F1350	
-005	400	F1400	
-006	225		D1225
-007	250		D1250
-008	300		D1300
-009	350		D1350
-010	400		D1400

PREPARING ACTIVITY:

DLA - ES

(Project 5920-0433-35)

AMSC N/A

FSC 5920

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:36Z
Check the source to verify that this is the current version before use.