A-A-734
February 25, 1981

COMMERCIAL ITEM DESCRIPTION

GENERATOR SET, GASOLINE ENGINE (AIR COOLED, STATIONARY, 120 V, 60 HERTZ, SINGLE PHASE)

The General Services Administration has authorized the use of this commercial item description.

This commercial item description covers gasoline or gas driven, stationary, air cooled, motor generator sets with electrical rating of 120 volts, 60 Hertz.

Salient characteristics:

Four cycle engine with air cleaner.
Fuel line.
Five percent speed regulation at rated load.
Start-stop switch.
Mounted control box with reverse current cutout.
Battery terminals.
Remote control terminals.
Muffler.
Flexible exhaust connection.
Battery cables.
Automatic choke.
Batteries.
Temperature rise at rated load for the alternator shall be in accordance with NEMA MG-1-22.40.
Insulation system shall be in accordance with class B of NEMA MG-1-1.65.
The electrical ratings shall be as follows:

Type	Watts	Amperes
A	1,000	8.3
B	2,500	20.8

The issue of NEMA MG-1 in effect on the date of the solicitation shall be used to determine compliance wi stated requirements.

Certification. The contractor shall certify that the product offered meets the salient characteristics of th description, and that the product conforms to the producer's own drawings, specifications, standards and quali assurance practices and is the same product sold in the commercial marketplace. The Government reserves the rig to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under t provisions of the contract.

Regulatory Requirements. The manufacturer shall utilize recovered materials to the maximum extent practicable.

Packaging, Packing, and Marking. The items shall be packaged in accordance with normal commercial practice a packed to assure acceptance by common carrier and provide product protection against loss and damage duri multiple shipments, handling, and storage. The shipping container shall be in compliance with National Motor Freig Classification and Uniform Freight Classification. Shipping containers shall be marked as specified in the contract order.

Copies of NEMA MG-1 are available from the National Electrical Manufacturers Association, 2101 L Street, N Washington, DC 20037.

FSC 6115

GSA DC-01102526

Source: https://assist.dla.mil -- Downloaded: 202610-26T08:10Z
Check the source to verify that this is the current version before use.