MIL-V-3293A
10 DECEMBER 1956
SUPERSEDING
MIL-V-3293
20 SEPTEMBER 1950

MILITARY SPECIFICATION

VALVE, ANTI-BACK-DRAFT, PROTECTIVE SHELTER, M1

This specification has been approved by the Department of Defense and is mandatory for use by the Departments of the Army, the Navy, and the Air Force.

1. SCOPE

1.1 This specification covers a valve for use in regulating the pressure between the outer air locks of protective shelters and the atmosphere.

2. APPLICABLE DOCUMENTS

2.1 The following standards and drawings, of the issue in effect on date of invitation for bids, form a part of this specification.

STANDARDS

MILITARY

MIL-STD-10 — Surface Roughness, Waviness, and Lay.

MIL-STD-105 — Sampling Procedures and Tables for Inspection by Attributes.

MIL-STD-129 — Marking for Shipment and Storage.

DRAWINGS

CHEMICAL CORPS

C5-65-2 — Valve, Anti-Back-Draft, M1—Bill of Material.

D5-20-122 — Packing, Anti-Back-Draft Valve — Assembly, Packing Diagram, and Bill of Material.

(Copies of specifications, standards, drawings, and publications required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

3. REQUIREMENTS

3.1 **Materials and components.** All materials and components shall conform to specifications and drawings forming a part of this specification.

3.2 **Manufacture and assembly.** The valve shall be manufactured and assembled in accordance with Drawing C5-65-3 which is listed on Drawing C5-65-2 and subsidiary drawings listed thereon. Surface roughness, waviness, and lay specified by symbols on detail drawings shall comply with the applicable classes specified in Standard MIL-STD-10.

3.3 **Flap seating.** The flap, Drawing C5-65-6 which is listed on Drawing C5-65-2, when in the closed position shall be away from the felt gasket not more than one sixteenth of an inch at any point, when tested as specified in 4.4.

FSC 5680

Source: https://assist.dla.mil -- Downloaded: 2026-10-16T17:27Z
Check the source to verify that this is the current version before use.

3.4 **Workmanship.** The valve shall be free from any damage, defects or contamination.

4. QUALITY ASSURANCE PROVISIONS

4.1 Lot. A regular production lot shall consist of the valves produced by one manufacturer, from the same materials, and under essentially the same manufacturing conditions. The inspection lot for nondestructive inspection, within the above limitations shall be designated by the inspector. When specified in the contract or order, groups for shipment shall be formed from each production lot. The number of units in the group and the marking shall be as specified (see 6.1).

4.2 Sampling for nondestructive inspection. Sampling shall be conducted in accordance with the classification of defects (4.3.3) and Standard MIL–STD–105.

4.3 Inspection.

4.3.1 *Components.* The inspector shall ascertain that, prior to assembly, all materials, components or subassemblies of the valve covered by separate specifications, standards, or drawings are in accordance with their respective specifications, standards, or drawings prior to final acceptance of the valve.

4.3.2 *Packing and marking.* The inspector shall inspect the packing and marking for compliance with section 5.

4.3.3 *Classification of defects.* Inspection of the valve shall be conducted as follows:

4.3.3.1 *Valve, anti-back-draft, M1 assembly.* (Dwg. C5–63–3 which is listed on Dwg. C5–65–2)

Categories and defects	*Acceptance standards*
Major A AQL 1.0 percent defective	
1a. Flap seating	4.4
Major AQL 2.5 percent defective	
1. Component missing or incorrectly assembled	
2. Flange not at right angle to body	
3. Mounting holes missing	
4. Counterweight not free to move entire rod length	
5. Rod length incorrect	
6. Brazing or welding incorrect	
7. Counterweight dimensions incorrect	
8. Nonfunctioning	
9. Damage	
Minor AQL 6.5 percent defective	
51. Flange to lip at top of body (1½) incorrect	
52. Box depth incorrect	
53. Body height or width incorrect	
54. Mounting flange dimensions or location incorrect	
55. Mounting holes diameter or location incorrect	
56. Hinge incorrect	
57. Coating missing, inadequate, or incorrect	
58. Corrosion preventative missing or inadequate	
Incidental AQL 10 percent defective	
101. Contamination	

4.4 Flap seating test. With the mounting flange in a vertical position and the counterweight located in its innermost position (handtight), the distance between the flap and the gasket shall be determined by the use of a feeler gage or other suitable means.

5. PREPARATION FOR DELIVERY

5.1 Preservation and packing.

5.1.1 *Level A.* The valve shall be preserved and packed in accordance with level A as specified on Drawing D5–20–122.

5.1.2 *Level B.* The valve, preserved as specified in 5.1.1, shall be packed in accordance with level B as specified on Drawing D5–20–122.

5.2 Marking. In addition to any special marking required by the contract or order, all shipping containers shall be marked in accordance with Standard MIL–STD–129.

Source: https://assist.dla.mil -- Downloaded: 2026-10-16T17:27Z
Check the source to verify that this is the current version before use.

6. NOTES

6.1 Ordering data. *Procurement documents* should specify the following:

a. The title, number, and date of this specification.

b. Selection of applicable level of packing.

c. Shipment group size and marking (when required).

6.2 Stock number. The Federal stock number for this item is 5680–368–6143.

Notice. When Government drawings, specifications, *or other data are used for any purpose other than in* connection with a definitely related Government procurement operation, the United States Government thereby incurs no responsibility nor any obligation whatsoever; and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

Custodians:
Army—Chemical Corps
Navy—Bureau of Yards and Docks

Other interest:
Army—TE

Preparing activity:
Army—Chemical Corps

Source: https://assist.dla.mil -- Downloaded: 2026-10-16T17:27Z
Check the source to verify that this is the current version before use.