A-A-53755
11 November 1988

COMMERCIAL ITEM DESCRIPTION

BLADE, GAG, RING RETRACTOR

The General Services Administration has authorized the use of this commercial item description.

This commercial item description covers ring retractor gag blades used in endotracheal anesthesia.

Salient characteristics.

General. Shall be a ring retractor gag blade to be used with McIvor, Davis, or Leivers mouth gag frames. The blade shall accommodate various size tracheal tubes depending on blade size.

Material. The material shall be Class 3 or 4 austenitic or martensitic stainless steel in accordance with ASTM Designation F899.

Hardness. The blade fabricated from Class 3 material shall have a Rockwell Hardness B Scale (HRB) of 75 to 85. The blade fabricated from Class 4 material shall have a Rockwell Hardness C Scale (HRC) of 40 to 47. The hardness shall be tested in accordance to ASTM Designation E18 or ASTM Designations E92 and E140.

Style and design. The blade shall be in accordance with Defense Personnel Support Center (DPSC) Drawing No. 24560.

Finish. The finish of the gag blade shall be mirror, satin or matte. The matte finish shall exhibit a uniform non-directional surface texture equivalent to that produced by lightly blasting the prepared surfaces with fine abrasives under pressure.

Corrosion resistance. The blade shall show no signs of corrosion or plating of copper when tested for corrosion resistance in accordance with ASTM Designation F1089.

AMSC N/A FSC 6515

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:24Z
Check the source to verify that this is the current version before use.

Identification marking. The blade shall bear the contractor's name or registered trademark and the word "stainless". Blade shall bear the name of the country of origin.

Workmanship. The blade shall be free from defects which detract from its appearance or impair its serviceability.

Product Quality Level.

Visual and dimensional examination. Shall be examined to verify that design, construction and workmanship are in accordance with applicable requirements.

Materials. The supplier shall be responsible for assuring that materials are in accordance with requirements specified.

Unit. Each (EA). One gag blade, as specified, constitutes one unit.

Quality Assurance Provisions.

Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

Records. Records of examinations and tests performed by or for the contractor shall be maintained by the contractor and made available to the Government upon the Government's request, at any time, or from time to time, during the performance of the contract and for a period of three years after delivery of the supplies to which such records relate.

Inspection. Inspection, as used herein, is defined as both examination (such as visual or auditory investigation without the use of special laboratory appliances or procedures) and testing (determination by technical means of physical and chemical properties) of the item.
characteristics.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:24Z
Check the source to verify that this is the current version before use.

Tests. Tests shall be conducted to determine compliance with specification requirements. Where feasible, the same sample shall be used for the determination of two or more test characteristics.

Sampling for examination. Sampling for examination shall be conducted in accordance with MIL-STD-105, with an Inspection Level of II and an AQL of 1.0 (percent defective). Unit of product for examination purposes shall be one blade. Defects shall be those listed below.

Defects

Blade not free from cracks, pits, burs, sharp edges, scale, rough areas or corrosion.

Finish of the blade not as specified.

Style and design not as specified.

Identification markings not present, not complete, not correct, or not legible.

Sampling for tests. Sampling for tests shall be conducted in accordance with MIL-STD-105 and as specified herein. The unit of product for test purposes shall be one blade. AQL shall be 1.0 (percent defective) and an Inspection Level of S-2.

Contractor certification. The contractor shall certify that the product offered meets the salient characteristics of this description and conforms to the producers' own drawings, specifications, standards, and quality assurance practices. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

Metric products. Products manufactured to metric dimensions will be considered on an equal basis with those manufactured using inch-pound units, providing they fall within the tolerances specified using conversion tables contained in the latest revision of Federal Standard No. 376, and all other requirements of this document are met.

If a product is manufactured to metric dimensions and those dimensions exceed the tolerances specified in the inch/pound units, a request should be made to the contracting officer to determine if the product is acceptable.

The contracting officer has the option of accepting or rejecting the product.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:24Z
Check the source to verify that this is the current version before use.

Regulatory requirements.

Federal Food, Drug and Cosmetic Act. If the product covered by this document has been determined by the U.S. Food and Drug Administration to be under its jurisdiction, the offeror/contractor shall comply, and be responsible for compliance by its subcontractors/suppliers, with the requirements of the Federal Food, Drug and Cosmetic Act, as amended, and regulations promulgated thereunder. In addition, the offeror/contractor shall comply, and be responsible for compliance by its subcontractors/suppliers, with the requirements of all other applicable Federal, State, and local statutes, ordinances, and regulations.

Recovered materials. The offeror/contractor is encouraged to use recovered material in accordance with Public Law 94-580, as amended, and as implemented by Federal Acquisition Regulation Subpart 23.4 to the maximum extent practical.

Preservation, packaging, packing, labeling, and marking. Unless otherwise specified, preservation, packaging, and packing shall be to a degree of protection to preclude damage to containers and/or contents thereof under normal shipping conditions, handling, etc., involving shipment from the supply source to the receiving activity, plus resnipment from receiving activity, and shall conform to applicable carrier's rules and regulations. Intermediate and exterior package quantities and labeling and marking shall be as specified in the contract and/or order.

NOTE: The following National Stock Numbers are is covered by this document:

NSN	ITEM IDENTIFICATION
6515-00-104-8917	Blade, Gag, Right, No. 4, by 1-1/4 by 3-1/2 inches
6515-00-104-8929	Blade, Gag, Left, Ring, No. 4, 1-1/4 by 3-1/2 inches
6515-00-104-8960	Blade, Gag, Right, Ring, No. 3, 1-1/8 by 3 inches
6515-00-104-8966	Blade, Gag, Left, Ring, No. 3, 1-1/8 by 3 inches

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:24Z
Check the source to verify that this is the current version before use.

NSN	ITEM IDENTIFICATION
6515-00-104-8968	Blade, Gag, Left, Ring, No. 2, 7/8 by 2-1/4 inches
6515-00-104-8971	Blade, Gag, Right, Ring, No. 2, 7/8 by 2-1/4 inches

Ordering data (Intermediate/exterior package quantities and labeling and marking must be specified in the contract and/or order).

MILITARY INTERESTS:

Custodians:

Army - MD
Navy - MS
Air Force - 03

Preparing Activity:

DoD-MB

Agent:

DLA-DM

CIVIL AGENCY COORDINATING ACTIVITIES:

VA-OSS
PHS
FDA-MPQAS

Project No. 6515-4140

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:24Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2 DOCUMENT TITLE
A-A-53755	BLADE, GAG, RING RETRACTOR

3a. NAME OF SUBMITTING ORGANIZATION	4 TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
	☐ USER
b ADDRESS *(Street, City, State, ZIP Code)*	☐ MANUFACTURER
	☐ OTHER *(Specify)*. _____

5 PROBLEM AREAS

a. Paragraph Number and Wording

b Recommended Wording

c Reason/Rationale for Recommendation

6 REMARKS

7a NAME OF SUBMITTER *(Last, First, MI)* – Optional	b WORK TELEPHONE NUMBER *(Include Ar Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8 DATE OF SUBMISSION *(YYMMDD)*

(TO DETACH THIS FORM, CUT ALONG THIS LINE.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:24Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO 4966 Alexandria, VA

POSTAGE WILL BE PAID BY

Commander
Defense Personnel Support Center
ATTN: DPSC-RSTE
2800 South 20th Street
Philadelphia, Pennsylvania 19101-8419

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:24Z
Check the source to verify that this is the current version before use.