SS-C-192G
Int. Amendment-2(COM-NBS)
April 21, 1971

INTERIM AMENDMENT

TO

FEDERAL SPECIFICATION

CEMENT, PORTLAND

This interim amendment was developed by the National Bureau of Standards, Department of Commerce, Washington, DC 20234, based on currently available technical information. It is recommended that Federal agencies use it in procurement and forward recommendations for changes to the preparing activity at the address shown above.

The General Services Administration has authorized the use of this interim amendment as a valid exception to Federal Specification SS-C-192G dated December 4, 1964.

PAGE 2

Table I, chemical requirements. Increase the maximum allowable percent of sulfur trioxide (SO_3) content for Types I and IA cement from 2.5 and 3.0 to 3.0 and 3.5 respectively; for Types II and IIA cement from 2.5 to 3.0; and for Types III and IIIA cement from 3.0 and 4.0 to 3.5 and 4.5 respectively. Raise the maximum allowable percent of magnesium oxide (MgO) for Type V cement from 4.0 to 5.0.

PAGE 4

Paragraph 3.3, processing addition. Lines 3 and 4, delete the word "untreated".

Section 4: Delete title and substitute "QUALITY ASSURANCE PROVISONS".

Paragraph 4.1: Delete and substitute the following:

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified, the supplier may utilize his own facilities or any other commercial laboratory acceptable to the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure that supplies and services conform to prescribed requirements.

PAGE 5

Paragraph 4.5, rejection and retests. Change the second sentence to read "Cement remaining in storage prior to shipment for a period longer than 6 months after test may be retested for fineness, loss on ignition, and strength (and for airentraining cements, also for airentraimment), and shall be rejected if it fails to meet the specification requirements for any of these properties." Delete the last two sentences.

PAGE 6

Paragraph 6.4, transportation description. Delete.

FSC 5610

GSA DC 71-13730

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:12Z
Check the source to verify that this is the current version before use.