SS-T-315B
July 10, 1974
SUPERSEDING
Fed. Spec. SS-T-315A
July 31, 1967

FEDERAL SPECIFICATION

TILE, GYPSUM (INTERIOR; FLOOR AND ROOF, PRECAST)

This specification was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

1. SCOPE AND CLASSIFICATION

1.1 Scope. This specification covers precast, reinforced, gypsum tiles (slabs) consisting essentially of gypsum with metal reinforcement.

1.2 Classification.

1.2.1 Type and size. Gypsum tile furnished under this specification shall be of the following types and sizes as specified (see 6.2):

Type I - Long-span, steel-edged, tongue-and-groove tile.

Size - 10 feet long by 15 inches wide by two inches thick, nominal size.

Type II - Short-span title.

Size - 2-1/2 feet long, by 12 inches wide, by three inches thick, nominal size.

2. APPLICABLE DOCUMENTS

2.1 The following documents, of the issues in effect on date of invitation for bids or request for proposal, form a part of this specification to the extent specified herein.

Federal Specification:

QQ-S-781 - Strapping, Steel Flat and Seals.

Federal Standard:

Fed. Std. No. 123 - Marking for Domestic Shipment (Civil Agencies).

(Activities outside the Federal Government may obtain copies of Federal Specifications, Standards, and Handbooks as outlined under General Information in the Index of Federal Specifications and Standards and at the prices indicated in the Index. The Index, which includes cumulative monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

(Single copies of this specification and other Federal Specifications required by activities outside the Federal Government for bidding purposes are available without charge from Business Service Centers at the General Services Administration Regional Offices in Boston, New York, Washington, DC, Atlanta, Chicago, Kansas City, MO, Fort Worth, Denver, San Francisco, Los Angeles, and Seattle, WA.

(Federal Government activities may obtain copies of Federal Specifications, Standards, and Handbooks and the Index of Federal Specifications and Standards from established distribution points in their agencies.)

Military Standards:

MIL-STD-105 - Sampling Procesures and Tables for Inspection by Attributes.
MIL-STD-129 - Marking for Shipment and Storage.

Source: https://assist.dla.mil -- Downloaded: 202610-26T12:13Z
Check the source to verify that this is the current version before use.

(Copies of Military Specifications and Standards required by suppliers in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless a specific issue is identified, the issue in effect on date of invitation for bids or request for proposal shall apply.

American Society for Testing and Materials (ASTM) Standards:

C 377 - Specifications for Precast Reinforced Gypsum Slabs.
C 473 - Physical Testing of Gypsum Board Products and Gypsum Tile or Block.

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.)

National Motor Freight Traffic Association, Inc., Agent:

National Motor Freight Classification.

(Application for copies should be addressed to the American Trucking Associations, Inc., Tariff Order Section, 1616 P Street, N.W., Washington, DC 20036.)

Uniform Classification Committee, Agent:

Uniform Freight Classification.

(Application for copies should be addressed to the Uniform Classification Committee, Room 1106, 222 South Riverside Plaza., Chicago, IL 60606.)

3. REQUIREMENTS

3.1 Material. When tested in accordance with 4.4.2, the gypsum tile shall conform with the requirements of ASTM C 377, except for packaging and marking, inspection, rejection and rehearing.

3.2 Marking. Tile shall be marked with the manufacturer's name or brand on the face. Each tile shall be clearly marked to indicate which side is to be placed upward when installed.

3.3 Workmanship. Tile shall be uniform in size, provide close fitting joints, even bearing, and flush top surfaces. Reinforcements shall be free from dirt, scale, grease and other substances that reduce bond.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or order, the supplier may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure that supplies and services conform to prescribed requirements.

4.2 Sampling.

4.2.1 Lot. Unless otherwise specified (see 6.2), a lot shall consist of each type submitted for inspection at the same time.

4.2.2 Visual examination of end item. Samples for visual examination shall be selected in accordance with level S-3 in MIL-STD-105.

4.2.3 Samples for test. The number of samples for tests shall be selected in accordance with ASTM C 377.

4.3 Examination.

4.3.1 End item. Gypsum tile selected in accordance with 4.2.2 shall be examined for defects listed in table I. The acceptable quality levels (AQL's) for defects shall be 2.5 percent defective for major defects and 4.0 percent defective for minor defects.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:13Z
Check the source to verify that this is the current version before use.

TABLE I. Classification of defects, end item

Defects	Major	Minor
Type not as specified	X	
Length, width and thickness not within tolerances	X	
Edges not as specified	X	
Edges not square with ends	X	
Reinforcement not galvanized	X	
Edge strips on type I tiles not galvanized	X	
Weight greater than 14 pounds per square foot for type I	X	
Weight greater than 17 pounds per square foot for type II	X	
Marking missing on tiles		X
Damage or defects affecting function or serviceability	X	
Damage or defects not affecting function or serviceability		X

4.3.2 Inspection of preparation for delivery. An inspection shall be made to determine that the packaging, packing, and marking requirements comply with section 5. Defects shall be scored in accordance with table II. Sampling shall be in accordance with MIL-STD-105. Defects of closure listed shall be examined on shipping containers fully prepared for delivery. The lot size shall be the number of shipping containers in the end item inspection lot. The inspection level shall be S-2 and the AQL shall be 4.0 defects per hundred units.

TABLE II. Classification of preparation for delivery defects

Examine	Defects
Marking (exterior and interior)	Omitted; illegible; or improper size, location, sequence, or method of application.
Materials	Any component missing or damaged.
Workmanship	Inadequate application of components such as loose strapping.

4.4 Tests.

4.4.1 Acceptable Quality Levels. The acceptable quality levels for tests shall be 6.5 percent.

4.4.2 Physical tests. Physical tests shall be conducted in accordance with ASTM C 473 (see 3.1 and 4.2.3).

5. PREPARATION FOR DELIVERY

5.1 Packing. Packing shall be level A, B or C as specified (see 6.2).

5.1.1 Level A or B. Tile of like description shall be bundled in quantities as specified (see 6.2), and strapped with steel strapping conforming to QQ-S-781, Type I, Class B, Grade 2.

5.1.2 Level C. Packing shall be in accordance to commercial practice to insure carrier acceptance and safe delivery to destination at lowest rates in compliance with Uniform Freight Classification rules or National Motor Freight Classification rules.

5.2 Marking. In addition to marking required by the contract or order shall be marked in accordance with 5.2.1 or 5.2.2 as applicable (see 6.2).

5.2.1 Civil agencies. All marking shall be in accordance with Fed. Std. No. 123.

5.2.2 Military activities. All marking shall be in accordance with MIL-STD-129.

6. NOTES

6.1 Intended use.

6.1.2 Type I. Steel-edged tongue-and-groove, long-span tile is intended for support on primary structural framing.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:13Z
Check the source to verify that this is the current version before use.

6.1.3 Type II. Short-span tile is designed for end support or subpurlins.

6.2 Ordering data. Purchasers should select the preferred options permitted herein, and include the following information in procurement documents:

(a) Title, number, and date of this specification.
(b) Type of tile required (see 1.2.1).
(c) Size of lot, if different from 4.2.1.
(d) Level of packing required see 5.1.
(e) Quantity of tiles see 5.1.1.

Preparing activity:

GSA-FSS

Civil Agency Coordinating Activities:

COMMERCE-NBS
USDA-AFS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:13Z
Check the source to verify that this is the current version before use.