
FED. SUP CLASS
5975



NOTES:

1. REFERENCED DOCUMENTS SHALL BE OF THE ISSUE IN EFFECT ON DATE OF INVITATIONS FOR BID.
2. THIS STANDARD TAKES PRECEDENCE OVER DOCUMENTS REFERENCED HEREIN.
3. SHIM - BRASS, SPRING TEMPER, SHALL BE IN ACCORDANCE WITH FEDERAL SPECIFICATION QQ-B-613.
4. WEDGE - BRASS, HALF HARD, SHALL BE IN ACCORDANCE WITH FEDERAL SPECIFICATION QQ-B-613.
5. PULL - COPPER WIRE, ANNEALED SHALL BE IN ACCORDANCE WITH FEDERAL SPECIFICATION QQ-W-341.
6. SHELL - COPPER, STRIP, COLD-ROLLED, HALF-HARD IN ACCORDANCE WITH FEDERAL SPECIFICATION QQ-C-576.
7. CLAMP SHALL BEAR MANUFACTURER'S SYMBOL OR IDENTIFICATION MARK IN ACCORDANCE WITH FEDERAL SUPPLY CODE FOR MANUFACTURERS.

Reviewer/user information is current as of the date of this document. For future coordination of changes to this document, draft circulation should be based on the information in the current DODISS (FSC listing).
Navy YD/
Army CL3 EL/
AF 85/ 82/

This military standard has been approved by the Department of Defense and is mandatory for use by all Departments and Agencies of the Department of Defense. Selection for all new engineering and design applications and for repetitive use shall be made from this document.

APPROVED 18 JULY 58 REVISED (A) 19 December 1967

ALL DIMENSIONS IN INCHES

P.A. EL Other Cust YD 82	TITLE CLAMP, DROPWIRE ELECTRICAL CONDUCTOR, STRAIN (POLE LINE)	MILITARY STANDARD MS 39031
PROCUREMENT SPECIFICATION MIL-H-55053	SUPERSEDES:	SHEET 1 OF 1

5975-0279

DD FORM 10 APR 64 672 (Coordinated) PREVIOUS EDITIONS OF THIS FORM ARE OBSOLETE

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T17:44Z
Check the source to verify that this is the current version before use.