[INCH-POUND]
A-A-2156A
January 6, 1997
SUPERSEDES
A-A-2156
July 15, 1983

COMMERCIAL ITEM DESCRIPTION

FIRE HOSE, RELAY-SUPPLY

The General Services Administration has authorized the use of this commercial item description by all Federal agencies.

1. SCOPE. This commercial item description (CID) covers large diameter hose for fire department relay and supply operations.

2. CLASSIFICATION. The hoses shall be the following types and sizes:

Type A - Threaded couplings with rocker lugs.
Type B - Non-threaded (Storz) couplings.

Size 1 - 4 inch
Size 2 - 5 inch

Length to be specified on the contract or purchase order.

3. SALIENT CHARACTERISTICS

3.1 General. Each hose assembly shall consist of a section of hose fitted with either a type A or type B couplings, as specified, on each end. The type A hose shall be supplied with an externally threaded (male) coupling assembly on one end and a swivel internally threaded (female) coupling assembly on the other. All testing and certification for the hose shall include the couplings supplied with the hose.

3.2 Hose. The hose shall be a synthetic rubber with imbedded reinforcement yarns. The hose shall be resistant to ozone, sunlight/UV, and cold to -20°F (-93°C). The hose shall be in conformance with National Fire Protection Association (NFPA) 1961, Standard on Fire Hose, specifically for Supply Hose. The hose inside diameter shall be the specified size as a minimum.

3.2.1 Abrasion resistance. The hose shall withstand 14,000 cycles using an H-22 wheel and 1 kg weight, when tested in accordance with ASTM D3884.

3.3 Couplings. The couplings shall be hardcoated aluminum alloy normally used for fire hose couplings. The coupling attachment system shall retain the couplings on the hose when subjected to the full test pressure specified by NFPA 1961 for the applicable hose diameter.

3.3.1 Type A. The type A couplings shall be in accordance with NFPA 1963, Standard for Fire Hose Connections, specifically for Threaded Connections, sized as follows: Unless otherwise specified by the contract or purchase order, size 1 hose shall be supplied with 4 inch couplings, size 2 hose shall be supplied with 5 inch couplings.

3.3.2 Type B. The type B couplings shall be in accordance with NFPA 1963, Standard on Fire Hose Connections, specifically for Non-threaded Connections, sized as follows: Size 1 hose shall be supplied with 4 inch couplings, size 2 hose shall be supplied with 5 inch couplings. The coupling attachment system shall be field repairable with hand tools.

Beneficial comments, recommendations, additions, deletions, clarifications, etc. and any data which may improve this document should be sent to: General Services Administration, Engineering Group (7FXEE), 819 Taylor Street, Fort Worth, TX 76102

FSC 4210

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:20Z
Check the source to verify that this is the current version before use.

3.4 Color. The hose shall be yellow in color.

3.5 Length. The length of the hose shall be as specified in the contract or purchase order, couplings included. Unless otherwise specified, the length tolerance shall be minus 1 , plus 3 feet (-30 cm, +91 cm.)

3.6 Workmanship. The hose shall be complete and ready for use. The hose shall be clean and free from defects which may affect appearance or serviceability. The couplings shall be clean, free from pits, tool marks, or other defects that may affect appearance or serviceability.

3.7 Metric products. Except as stated below, products manufactured to metric dimensions will be considered on an equal basis with those manufactured using inch-pound units, providing they fall within tolerances specified and all other requirements of this document are met. The exception to this will be the fire hose connections, no metric equivalents are provided and none will acceptable.

4. REGULATORY REQUIREMENTS.

4.1 Regulatory requirements. The offeror/contractor is encouraged to use recovered materials to the maximum extent practicable, in accordance with paragraph 23.403 of the Federal Acquisition Regulation (FAR).

5. QUALITY ASSURANCE PROVISIONS

5.1 Product conformance. The products provided shall meet the salient characteristics of this CID, shall conform to the producer's own drawings, specifications, standards, and quality assurance practices, and shall be the same product offered for sale in the commercial market. The government reserves the right to require proof of such conformance.

6. PACKAGING, PACKING AND MARKING

6.1 Packaging, packing and marking. The packaging, packing, and marking shall be as specified in the contract or order.

7. NOTES

7.1 Intended use. This hose is intended to supply water from fire hydrants to fire apparatus, from one apparatus to another, and from a fire apparatus to a stationary monitor.

7.2 Ordering data. Purchases should select the preferred options permitted herein and include the following information in procurement documents:

a. Title, number, and date of this CID.
b. Type and size.
c. The packaging, packing and marking desired

7.3 Referenced documents.

NFPA 1961 - Fire Hose
NFPA 1963 - Fire Hose Connections

National Fire Protection Association (NFPA) documents can be obtained from NFPA, PO Box 9101, Quincy, MA 02269-9101, (617) 770-3000.

ASTM D 3884 - Standard Test Method for Abrasion Resistance of Textile Fabrics (Rotary Platform, Double Head Method)

Copies of ASTM standards are available from ASTM, 100 Bar Harbor Dr., West Conshohocken, PA 19428-2959, (610-832-9500).

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:20Z
Check the source to verify that this is the current version before use.

7.4 Part Identification Number (PIN). This part numbering system is intended for identification and cross-indexing of the item by the government only and does not constitute a requirement for the contractor.

Example: AA2156 / A 1/50

- AA2156 — CID A-A-2156
- A — Type A or B
- 1 — Size - 1 or 2
- 50 — Length in feet.

7.5 National Stock Numbers. The following NSNs (with the appropriate part number) are known to use this document:

NSN	Type	Size	Length	Part Number
4210-01-170-3582	A	1	50	AA2156/A1/50
4210-01-170-5092	B	1	50	AA2156/B1/50
4210-01-170-5095	B	2	50	AA2156/B2/50
4210-01-322-4996	B	1	100	AA2156/B1/100
4210-01-322-4997	B	2	100	AA2156/B2/100

Preparing Activity:
GSA - FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:20Z
Check the source to verify that this is the current version before use.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:20Z
Check the source to verify that this is the current version before use.