INCH-POUND
MIL-P-23928/4B(SH)
5 December 1988
Superseding
MIL-P-23928/4A(SH)
11 May 1979

MILITARY SPECIFICATION SHEET

PANEL, ELECTRICAL, POWER DISTRIBUTION FOR DOUBLE AQB-A101 AND NQB-A101 CIRCUIT BREAKERS, 2-12 CIRCUITS, WITH AND WITHOUT MANUAL TRANSFER, DRIPPROOF, TOTALLY ENCLOSED AND WATERTIGHT

This specification sheet is approved for use by the Naval Sea Systems Command, Department of the Navy, and is available for use by all Departments and Agencies of the Department of Defense.

The requirements for acquiring the product described herein shall consist of this specification sheet and the issue of the following specification listed in that issue of the Department of Defense Index of Specifications and Standards (DoDISS) specified in the solicitation: MIL-P-23928(SH).




FIGURE 1. Distribution panel with double AQB-A101 and NQB-A101 circuit breakers, totally enclosed and dripproof enclosure (typical).

FSC 5925

AMSC N/A

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited

Source: https://assist.dla.mil -- Downloaded: 202610-19T18:20Z
Check the source to verify that this is the current version before use.






FIGURE 2 Distribution panel with double AQB-A101 and NQB-A101 circuit breakers, watertight enclosure (typical).

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T18:20Z
Check the source to verify that this is the current version before use.



NO OF DIST CKTS	DISTRIBUTION ONLY WITH AND WITHOUT SPLIT BUS			
4	26 25	7 13	20.00	14 75
6	30.37			18.87
8	34.50			23.00
10	38 62			27 12
12	42.75			31 25
14	47 00			35 50

PANEL AND MOUNTING DIMENSIONS




WIRING DIAGRAM, FRONT VIEW (TYPICAL)

SH13231817

FIGURE 3. Panel mounting dimensions and wiring diagram for figures 1 and 2


Source: https://assist.dla.mil -- Downloaded: 202610-19T18:20Z
Check the source to verify that this is the current version before use.



NO OF DIST CKTS	DISTRIBUTION WITH ONE TWO-WAY 100A BUS TRANSFER					
	A	B	C	D	E TE & DP	F
2	26 00	7 56	21 00	12.25	17 50	–
4	30.25			16 5		–
6	34.50			20.75		–
8	38.75			25 00		–
10	44.50			30.75		16.50
12	48.75			35 00		20.75

PANEL AND MOUNTING DIMENSIONS


SH13231818




WIRING DIAGRAM, FRONT VIEW (TYPICAL)

FIGURE 4 Distribution panel with double AQB-A101 circuit breakers with 2-way 100 amp NQB circuit breaker transfer switches (typical).

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T18:20Z
Check the source to verify that this is the current version before use.





WIRING DIAGRAM, FRONT VIEW (TYPICAL)


NO. OF DIST CKTS	DISTRIBUTION WITH ONE THREE-WAY 100A BUS TRANSFER					
	A	B	C	D	E TE & DP	F TE & DP
4	34.87	7.86	24.00	19.62	21.25	13.31
6	39.12			23.75	21.25	
8	43.37			27.87	21.25	
10	47.62			32.00	21.25	
12	53.37			27.87	38.12	


PANEL AND MOUNTING DIMENSIONS

SH13231819

FIGURE 5. Distribution panel with double AQB-A101 circuit breakers with 3-way 100 amp NQB circuit breaker transfer switches (typical).

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T18:20Z
Check the source to verify that this is the current version before use.





WIRING DIAGRAM, FRONT VIEW (TYPICAL)

NO. OF DIST CKTS	DISTRIBUTION WITH ONE THREE-WAY 100A BUS TRANSFER					
	A	B ±.031	C ±.06	D	E	F
4	38.13	9.125	26.00	24.38	10.00	14.38
6	43.38			28.63	14.25	
8	47.63			32.88	18.50	
10	53.38			38.63	24.25	
12	57.63			42.88	28.50	

PANEL AND MOUNTING DIMENSIONS

SH13231820


FIGURE 6. Distribution panel with double AQB-A101 circuit breakers with 2-way 250 amp NQB circuit breaker transfer switches (typical).

Source: https://assist.dla.mil -- Downloaded: 202640-19T18:20Z
Check the source to verify that this is the current version before use.

TABLE I Part or identifying numbers (PIN's).

Dash Number	Number of circuits	Symbol number and enclosure type			Panel type
		Dripproof (DP)	Totally enclosed (TE)	Watertight (WT)	
01	2	2521	2521.1	2521.2	Distribution panel
02	4	2522.2	2522.3	2522.4	
03	6	2523.2	2523.3	2523.4	
04	8	2531.2	2531.3	2531.4	
05	10	2532.2	2532.3	2532.4	
06	12	2533.2	2533.3	2533.4	
11	4	2511	2511.1	2511.2	Distribution panel with (two) NQB-A101 circuit breakers for two-way 100A bus transfer
12	6	2511.3	2511.4	2511.5	
13	8				
14	10	2511.9	2511.10	2511.11	
15	12	2511.12	2511.13	2511.14	
21	4	2512	2512.1	2512.2	Distribution panel with (three) NQB-A101 circuit breakers for three-way 100A bus transfer
22	6	2512.3	2512.4	2512.5	
23	8	2512.6	2512.7	2512.8	
24	10	2512.9	2512.10	2512.11	
25	12				
31	4	2513	2513.1	2513.2	Distribution panel with (two) NQB-A250 circuit breakers for two-way 250A bus transfer
32	6	2513.3	2513.4	2513.5	
33	8	2513.6	2513.7	2513.8	
34	10	2513.9	2513.10	2513.11	
35	12	2513.12	2513.13	2513.14	

Example: The full PIN for an 8-circuit distribution panel with (two) NQB-A101 circuit breakers for two-way bus transfer is:



Source: https://assist.dla.mil -- Downloaded: 202610-19T18:20Z
Check the source to verify that this is the current version before use.

REQUIREMENTS:

Class: 1 - Dripproof (see note 1).
Class: 2 - Totally enclosed (see note 2).
Class: 3 - Watertight (see note 3).
Dimensions and configuration: See figures.
Composition: Steel or aluminum (see note 6).
Current rating: 400 amperes.
Voltage rating: 500 Vac and 250 Vdc.
Short circuit capacity: 100,000 amperes.
Bus bar sizes (minimum): 400 amperes - 1 x 0.250 inch.
Circuit breakers: AQB-A101, NQB-A101, and NQB-A250 (see MIL-C-17361).

NOTES:

1. Class 1 panels with doors shall meet the 45 degree dripproof requirements and panels without doors shall meet the 15 degree dripproof requirements as specified in MIL-STD-108. When used, drip shield dimensions shall be as required to provide the specified degree of enclosure. Panels shall be furnished without doors only when specified in acquisition documents.
2. Class 2 panels shall meet the totally enclosed requirements as specified in MIL-STD-108.
3. Class 3 panels with doors, gaskets, and drain opening shall meet the watertight requirements as specified in MIL-STD-108.
4. A power available light shall be provided for each circuit breaker used for bus transfer switching. The indicator light shall be placed in close proximity to the circuit breaker to which it refers and shall illuminate when power is available.
5. A split bus arrangement shall be provided when specified in the acquisition documents. The current ratings shown will apply to each separate bus grouping.
6. Panels shall be of aluminum construction unless steel is specified in the acquisition document.

Revision letters are not used to denote changes due to the extensiveness of the changes.

Preparing activity:
Navy - SH
(Project 5925-N118-03)

Source: https://assist.dla.mil -- Downloaded: 20261O-19T18:20Z
Check the source to verify that this is the current version before use.