MILITARY SPECIFICATION SHEET

# PANEL, ELECTRICAL, POWER DISTRIBUTION FOR DOUBLE AQB-A250 AND NQB-A250 CIRCUIT BREAKERS, DRIPPROOF, TOTALLY ENCLOSED AND WATERTIGHT

This specification sheet is approved for use by the Naval Sea Systems Command, Department of the Navy, and is available for use by all Departments and Agencies of the Department of Defense.

The complete requirements for acquiring the panel described herein shall consist of this document and the latest issue of MIL-P-23928.





FIGURE 1. Distribution panel for double AQB-A250 and NQB-A250 circuit breakers, totally enclosed and dripproof enclosure (typical).



FSC 5925

Source: https://assist.dla.mil -- Downloaded: 20261O-19T18:21Z
Check the source to verify that this is the current version before use.






FIGURE 2. Distribution panel for double AQB-A250 and NQB-A250 circuit breakers, waterproof enclosure (typical).




Source: https://assist.dla.mil -- Downloaded: 2026-10-19T18:21Z
Check the source to verify that this is the current version before use.




SH 11369

FIGURE 3. Panel and mounting dimensions.




SH 11370

FIGURE 4. Wiring diagram, front view (typical).

TABLE I. Part numbers.

| Dash number | Symbol number and enclosure type | | |
|---|---|---|---|
| | Dripproof (DP) | Totally enclosed (TE) | Watertight (WT) |
| 01 | | | |

Example: The full part number for a double circuit breaker, watertight distribution panel is:

M23928/7-01 WT

- M23928 — Military specification
- 7 — Specification sheet number
- 01 — Dash number (see table I)
- WT — Enclosure type (see table I)



Source: https://assist.dla.mil -- Downloaded: 20260-19T18:21Z
Check the source to verify that this is the current version before use.

REQUIREMENTS:

Class: 1 - Dripproof (see note 1).
Class: 2 - Totally enclosed (see note 2).
Class: 3 - Watertight (see note 3).
Dimensions and configuration: See figures.
Composition: Steel or aluminum (see note 4).
Current rating: 500 amperes (A).
Voltage rating: 500 volts alternating current and 250 volts direct current.
Short circuit capacity: 100,000 A.
Bus bar size (minimum): 1 x 1/4 inch.
Circuit breakers: AQB-A250 and NQB-A250 (see MIL-C-17361).

NOTES:
1. Class 1 panels with doors shall meet the 45 degree dripproof requirements and panels without doors shall meet the 15 degree dripproof requirements as defined by MIL-STD-108. When used, drip shield dimensions shall be as required to provide the specified degree of enclosure. Panels shall be furnished without doors only when specified in acquisition documents..
2. Class 2 panels shall meet the totally enclosed requirements as defined in MIL-STD-108. Panel shall be furnished without doors only when specified in acquisition documents.
3. Class 3 panels with doors, gaskets and drain opening shall meet the watertight requirements as defined in MIL-STD-108.
4. Panels shall be of aluminum construction unless steel is specified in the acquisition document.

Revision letters are not used to denote changes due to the extensiveness of the changes.

Preparing activity:
Navy - SH
(Project 5925-N083-7)



Source: https://assist.dla.mil -- Downloaded: 2026-10-19T18:21Z
Check the source to verify that this is the current version before use.

# STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

INSTRUCTIONS This form is provided to solicit beneficial comments which may improve this document and enhance its use DoD contractors, government activities, manufacturers, vendors, or other prospective users of the document are invited to submit comments to the government Fold on lines on reverse side, staple in corner, and send to preparing activity Attach any pertinent data which may be of use in improving this document. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity. A response will be provided to the submitter, when name and address is provided, within 30 days indicating that the 1426 was received and when any appropriate action on it will be completed.

NOTE This form shall not be used to submit requests for waivers, deviations or clarification of specification requirements on current contracts Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements

DOCUMENT IDENTIFIER *(Number)* AND TITLE

MIL-P-23928/7A

NAME OF ORGANIZATION AND ADDRESS OF SUBMITTER

☐ VENDOR ☐ USER ☐ MANUFACTURER

1 ☐ HAS ANY PART OF THE DOCUMENT CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE? ☐ IS ANY PART OF IT TOO RIGID, RESTRICTIVE, LOOSE OR AMBIGUOUS? PLEASE EXPLAIN BELOW.

A GIVE PARAGRAPH NUMBER AND WORDING

B RECOMMENDED WORDING CHANGE

C REASON FOR RECOMMENDED CHANGE(S)

2 REMARKS

SUBMITTED BY *(Printed or typed name and address — Optional)*

TELEPHONE NO

DATE

DD FORM 1 OCT 76 1426 Replaces edition of 1 Jan 72 which may be used. S/N 0102-LF-001-4260

Source: https://assist.dla.mil -- Downloaded: 202610-19T18:21Z
Check the source to verify that this is the current version before use.

FOLD

POSTAGE AND FEES PAID
DEPARTMENT OF THE NAVY
DoD 316

U.S MAIL

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

Commander

Naval Sea Systems Command (SEA 3112S)
Department of the Navy
Washington, DC 20362

FOLD

Source: https://assist.dla.mil -- Downloaded: 202640-19T18:21Z
Check the source to verify that this is the current version before use.