MIL-B-14563C(AL)
14 July 1983
SUPERSEDING
MIL-B-14563B(WC)
13 September 1972

MILITARY SPECIFICATION

BOOTH, SPRAYING, DRY

(BENCH TYPE WITH LEGS)

This specification is approved for use by the US Army Armament, Munitions and Chemical Command, Department of the Army, and is available for use by all Departments and Agencies of The Department of Defense.

1. SCOPE

1.1 Scope. This specification covers one self supported, dry (not water wash), bench type spray booth incorporating an exhaust unit. The booth is for confining and directing dust, fumes, and overspray when spraying paint or preservatives on parts.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications, standards, and handbooks. Unless otherwise specified, the following specifications, standards, and handbooks of the issue listed in that issue of the Department of Defense Index of Specifications and Standards (DODISS) specified in the solicitation form a part of this specification to the extent specified herein.

SPECIFICATIONS

FEDERAL

CC-M-1807	-	Motor, Alternating Current, Fractional and Integral Horsepower (500 HP and Smaller)
TT-E-489	-	Enamel, Alkyd, Gloss (For Exterior and Interior Surfaces)
TT-P-636	-	Primer Coating, Alkyd, Wood and Ferrous Metal
PPP-B-601	-	Boxes, Wood, Cleated Plywood
PPP-B-621	-	Boxes, Wood, Nailed and Lock Corner
PPP-B-636	-	Boxes, Shipping, Fiberboard
PPP-C-843	-	Cushioning Material, Cellulosic
PPP-T-60	-	Tape, Packaging, Waterproof

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commander, US Army Armament, Munitions and Chemical Command, ATTN: DRSMC-LEE-S (R), Rock Island, IL 61299 by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T03:26Z
Check the source to verify that this is the current version before use.

MILITARY

MIL-P-116	-	Preservation, Methods of
MIL-B-121	-	Barrier Material, Greaseproofed, Waterproofed, Flexible
MIL-E-16298	-	Electric Machines Having Rotating Parts and Associated Repair Parts: Packaging Of

STANDARDS

FEDERAL

FED-STD-H28	-	Screw Thread Standards For Federal Services

MILITARY

MIL-STD-105	-	Sampling Procedures and Tables for Inspection by Attributes
MIL-STD-129	-	Marking For Shipment and Storage
MIL-STD-130	-	Identification Marking of US Military Property
MIL-STD-889	-	Dissimilar Metals
MIL-STD-1186	-	Cushioning, Anchoring, Bracing, Blocking, and Waterproofing; With Appropriate Test Methods

2.1.2 Other Government documents, drawings, and publications. The following other Government documents, drawings, and publications form a paart of this specification to the extent specified herein.

US DEPARTMENT OF LABOR

OSHA 2206 - GENERAL INDUSTRY, OSHA Safety and Health Standards (29 CRF 1910)

2.2 Other publications. The following document(s) form a part of this specification to the extent specified herein. The issues of the documents which are indicated as DOD adopted shall be the issue listed in the current DODISS and the supplement thereto, if applicable.

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA Standard No. 33 - Spray Application

(Application for copies should be addressed to the National Fire Protection Association, Battery March Park, Quincy, MA 02269.)

AMERICAN SOCIETY OF HEATING, REFRIGERATING, AND AIR-CONDITIONING ENGINEERS (ASHRAE)

ASHRAE Handbook and Product Directory

(Application for copies should be addressed to the American Society of Heating, Refrigerating, and Air-conditioning Engineers, Inc., 1791 Tullie Circle, NE, Atlanta, GA 30329.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T03:26Z
Check the source to verify that this is the current version before use.

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

ASTM D3951-82 - Standard Practice for Commercial Packaging

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.)

(Industry association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

2.3 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein, the text of this specification shall take precedence.

3. REQUIREMENTS

3.1 First article. When specified (see 6.2), the contractor shall furnish one complete spray booth for first article inspection. The first article may be either a preproduction model or an initial production item which conforms to the requirements of this specification. In either case, the approved first article and the production items shall be identical and in accordance with the terms of the contract. Approval of the first article shall not relieve the contractor of the responsibility to furnish equipment in accordance with the requirements of this specification.

3.2 Design. The spray booth shall be new and of the latest standard commercial design meeting the performance requirements specified herein. All parts subject to wear, breakage, or distortion shall be accessible for adjustment or repair.

3.2.1 Maintainability. Item configuration and adjustment features shall be designed to reduce maintenance operations to the simplest procedures compatible with a minimum of maintenance skills and common standard maintenance equipment. Instructions for disassembly, repair, adjustment, and reassembly shall be concise and clearly defined.

3.2.2 Interchangeability. All replaceable parts shall be manufactured to such standards as shall permit replacement or adjustment without the need for modification of the parts or the spray booth.

3.2.3 Electrical connections. Connections of conductors and terminal parts shall be of the screw, pressure, or solder type. When soldered connections are used, the connections shall be mechanically secured before soldering. Rosin base fluxes only shall be used in soldering operations. Connections to screw type terminals shall be mechanically secured, and have a means to prevent loss of tightness.

3.2.4 Safety provisions. Protection against electrical shock and mechanical parts that could be hazardous to the operator shall be incorporated. When special safety devices are required, they shall be as specified by the procuring activity (see 6.2).

3.2.5 Threads. All threaded parts of the spray booth shall conform to FED-STD-H28 and the applicable Detailed Standard section referenced therein.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T03:26Z
Check the source to verify that this is the current version before use.

3.2.6 Material. Materials not specifically designated herein or in the contract shall be of a quality commensurate with commercial practice within the producing industry. When dissimilar metals are used in contact with each other, suitable protection against galvanic corrosion shall be applied in accordance with MIL-STD-889.

3.2.6.1 Reclaimed materials. The contractor is encouraged to use reclaimed materials for fabricating new parts without jeopardizing the chemical and physical properties, design integrity, and intent of the materials originally selected or specified. The reclaimed materials shall have been reprocessed, remanufactured, or recycled in a manner that shall restore them to the same chemical composition and physical properties as the materials originally selected for use. It shall not be permissible to use reclaimed parts as is, or rebuilt from scrap or other used equipment.

3.3 Construction. The spray booth shall be complete so that, when installed, it can be used for the operations specified herein. Construction shall comply with the requirements of OSHA 2206.

3.3.1 Welding, brazing, and soldering. Welding, brazing, and soldering shall be of a quality which shall sustain the performance requirements of the welded, brazed, or soldered part. These operations, however, shall not be employed as repair measures for defective parts.

3.3.2 Fastening devices. All screws, pins, bolts, and similar locking parts shall be installed with means for preventing loss of tightness. All such parts that are subject to removal or adjustment shall not be swaged, peened, staked, or otherwise permanently deformed.

3.4 Performance. The spray booth shall confine paint fumes and spray dust while providing protection to the operator.

3.5 Component parts. The spray booth shall consist of the following principal component parts.

3.5.1 Booth. The booth shall be fabricated of sheet steel of not less than a thickness of 0.0478 inches reinforced to provide a rigid and sturdy unit. The inside surface of the booth shall be smooth to prevent pocketing of residue and to facilitate draft within the working area. The air velocity at any point in the frontal area of the booth shall be not less than 150 feet per minute (fpm). Filters shall be Class 2, dry filter, listed by Underwriters Laboratory and Factory Mutual approved. The filters shall be removable for replacement. The dimensions of the frontal opening of the booth shall not be less than 42 inches or more than 48 inches high. The booth shall provide a minimum working depth of 23 inches measured from the closest point on the filters to the front edge of the booth.

3.5.1.1 Exhaust opening. Unless otherwise specified (see 6.2), the booth shall have an exhaust opening in the top panel. The exhaust opening shall not be less than 17 inches in diameter.

3.5.2 Legs. The spray booth shall be fitted with four legs fabricated of sheet metal, angle iron, or other suitable material to securely support the booth. The height of the legs shall be not less than 30 inches nor more than 32 inches.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T03:26Z
Check the source to verify that this is the current version before use.

3.5.3 Exhaust fan. The spray booth shall incorporate an exhaust fan for directing all dust and fumes out the exhaust system. The exhaust fan shall be not less than 16 inches in diameter. The fan blades shall be constructed of non-sparking, non-corrosive material and shall be assembled on anti-friction bearings. The blades shall be balanced to assure vibration-free operation, and shall be mounted on a shaft of adequate size to maintain alignment when the fan is under load. Clearance shall be maintained between the fan blades and fan casing to prevent fire by friction. Necessary allowance shall be provided for expansion and load on the fan. The exhaust fan unit shall be capable of delivering no less than an air volume of 2,400 cubic feet per minute (cfm) against a static pressure equivalent to 1/3 inch water gage. The exhaust fan unit shall be removable and accessible for cleaning and replacement of parts.

3.5.3.1 Exhaust fan mounting. Unless otherwise specified (see 6.2), the exhaust fan shall be located and mounted in the exhaust duct at least two duct diameters from the duct entrance or other air-flow disturbances.

3.5.4 Drive. The drive unit shall incorporate pulleys on the exhaust fan and motor. A standard V-belt shall be provided for power transmission. A movable motor base, or other suitable means, shall be provided to furnish an adjustment arrangement for V-belt tension, with a locking device to securely hold the pulley drive when the desired belt tension is attained. The fan belt and fan pulley shall be completely enclosed, by means of a suitable metal housing, so as to be protected from exhaust gases. The motor drive pulley shall be outside the exhaust duct and spray booth.

3.5.5 Exhaust duct. An exhaust duct, not less than 17 inches in diameter and not less than three feet long, shall be provided. The exhaust duct shall embody an access door for cleaning the duct. The exhaust duct shall be fabricated of sheet metal of not less than a thickness of 0.0329 inches. The construction of the exhaust duct shall be such as to totally confine exhaust fumes or vapors.

3.6 Electrical components.

3.6.1 Motor. Unless otherwise specified (see 6.2), the motor shall be not less than 1/2 horsepower at 1,750 revolutions per minute. It shall operate from a power of 115 volts, 60 hertz, single phase current. The motor shall be an induction squirrel-cage type, totally enclosed, conforming to CC-M-1807, Grade B insulation or better. The motor shall be mounted on a suitable base, which shall be located outside of the exhaust duct and booth. The motor and drive shall be sized so that neither are overloaded at any operating pressure, from blocked flow to wide open volume, when handling standard air at .075 pounds per cubic foot density.

3.6.2 Switch. A motor switch shall be provided. The switch shall be completely enclosed and explosion proof. The switch shall be located and mounted outside the spray booth and shall be readily accessible to the operator without the necessity of a switch rod.

3.7 Fire protection. Unless otherwise specified (see 6.2), the spray booth shall conform to the fire protection requirements of NFPA Standard Number 33.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T03:26Z
Check the source to verify that this is the current version before use.

3.8 Dimensions. The over-all dimensions of the spray booth, less the exhaust fan unit and exhaust duct, shall not exceed 80 inches ± six inches, 52 inches in width, and 62 inches in depth.

3.9 Painting. Unless otherwise specified (see 6.2), the spray booth shall be painted and finished in accordance with standard commercial practice provided the following minimum criteria are met or exceeded: all surfaces to be painted shall have been cleaned to be free of all foreign matter detrimental to painting, and at least one coat of primer and one coat of enamel, or equivalent, applied.

3.10 Identification marking. The spray booth shall be marked for identification in accordance with MIL-STD-130 and, unless otherwise specified (see 6.2), shall include the National Stock Number.

3.11 Workmanship. Standards of workmanship shall assure that the spray booth shall have the stability and efficient operating characteristics found in standard commercial items and as specified in Section 3 herein.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.2 Classification of inspection. The inspection requirements specified herein are classified as follows:

(a) First article inspection (see 4.3).
(b) Quality conformance inspection (see 4.4).

4.3 First article inspection. First article inspection shall be applied to the preproduction model or initial production item (see 3.1). Unless otherwise specified (see 6.2), first article inspection shall consist of the examination in 4.5 and all tests under 4.6. Failure of the first article to pass the examination or any of the tests shall be cause for rejection.

4.4 Quality conformance inspection. Unless otherwise specified (see 6.2), quality conformance inspection shall be applied to production items offered for acceptance under the contract. Unless otherwise specified (see 6.2), quality conformance inspection shall consist of (a) through (c) below. Failure of any item to pass an examination or test shall be cause for rejection of the item.

(a) Product examination (see 4.5).
(b) Tests (see 4.6).
(c) Packaging inspection (see 4.7).

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T03:26Z
Check the source to verify that this is the current version before use.

4.4.1 Sampling. When required (see 6.2), sampling for quality conformance inspection shall be as specified in MIL-STD-105 at the Inspection Level and Acceptable Quality Level (AQL) specified in the contract. For packing inspection (see 4.7), special inspection level S-4 and an AQL of 4.0 percent defective shall be used.

4.5 Product examination. Each complete spray booth shall be examined to determine compliance with the requirements in Section 3. As a minimum, the following product characteristics shall be examined:

CHARACTERISTICS	REQUIREMENT PARAGRAPH
Interchangeability not as specified	3.2.2
Electrical connections not as specified	3.2.3
Safety provisions/devices not as specified	3.2.4
Thread defects	3.2.5
Materials not as specified	3.2.6 and 3.2.6.1
Construction defects	3.3
Welding, brazing, and soldering not as specified	3.3.1
Fastening devices not as specified	3.3.2
Booth not as specified	3.5.1
Exhaust opening not as specified	3.5.1.1
Legs not as specified	3.5.2
Exhaust fan not as specified	3.5.3
Exhaust fan mounting not as specified	3.5.3.1
Drive not as specified	3.5.4
Exhaust duct not as specified	3.5.5
Motor characteristics not as specified	3.6.1
Switch not as specified	3.6.2
Spray booth not in compliance with NFPA requirements	3.7
Overall dimensions not as specified	3.8
Painting not as specified	3.9
Product identification not as specified	3.10
Workmanship not as specified	3.11

4.6 Tests.

4.6.1 Operational test. The booth shall be set up to simulate actual operating conditions. A visual performance (smoke) test will be performed to insure that the booth is capable of confining contaminants. Test will consist of (1) Placing the booth into operation, (2) Positioning a 30 second smoke candle onto work surface of the booth, and (3) Lighting smoke candle and observing for escape of smoke from the booth. The booth shall then be subjected to one hour of continuous operation, using a four to five cfm spray gun while spraying enamel conforming to the requirements of TT-E-489. During this test, adequacy of fume dissipation and exhaust disposal, fan and motor operation, and construction shall be checked for compliance with the requirements specified herein (see 3.4). At the conclusion of the test, the booth shall be inspected for accessibility for cleaning and maintenance and for evidence of damage and defects.

4.6.2 Exhaust fan air delivery test. The exhaust fan shall be tested for volume of air delivered in accordance with the Standard Test Code for Axial Fans, which was approved and adopted by the American Society of Heating, Refrigerating, and Air Conditioning Engineers. The exhaust fan shall provide a

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T03:26Z
Check the source to verify that this is the current version before use.

minimum air volume of 2,400 cfm at a static pressure of 1/3 inch water gage (see 3.5.3). Certification of air handling capacity from previous rating tests, in accordance with the above code on an identical fan series, shall be acceptable in lieu of this test.

4.6.3 Facial velocity test. The complete spray booth shall be installed with 10 feet of exhaust duct. With the exhaust fan in operation, the air velocity shall be measured, across the plane of the booth frontal area at a minimum of 16 points, with an anemometer or velometer having an accuracy within ±five fpm. The velocity readings shall be observed to determine compliance with 3.5.1

4.7 Packaging inspection. Packaging inspection shall be conducted before and after packaging to determine compliance with the requirements of Section 5.

5. PACKAGING

5.1 Preservation. Preservation shall be Level A or Industrial, as specified (see 6.2).

5.1.1 Level A.

5.1.1.1 Cleaning. Spray booths shall be cleaned in accordance with MIL-P-116, process C-1.

5.1.1.2 Drying. Spray booths shall be dried in accordance with any applicable process of MIL-P-116.

5.1.1.3 Preservative applications. Non-critical ferrous unpainted surfaces shall be preserved with P-1 conforming to MIL-P-116. Critical ferrous unpainted surfaces shall be preserved with P-2 conforming to MIL-P-116. Surfaces preserved with P-2, which are subject to being disturbed during shipping and handling, shall be wrapped with MIL-P-121, grade A.

5.1.1.4 Unit packs. Unless otherwise specified (see 6.2), each spray booth shall be individually unit-packed in accordance with the methods of MIL-P-116 designated herein, insuring compliance with the applicable requirements of that specification.

5.1.1.4.1 Disassembly. Spray booths may be shipped disassembled in accordance with MIL-STD-1186. Assembly instructions shall be provided with each booth.

5.1.1.4.2 Drive belts. Drive belts shall be removed or released from tension. Removed belts shall be packaged Method III, in accordance with MIL-P-116. The grooves of the metal pullies shall be coated with primer conforming to TT-P-636.

5.1.1.4.3 Electrical equipment. The electrical motor shall be packaged in accordance with level A requirements of MIL-E-16298 and the applicable subparagraphs for assembled machines. Coil the power cord to a minimum safe diameter and secure to the basic unit with cotton tape or twine. Cover the plug

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T03:26Z
Check the source to verify that this is the current version before use.

with barrier material conforming to MIL-B-121, grade A. The motor switch shall be covered with uncompressed, one-inch thick, cushioning material conforming to PPP-C-843, type II. Cushioning and barrier material shall be secured with tape conforming to PPP-T-60, type IV.

5.1.1.5 Consolidated packaging. Disassembled parts and technical publications shall be cushioned with material conforming to PPP-C-843, type II, and placed in a snug-fitting fiberboard box conforming to PPP-B-636, class weather-resistant. The box shall be secured inside the shipping container in a manner to restrict movement.

5.1.2 Industrial. The preserved spray booths shall be packaged in accordance with the requirements of ASTM D3951-82.

5.2 Packing. Packing shall be Level A or Industrial, as specified (see 6.2).

5.2.1 Level A. The spray booths shall be packed in a container conforming to PPP-B-601, overseas type, or PPP-B-121, class 2. Arrangement of contents, blocking, bracing, and cushioning shall be in accordance with MIL-STD-1186. Containers shall be closed and strapped in accordance with the container specification and the appendix therein.

5.2.2 Industrial. The spray booths shall be packed in accordance with the requirements of ASTM D3951-82.

5.3 Marking.

5.3.1 Level A. In addition to any special or other identification marking required by the contract (see 6.2), each intermediate and exterior container and each unitized load shall be marked in accordance with MIL-STD-129.

5.3.2 Industrial. Industrial marking shall be in accordance with the requirements of ASTM D3951-82.

6. NOTES

6.1 Intended use. The bench type spray booths covered by this specification are used to confine, restrict, and direct dust, fumes, and overspray when spraying items with paint or preservatives. The booths are used in field and maintenance shops.

6.2 Acquisition requirements. Acquisition documents should specify the following:

(a) Title, number, and date of this specification.
(b) First article when required (see 3.1).
(c) Special safety devices when required (3.2.4).
(d) Exhaust opening if different (see 3.5.1.1).
(e) Exhaust fan mounting if different (see 3.5.3.1).
(f) Motor capacity if different (see 3.6.1).
(g) Fire protection requirements if different (see 3.7).
(h) Painting if different (see 3.9).
(i) Product marking if different (see 3.10).

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T03:26Z
Check the source to verify that this is the current version before use.

(j) First article inspection if different (see 4.3).
(k) Quality conformance inspection if different (see 4.4).
(l) Sampling when required (see 4.4.1).
(m) Selection of applicable level of preservation, packing, and marking (see 5.1, 5.2, and 5.3).
(n) Unit packs if different (see 5.1.1.4).
(o) Any special packaging marking required (see 5.3.1).

6.3 Safety and health requirements. In order that equipment integrated into the user's operational environment will comply with OSHA limitations and controls of noise levels, radiation, electromagnetic emissions, noxious vapors, heat, etc., as applicable, specific requirements concerning such points of operation, and other health and safety requirements, should be specified by the user.

6.4 Changes from previous issue. Asterisks are not used in this revision to identify changes with respect to the previous issue due to the extensiveness of the changes.

Custodian:

Army - AL

Review activity:

Army - SM

Preparing activity:

Army - AL

Project Number 4940-A458

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T03:26Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

DEPARTMENT OF THE ARMY

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO. 12062 WASHINGTON D. C.

POSTAGE WILL BE PAID BY THE DEPARTMENT OF THE ARMY

Commander US Army Armament Materiel Readiness Command
ATTN: DRSAR-LEE-S
Rock Island, IL 61299

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T03:26Z
Check the source to verify that this is the current version before use.

(TO DETACH THIS FORM, CUT ALONG THIS LINE.)

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
b. ADDRESS *(Street, City, State, ZIP Code)*	☐ USER
	☐ MANUFACTURER
	☐ OTHER *(Specify)*: _____

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T03:26Z
Check the source to verify that this is the current version before use.