INCH-POUND
A-A-60056
27 November 2023

COMMERCIAL ITEM DESCRIPTION

SPILL CONTAINMENT UNIT, All TERRAIN BERMS

The General Services Administration has authorized the use of this commercial Item description for all federal agencies.

1. SCOPE. This commercial item description (CID) describes three sizes of the All-Terrain Berm (ATB), a portable secondary containment system designed to be used with large primary fluid storage devices that do not have integral secondary containment capabilities.

2. CLASSIFICATION. The ATB shall be of the following sizes. The size of the ATB to be furnished shall be as specified in the acquisition documents.

Size A – 10,000 gallons.

Size B – 50,000 gallons.

Size C – 210,000 gallons.

3. SALIENT CHARACTERISTICS.

3.1 ATB description. The All-Terrain Berm (ATB) is a portable secondary containment system for fuel storage bladders that do not have integral secondary containment capabilities. The ATB is specifically designed to contain a catastrophic spill from a primary fuel containment bladder to reclaim and reuse. Three size classifications interface with existing 10K, 50K, and 210K Collapsible Fuel Tanks (CFTs) for operation in extreme terrains and climates. A structurally supported liner system allows for temporary applications in austere locations that do not allow construction of permanent containment areas or earthen berms.

3.2 Capabilities. The ATBs shall be used in conjunction with the 10K, 50K and 210K Collapsible Fuel Tank (CFT) assemblies under Military Specification MIL-PRF-32233C. The ATB shall protect the surrounding environment from liquid spills that may contaminate the soil or water supply. The ATB shall be a structurally supported liner system that is transportable to emergency, military, or temporary applications that do not allow permanent containment areas or earthen berms to be constructed. The ATB shall be designed for ease of setup and teardown for reconstitution, and capable of withstanding multiple assembly/disassembly operations.

Beneficial comments, recommendations, additions, deletions, clarifications, etc., and any data that may improve this document should be sent to: AFLCMC/EZSS, 2145 Monahan Way, Area B, Bldg 28, Wright-Patterson AFB, OH 45433 or email engineering.standards@us.af.mil. Since contact information can change, you should verify the currency of this information using the ASSIST Online database at https://assist.dla.mil.

AMSC N/A FSC 4235

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:33Z
Check the source to verify that this is the current version before use.

3.3 Service life. The ATB shall have a service life of 8 years, when exposed to UV environments.

3.4 Design and construction. The design shall promote cost effective, life-cycle sustainability while satisfying system performance requirements. It shall be designed and constructed to withstand the strains and other conditions incident to shipping, storage, installation, and service. It shall be weatherproof.

3.4.1 Capacity. The ATB classifications shall have net volumes of not less than 10,000 gallons (size A), 50,000 gallons (size B), and 210,000 gallons (size C). The ATB shall have a fluid containment liner at 36 inches tall forming the containment volume. The frame/liner system shall be able to withstand rupture of a fuel bladder and have an inward directed feature extending at least 12 inches above the containment height. The ATB shall be sufficient to meet the following objectives:

TABLE I. Size, dimensions, and capacity.

Size	Dimensions W x L x H	Capacity
10K	21 feet x 21 feet x 3 feet	19,478 gallons
50K	36 feet x 80 feet x 3 feet	68,532 gallons
210K	100 feet x100 feet x 3 feet	231,000 gallons

3.4.2 Materials. Materials shall not deteriorate to an unserviceable condition during the service life of the ATB when exposed to sunlight, weather, or normally encountered operational conditions.

3.4.3 Liner. The liner shall be constructed of a heavy-duty nylon fabric with a nominal weight of 13 ounces/yard^2 and coated with a polyester-based polyurethane for a nominal thickness of 35 millimeters.

3.4.3.1 Drainage. Drain fittings shall be provided and located to effect maximum drainage of accumulated water from the ATB back to the soil without the release of petroleum products. Drain fittings shall be located near the bottom corners of the ATB. The minimum size of the drain fittings shall be 2 inches.

3.4.3.2 Color. The color of the liner shall be tan IAW MS 446.

3.4.4 Lifting straps. Two lifting straps shall be provided and packaged in position with the folded ATB to allow lifting without damage from the shipping crate.

3.4.5 Liner underlay. The ATB shall come with an underlayment that will provide protection for the bottom on the ATB for sites that are located on rough terrains, concrete, asphalt, and other conditions that would cause tears of the liner.

3.4.6 Entrance Ladder. The ATB shall have an entrance ladder to allow members entrance and egress to manually place the bladders inside the berm. The ladder shall be of sufficient size to prevent it from resting on the ATB side surface and shall have feet with sufficient weight distribution to prevent puncture of the ATB bottom surface.

3.4.7 Liner support. The liner shall have a collapsible aluminum A-frame support system. The combined A-frame supports, liner, and ground tarp form a dike containment in the event of catastrophic failure of the bladder within the ATB. The supports shall be corrosion resistant and light enough to be carried by a single individual and shall be able to prevent unnecessary damage

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:33Z
Check the source to verify that this is the current version before use.

if resting on the liner's underlay. The supports shall allow sandbags to rest on it during high winds or inclement weather.

3.4.8 Tripod. The ATB shall come with 2 tripod devices that will prevent the issue and receipt hoses from resting on top of the berm liner. Each tripod shall have the capability to hold two 6-inch hoses. The tripods shall be developed for ease of set up and operation.

3.4.9 Shipping Crates. Each ATB shall be shipped inside two plastic crates that shall be used for long term storage in inclement weather and transport with severe handling conditions. Crates shall include reliefs on the bottoms to allow access for two 8-inch-wide forklift tines for lifting. The liner, underlay, and straps shall be shipped and stored in one crate. The A-frames and other accessories shall be shipped and stored in the second crate.

3.4.10 Markings. All markings shall be in accordance with MIL-STD-130. Markings shall be permanently adhered to outside of the liner surface and to the support system accessories with 1-inch-high block letters unless prohibited by the available space. In such cases, the markings shall be the largest size possible. Markings, Information/Caution shall be Lusterless Black, Color Number 37038 of SAE-AMS-STD-595, and Markings, Warning/Danger shall be Lusterless Red, Color Number 31136 of SAE-AMS-STD-595. Markings shall be applied to all four sides of the outside of the liner and shall include the appropriate placement of the support frames and fire safety cautions and warnings.

3.4.10.1 Identification markings. Identification markings in accordance with MIL-STD-130 shall be permanently adhered to the outside of the liner surface in a readily accessible location. The identification markings shall contain the following information:

a. ATB nomenclature and size.

b. Manufacturer's part number.

c. Manufacturer's serial number.

d. Date of manufacture.

e. Manufacturer's name, address, and phone number.

f. Commercial and Government Entity (CAGE) code.

g. National Stock Number (NSN).

The ATB shall have Unique Identification (UID) (also known as Item Unique Identification (IUID)) information permanently adhered on or near the respective identification markings in accordance with MIL-STD-130. UID information shall be included as both a 2D Data Matrix and human readable markings.

3.4.11 Environment, Safety, and Occupational Health (ESOH).

3.4.11.1 Hazardous material. The design shall minimize, and control hazards associated with the inclusion or use of hazardous or toxic materials and the generation of toxic or noxious gases. The ATB shall not generate or use Class I or Class II Ozone Depleting Substances (ODS) during operation, maintenance, or disposal. Class I ODS and hazardous materials shall not be used in any system, component, or process. The ATB shall not contain or use either hexavalent chromium or cadmium without written approval by the procuring activity. Hazardous materials are defined in AFMAN32-7002; Class I and Class II ODS are defined in 40CFR82.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:33Z
Check the source to verify that this is the current version before use.

3.4.11.2 Component protection. All space in which work is performed during operation, service, and maintenance shall be free of hazardous protrusions, sharp edges, or other features which may cause injury to personnel.

3.4.11.3 Foreign object damage (FOD). All loose metal parts, such as pins or connector covers, shall be securely attached to the ATB with wire ropes or chains. "Dog tag" style beaded chains shall not be provided.

3.4.11.4 Electrostatic discharge (ESD). The design of the ATB shall preclude equipment damage due to ESD, protect personnel from electrical shock due to static charging, and prevent ignition of explosive atmospheres due to sparking.

3.4.12 Human systems integration. The ATB shall be designed in accordance with MIL-STD-1472 for ease of operation, inspection, and maintenance.

3.4.13 Fastening devices. All screws, bolts, nuts, pins, and other fastening devices shall be properly designed, manufactured, and installed with adequate means of preventing loss of torque or adjustment. Cotter pins, lock washers, or nylon patches shall not be used for this purpose, except for the attachment of trim items or as provided in commercial (see 7.3.1) components. Tapped threads shall have a minimum thread engagement in accordance with Table II.

TABLE II. Minimum thread engagement.

Material	Minimum Thread Engagement
Steel	1.0 times the nominal fastener diameter
Cast iron, brass, or bronze	1.5 times the nominal fastener diameter
Aluminum, zinc, or plastic	2.0 times the nominal fastener diameter

3.4.14 Welders and welding. Welding procedures shall be in accordance with a nationally recognized welding code. The surface parts to be welded shall be free from rust, scale, paint, grease, and other foreign matter. Welds shall be of sufficient size and shape to develop the full strength of the welded parts. Welds shall transmit stress without cracking or permanent distortion when the parts connected by the welds are subjected to test, proof, and service loadings.

3.5 Environmental conditions. The ATB shall operate in an unsheltered environment during weather conditions encountered in commercial applications.

3.5.1 Operating temperature range. The ATB shall be capable of operating in ambient temperatures ranging from -40 °F to 125 °F.

3.5.2 Storage temperature range. The ATB shall be capable of being stored in ambient temperatures ranging from -65 °F to 160 °F.

3.5.3 Precipitation.

3.5.3.1 Rain. The ATB shall be capable of storage and operation during rainfall of 5-inches per hour for three consecutive hours and 10-inches per hour for 10 consecutive minutes, with winds of up to 35 knots; and with 6-inches of rain per hour impinging on the ATB at angles from vertical to 45 ° for 30 consecutive minutes.

3.5.3.2 Snow. The ATB shall be capable of storage and operation during accretion of wet snow up to 2-inches per hour for at least 12 hours.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:33Z
Check the source to verify that this is the current version before use.

3.5.3.3 Ice. The ATB shall be capable of storage and operation with ice accretion up to 1.5-inches on exposed horizontal surfaces.

3.5.4 Solar radiation. The ATB shall not be adversely affected by full time exposure to solar radiation, such as those conditions encountered in desert environments.

3.5.5 Fungus. All materials used in the ATB shall be fungus resistant or shall be suitably treated to resist fungus. Materials treated for fungus resistance shall retain their original physical properties, shall not present toxic hazards, and treatment shall last for the entire service life of the part. The ATB shall be suitable for operation and storage in conditions encountered in a tropical environment.

3.5.6 Salt fog. The ATB shall be capable of storage and operation in high temperature, high humidity, salt laden, seacoast environments without damage or deterioration of performance.

3.5.7 Sand and dust. The ATB shall be capable of storage and operation during exposure to wind-blown sand or dust without damage or deterioration of performance.

3.6 Dimensions. Overall weight and dimensions in air transport configuration (see 3.7.2) shall not exceed the values in Table III:

TABLE III. Shipping dimensions and weight.

ATB Size (gallons)	Length (feet)	Width (Feet)	Height (feet)	Weight (pounds)
10,000	70 ft	48 ft	34 inches	668 lbs.
50,000	70 ft	48 ft	34 inches	1860 lbs.
210,000	70 ft	48 ft	34 inches	2108lbs.

3.7 Transportability.

3.7.1 Surface transportability. The ATB shall be transportable within shipping crates (see 3.4.9) via all modes of surface shipment (highway, rail, and water) in accordance with MIL-STD-1366 and shall be capable of withstanding the mechanical shock and vibration characteristics of highway, rail, and water transport, except that design for rail impact testing is not required.

3.7.2 Air transportability. The ATB shall be transportable within shipping crates (see 3.4.9) on airframes, primarily C-130 and C-17. Each ATB size shall fit on a standard 463L pallet with dimensions 104 inches length x 84 inches width. Maximum shipment height is 96 inches. If necessary, an additional 463L may be utilized.

3.8 Inspection. The ATB shall only require periodic visual inspection for damage or leaks.

3.9 Maintenance. The ATB shall be provided with a repair kit for minor field repairs such as cuts, tears, and punctures resulting from normal use.

3.10 Special tools. The design of the item shall minimize the requirement for special tools (see 7.3.2). All special tools shall be provided with, and stored on, the ATB.

3.11 Workmanship. The ATB, including all parts and accessories, shall be constructed and finished in a thoroughly workmanlike manner. Workmanship objectives shall include freedom from blemishes, defects, burrs and sharp corners and edges; accuracy of dimensions, surface finish, and radii of fillets; thoroughness of welding, painting, and riveting; marking of parts and assemblies; and proper alignment of parts and tightness of assembly fasteners.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:33Z
Check the source to verify that this is the current version before use.

3.11.1 Bolted connections. Bolt holes shall be accurately punched or drilled and shall be deburred. Threaded fasteners shall be tight and shall not work loose during testing or service usage.

3.11.2 Riveted connections. Rivet holes shall be accurately punched or drilled and shall be deburred. Rivets shall be driven with pressure tools and shall completely fill the holes. Rivet heads shall be full, neatly made, concentric with the rivet holes, and in full contact with the surface of the component.

3.11.3 Cleaning. The ATB shall be thoroughly cleaned. Loose, spattered, or excess solder; welding slag; stray bolts, nuts, and washers; rust; metal particles; pipe compound; and other foreign matter shall be removed during and after final assembly.

3.12 Training materials. The ATB shall be provided with training materials that provide guides, including video and detailed graphics on step-by-step instructions for set-up, tear-down, maintenance, and other requirements for the ATB.

3.13 Technical manual. The ATB shall be provided with a technical manual with individual sections that address operations, maintenance, and illustrated parts breakdown with stock listing of all parts, consumables and equipment items associated with the ATB.

4. REGULATORY REQUIREMENTS.

4.1 Recycled, recovered, environmentally preferable, or biobased materials. Recycled, recovered, environmentally preferable, or biobased materials should be used to the maximum extent possible, provided that the material meets or exceeds the operational and maintenance requirements, and promotes economically advantageous life cycle costs. The offeror/contractor is encouraged to use recovered materials to the maximum extent practicable, in accordance with 23.403 of the Federal Acquisition Regulation (FAR). However, used, rebuilt, or refurbished items shall not be provided.

4.2 Green Procurement Program. Green Procurement Program (GPP) is a mandatory federal acquisition program that focuses on the purchase and use of environmentally preferable products and services. GPP requirements apply to all acquisitions using appropriated funds, including services and new requirements. FAR 23.404(b) applies and states the GPP requires 100% of EPA designated product purchase that are included in the Comprehensive Procurement Guidelines list that contains recovered materials, unless the item cannot be acquired: a) competitively within a reasonable timeframe; b) meet appropriate performance standards, or c) at a reasonable price. The prime contractor is responsible for ensuring that all subcontractors comply with this requirement.

5. PRODUCT CONFORMANCE.

5.1 Product Conformance.
The products provided shall meet the salient characteristics of this Commercial Item Description, conform to the producer's own drawings, specifications, standards, and quality assurance practices, and be the same product offered for sale in the commercial marketplace. The government reserves the right to require proof of such conformance.

5.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

a. First production inspection (see 5.3).

b. Conformance inspection (see 5.4).

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:33Z
Check the source to verify that this is the current version before use.

5.3 First production inspection. The first production ATB shall be subjected to the analyses, demonstrations, examinations, and tests described in 5.5.1 through 5.6.9 The contractor shall provide or arrange for all test equipment and facilities. The compatibility test shall be performed after successful completion of all other portions of the first production inspection.

5.4 Conformance inspection. Each production ATB shall be subjected to the examination described in 5.5.1.

5.5 Inspection requirements.

5.5.1 General inspection requirements. Apparatus used in conjunction with the inspections specified herein shall be laboratory precision type, calibrated at proper intervals to ensure laboratory accuracy.

5.5.2 Data. During all testing specified herein, at least the following data, unless not applicable, shall be recorded at intervals not to exceed 30 minutes. Additional data or shorter intervals shall be provided as appropriate for any specific test.

a. Date.

b. Time started.

c. Time finished.

d. Ambient temperature.

e. Ambient humidity.

5.5.3 Test rejection criteria. Throughout all tests specified herein, the ATB shall be closely observed for the following conditions, which shall be cause for rejection.

Failure to conform to design or performance requirements specified herein.

a. Any spillage or leakage of any liquid.

b. Thermal or structural failure of any component, including permanent deformation, or evidence of impending failure.

c. Evidence of excessive wear. If excessive wear is suspected, the original equipment manufacturers (OEM) specifications or tolerances shall be utilized for making a determination.

d. Evidence of corrosion or deterioration.

e. Misalignment of components.

f. Conditions that present a safety hazard to personnel during operation, servicing, or maintenance.

5.6 Test methods.

5.6.1 Examination of product. Each ATB shall be examined to verify compliance with the requirements herein prior to accomplishing any other demonstrations or tests listed in 5.6.9 A contractor-generated, Government-approved checklist (part of the test procedure) shall be used to identify each requirement not verified by an analysis, certification, demonstration, or test, and shall be used to document the examination results. Particular attention shall be given to materials, workmanship, dimensions, surface finishes, protective coatings and sealants and their application,

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:33Z
Check the source to verify that this is the current version before use.

welding, fastening, and markings. Proper operation of each ATB function shall be verified. Certifications and analyses shall be provided in accordance with Table IV. Each production ATB shall be inspected to a Government-approved reduced version of the checklist.

TABLE IV. Certifications and analyses.

Paragraph	Required Certifications
3.3 Service life.	Contractor certification.
3.4 Design and construction.	
3.4.1 Capacity.	Contractor certification.
3.4.2 Materials.	Contractor certification.
3.4.3 Liner.	Contractor certification.
3.4.11 ESOH.	
3.4.11.1 Hazardous material.	Contractor certification.
3.4.11.4 Electrostatic discharge (ESD).	Contractor certification.
3.4.12 Human systems integration.	Contractor certification.
3.5 Environmental conditions.	
3.5.1 Operating temperature range.	Contractor certification.
3.5.2 Storage temperature range.	Contractor certification.
3.5.3 Precipitation.	
3.5.3.1 Rain.	Contractor certification.
3.5.3.2 Snow.	Contractor certification.
3.5.3.3 Ice.	Contractor certification.
3.5.4 Solar radiation.	Contractor certification.
3.5.5 Fungus.	Contractor certification.
3.5.6 Salt fog.	Contractor certification.
3.5.7 Sand and dust.	Contractor certification.
3.7 Transportability.	
3.7.1 Surface transportability.	Contractor certification.
3.7.2 Air transportability.	Contractor certification.

5.6.2 Design and construction inspections and tests.

5.6.2.1 Liner. The first production ATB shall be inspected for the specified liner in compliance with the requirements of 3.4.3.

5.6.2.1.1 Drainage. The first production ATB shall be inspected for the specified drain fittings located near the bottom corners of the ATB, in compliance with the requirements of 3.4.3.1.

5.6.2.1.2 Color. The first production ATB shall be inspected for the specified liner color, in compliance with the requirements of 3.4.3.2.

5.6.2.2 Lifting straps. Each first production ATB classification shall be inspected in shipping configuration for the specified liner lifting straps and tested by lifting the liner from shipping crate by forklift, in compliance with the requirements of 3.4.4.

5.6.2.3 Liner underlay. The first production ATB shall be inspected for the specified liner underlay, in compliance with the requirements of 3.4.5.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:33Z
Check the source to verify that this is the current version before use.

5.6.2.4 Entrance Ladder. The first production ATB shall be inspected for the specified entrance ladder, in compliance with the requirements of 3.4.6.

5.6.2.5 Liner support. The first production ATB shall be inspected for the specified collapsible aluminum A-frame support system, in compliance with the requirements of 3.4.7.

5.6.2.5.1 Stakes. The first production ATB shall be inspected for the specified stakes, A frame support members.

5.6.2.6 Tripod. The first production ATB shall be inspected for the specified tripod devices, in compliance with the requirements of 3.4.8.

5.6.2.7 Shipping Crates. The first production ATB classification shall be inspected for the specified plastic shipping crates, in compliance with the requirements of 3.4.9.

5.6.2.8 Markings. The first production ATB shall be inspected for the specified markings, in compliance with the requirements of 3.4.10.

5.6.2.8.1 Identification markings. The first production ATB shall be inspected for the specified identification markings and IUID, in compliance with the requirements of 3.4.10.1.

5.6.3 ESOH inspections.

5.6.3.1 Component protection. The first production ATB shall be inspected for compliance with the requirements of 3.4.11.2.

5.6.3.2 Foreign object damage (FOD). The first production ATB shall be inspected for compliance with the requirements of 3.4.11.3.

5.6.3.3 Electrostatic discharge (ESD). The first production ATB shall be inspected for a grounding system in compliance with the requirement of 3.4.11.4.

5.6.4 Fastening devices. The first production ATB shall be inspected for compliance with the requirements of 3.4.13.

5.6.5 Welders and welding. The first production ATB shall be inspected for compliance with the requirements of 3.4.14.

5.6.6 Dimensions and weight. Each first production ATB classification shall be measured and weighed in shipping configuration, in compliance with the requirements of 3.6.

5.6.7 Workmanship. The first production ATB shall be inspected for compliance with the requirements of 3.11 through 3.11.3.

5.6.8 Training materials. The training materials shall be reviewed and approved prior to acceptance of the first production ATB, in compliance with the requirements of 3.12.

5.6.9 Technical manual. The technical manual shall be reviewed and approved prior to acceptance of the first production ATB, in compliance with the requirements of 3.13.

6. PACKAGING.

6.1 Packaging. Preservation, packing, and marking shall be as specified in the contract or order.

7. NOTES.

7.1 Source of documents.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:33Z
Check the source to verify that this is the current version before use.

7.1.1 Department of Defense and Federal documents. Department of Defense and Federal documents are available online at https://quicksearch.dla.mil/.

7.1.2 AFI. Copies of AFIs are available online at https://www.e-publishing.af.mil/.

7.1.3 CFR. Copies of the CFR are available online at https://www.ecfr.gov/.

7.1.4 FAR. Electronic copies of the FAR may be obtained from https://www.acquisition.gov/

7.1.5 AWS documents. Electronic copies of American Welding Society (AWS) documents may be obtained from , https://www.aws.org/.

7.1.6 SAE documents. Copies of SAE documents are available online https://www.sae.org/.

7.2 Ordering data. Acquisition documents should specify the following:

a. Title, number, and date of this CID.

b. Packaging requirements (see 6.1).

7.3 Definitions.

7.3.1 Commercial item.

a. Any item, other than real property, that is of a type customarily used by the general public or by non-Governmental entities for purposes other than Governmental purposes, and—

(1) Has been sold, leased, or licensed to the general public; or

(2) Has been offered for sale, lease, or license to the general public.

b. Any item that evolved from an item described in paragraph (1) of this definition through advances in technology or performance and that is not yet available in the commercial marketplace but will be available in the commercial marketplace in time to satisfy the delivery requirements under a government solicitation.

c. Any item that would satisfy a criterion expressed in paragraphs (1) or (2) of this definition, but for—

(1) Modifications of a type customarily available in the commercial marketplace; or

(2) Minor modifications of a type not customarily available in the commercial marketplace made to meet Federal Government requirements. Minor modifications mean modifications that do not significantly alter the non-Governmental function or essential physical characteristics of an item or component or change the purpose of a process. Factors to be considered in determining whether a modification is minor include the value and size of the modification, and the comparative value and size of the final product. Dollar values and percentages may be used as guideposts but are not conclusive evidence that a modification is minor.

d. Any combination of items meeting the requirements of paragraphs 7.3.1 (a), (b), (c), or (d) of this definition that are of a type customarily combined and sold in combination to the general public.

e. Installation services, maintenance services, repair services, training services, and other services if—

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:33Z
Check the source to verify that this is the current version before use.

(1) Such services are procured for support of an item referred to in paragraph 7.3.1 (a), (b), (c), or (d) of this definition, regardless of whether such services are provided by the same source or at the same time as the item; and

(2) The source of such services provides similar services contemporaneously to the general public under terms and conditions similar to those offered to the Federal Government.

f. Services of a type offered and sold competitively in substantial quantities in the commercial marketplace based on established catalog or market prices for specific tasks performed or specific outcomes to be achieved and under standard commercial terms and conditions. For purposes of these services—

(1) "Catalog price" means a price included in a catalog, price list, schedule, or other form that is regularly maintained by the manufacturer or vendor, is either published or otherwise available for inspection by customers, and states prices at which sales are currently, or were last, made to a significant number of buyers constituting the general public; and,

(2) "Market prices" means current prices that are established in the course of ordinary trade between buyers and sellers free to bargain and that can be substantiated through competition or from sources independent of the offerors.

g. Any item, combination of items, or service referred to in paragraphs (1) through (6) of this definition, notwithstanding the fact that the item, combination of items, or service is transferred between or among separate divisions, subsidiaries, or affiliates of a contractor; or,

h. A non-developmental item, if the procuring agency determines the item was developed exclusively at private expense and sold in substantial quantities, on a competitive basis, to multiple State and local Government. (Reference the Federal Acquisition Regulation (FAR) 2.101).

7.3.2 Special tool. A tool that is not commercially and readily available from a source other than the ATB contractor.

7.4 Key words.

All-terrain berm.

ATB.

Fuel containment.

Fuel bladder.

MILITARY INTEREST:

Custodian:

Air Force – 184

Reviewer:

DLA-GS

Preparing Activity:

Air Force – 184

Agent:

Air Force-110

(Project 4235-2023-002)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:33Z
Check the source to verify that this is the current version before use.

NOTE: The activities listed above were interested in this document as of the date of this document. Since organizations and responsibilities can change, you should verify the currency of the information above using the ASSIST Online database at https://assist.dla.mil.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:33Z
Check the source to verify that this is the current version before use.