FEDERAL SPECIFICATION

BUTANE, PROPANE, AND BUTANE-PROPANE MIXTURES

This amendment, which forms a part of Federal Specification BB-G-110A, dated May 4, 1971, was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

Paragraph 4.1.1: Delete and substitute:

4.1.1 Certificate of compliance. In lieu of contractor performing tests as specified in 4.4, a certificate furnished by the contractor, certifying that the gas complies with the Natural Gas Processors Association (NGPA) requirements, shall be acceptable as evidence of compliance with 3.1. The certificate shall not be interpreted to waive the Government's rights to make the specified tests or require the contractor to have them made in the event the Government has reason to suspect that contamination of the gases have occurred.

Add paragraph 4.3.4:

4.3.4 Visual and dimensional. Samples selected in accordance with 4.3.2 shall be inspected to the requirements in paragraphs 3.3 thru 3.3.2. AQL shall be 4.0 percent defective.

MILITARY INTEREST:

Custodians:

Navy - YD
Air Force - 68

User activities:

Navy - MC, SH
Army - ME

Military coordination activity:

Navy - YD

Preparing activity:

GSA-FSS

Civil agency coordinating activity:

DOT-FAA
GSA-FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:42Z
Check the source to verify that this is the current version before use.