CC-M-180 7
CANCELLATION
February 18, 1986

FEDERAL SPECIFICATION

MOTORS, ALTERNATING CURRENT, FRACTIONAL AND INTEGRAL HORSEPOWER (500 HP AND SMALLER)

This cancellation is approved by the Commissioner, Federal Supply Service, General Services Administration.

Federal specification CC-M-1807A, dated March 25, 1983, has been superseded by the National Electrical Manufacturers Association (NEMA) Standard MG-1, Standard for Motors and Generators.

In addition, Designs L (Explosion-proof) and M (Dust-ignition-proof) of the specification are also required to have the listing mark of the Underwriters Laboratories Inc. (UL) Standard number 674, Electric Motors and Generators for Hazardous Locations.

FSC 6105

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:42Z
Check the source to verify that this is the current version before use.