MIL-V-18433B(YD)

22 March 1974

SUPERSEDING
MIL-V-18433A(YD)
30 July 1965

MILITARY SPECIFICATION

VALVES, TEMPERATURE-REGULATING (THERMOSTATICALLY CONTROLLED)

1. SCOPE

* 1.1 Scope. This specification covers temperature-regulating valves designed to maintain fairly constant temperatures in heaters and storage tanks by regulation of the inlet fluid flow of the heating or cooling medium.

* 1.2 Classification. The temperature-regulating valves shall be of the following types, styles, and classes, as specified (see 6.2):

Type I - Temperature regulator

Style A - Direct acting (closes with a temperature increase)
Style B - Reverse acting (opens with a temperature increase)

Class 1 - Self-operated
Class 2 - Pilot-operated
Class 3 - Electric-operated

Type II - Combination pressure and temperature regulator

2. APPLICABLE DOCUMENTS

* 2.1 The following documents of the issue in effect on date of invitation for bids or request for proposal, form a part of the specification to the extent specified herein.

FSC 4820

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T11:32Z
Check the source to verify that this is the current version before use.

SPECIFICATIONS

Military

MIL-V-3 - Valves, Fittings, and Flanges (Except for Systems Indicated Herein); Packaging of
MIL-E-17555 - Electronic and Electrical Equipment, Accessories, and Repair Parts; Packaging and Packing of

STANDARDS

Military

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes
MIL-STD-109 - Quality Assurance Terms and Definitions
MIL-STD-129 - Marking for Shipment and Storage

(Copies of specifications, standards, drawings, and publications required by suppliers in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

* 2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless otherwise indicated, the issue in effect on date of invitation for bids or request for proposal shall apply.

American National Standards Institute, Inc. (ANSI)

B1.1 - Unified Screw Threads
B2.1 - Pipe Threads (Except Dryseal)
B2.2 - Dryseal Pipe Threads
B31.1 - Power Piping

(Application for copies should be addressed to the American National Standards Institute, Inc., 1430 Broadway, New York, NY 10018.)

Manufacturers' Standardization Society of the Valve and Fittings Industry (MSS)

MSS-SP-25 - Standard Marking System for Valves, Fittings, Flanges and Unions

(Application for copies should be addressed to the Manufacturer's Standardization Society of the Valve and Fittings Industry, 1815 North Fort Myer Drive, Arlington, VA 22209.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T11:32Z
Check the source to verify that this is the current version before use.

National Electrical Manufacturers' Association (NEMA)

IS1.1 - Enclosures for Controls and Systems

(Application for copies should be addressed to the National Electrical Manufacturers' Association, 155 East 44th Street, New York, NY 10017.)

National Motor Freight Traffic Association, Inc. Agent

National Motor Freight Classification

(Application for copies should be addressed to the American Trucking Associations, Inc., Tariff Order Section, 1616 P Street, N.W., Washington, DC 20036.)

Uniform Classification Committee, Agent

Uniform Freight Classification

(Application for copies should be addressed to the Uniform Classification Committee, Room 1106, 222 S. Riverside Plaza, Chicago, IL 60606.)

Technical society and technical association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.

3. REQUIREMENTS

* 3.1 Description. Within the range indicated in Table I, the valves shall automatically regulate fluid temperature by varying the flow of the heating or cooling medium. The valve assembly shall include a remote thermostatic bulb having flexible capillary tubing, a bellows, diaphragm, or other mechanical actuating device, a pilot valve, as required, and provisions that protect against overheating. The valve operating pressure, temperature, fluid service, and end connections shall be as specified (see 6.2). Valves of size 2-1/2-inch and larger shall be flanged. The type II unit shall be furnished with a pressure-regulating overide to limit and regulate the maximum outlet pressure of the temperature-regulating valve. The type I, class 3, valve electrical characteristics shall be as specified in 3.8.5.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T11:32Z
Check the source to verify that this is the current version before use.

* 3.2 Standard commercial product. The valves shall, as a minimum, be in accordance with the requirements of this specification and shall be the manufacturer's standard commercial product. Additional or better features which are not specifically prohibited by this specification but which are a part of the manufacturer's standard commercial product shall be included in the valves being furnished. Standard commercial product is a product which has been or will be sold on the commercial market through advertisements or manufacturer's catalogs or brochures, and represents the latest production model(s).

* 3.2.1 Repair parts and service. Replacement, or repair parts, and service for the standard commercial product provided under this specification shall be available from the manufacturer's regular, or through commercial, parts distribution or service organizations.

* 3.3 First article. When specified (see 6.2), the contractor shall furnish a valve for first article inspection and approval (see 4.2.1 and 6.4).

* 3.4 Interchangeability. All valves of the same classification, furnished with similar options under a specific contract, shall be identical to the extent necessary to insure interchangeability of component parts, assemblies, accessories, and spare parts.

* 3.5 Material. Material shall be as specified herein. Material not definitely specified shall be of the quality normally used in the manufacturer's commercial practice. All material shall be modern in design and shall not have been in prior service except as required by factory tests. Items performing the same functions shall be products of the same manufacturer.

* 3.6 Design. The unit shall be designed to conform to the requirements of ANSI B31.1. The design shall be such as to prevent conditions hazardous to personnel or deleterious to equipment. Screw threads and pipe threads shall be in conformance with ANSI B1.1, B2.1, or B2.2, as applicable. Valves shall be so designed, where feasible, that interior wearing parts may be repaired without removal of the valve assembly from its piping. Over-all valve dimensions shall be kept to a minimum consistent with the manufacturer's standard practice. Fluid-containing, thermostatic elements shall be hermetically sealed to preclude any mixing with the controlled medium. Unless otherwise specified (see 6.2), temperature calibration shall be accomplished at the mid-point of the temperature range specified.

Source: https://assist.dla.mil/ -- Downloaded: 2026-10-18T11:32Z
Check the source to verify that this is the current version before use.

* 3.7 Performance. Valves shall be capable of maintaining the controlled fluid temperature (see 4.6.2) within the accuracy requirements specified in Table I for the temperature range and limiting pressures indicated. Valve capacities shall be in accordance with Table II. Overheat protection shall be provided to prevent damage to valve internal parts and to the thermal sensing apparatus. The type II valve shall control outlet pressure in addition to temperature (see 4.6.2). Pressure adjustment shall be in definite proportion to temperature change. Maximum delivery pressure shall be maintained for the specified operating pressure within ± 1 pound per square inch (PSI). Valve response time shall be kept to a minimum, consistent with the standard practice for the intended service.

Table I. Valve characteristics

	Type I			Type II
	Class 1	Class 2	Class 3	
Temperature range ° F *	40	100	50	100
Accuracy ° F	±4	±2	±4	±2
Inlet pressure PSI max.**	125	250	200	600
Pressure differential PSI min.	5	5	5	15

*Maximum sensed temperature shall not exceed 250° F for type I valves or 450° F for type II valves.

**Based on saturated steam pressure.

Table II. Valve capacities - minimum

Nominal pipe size, inches	Steam service 35 PSI inlet 20 PSI outlet pounds/hour	Liquid service 5 PSI pressure drop GPM	Air or gas service 5 PSI inlet 0-3 PSI outlet CFM @ 68° F
1/4	32	1.3	4
3/8	60	2.1	8
1/2	95	4.0	12
3/4	210	7.3	21
1	300	11.0	30
1-1/4	500	17.0	45
1-1/2	750	26.0	72
2	1,200	43.0	115
2-1/2	2,100	78.0	240

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T11:32Z
Check the source to verify that this is the current version before use.

Table II.
(continued)

3	3,200	125.0	396
4	6,500	200.0	711
5	9,500	350.0	1,164
6	14,000	585.0	1,732

Note: The valve is set in the position it would assume at a temperature of 10° F above or below the temperature at which the valve is set to close, as applicable. The above capacities refer to the heating or cooling medium flowing through the main valve (see 4.6.1).

* 3.8 Construction. When assembled and installed in the required piping circuit, the temperature-regulating valve shall operate as specified in 3.7 without evidence of binding, seizing, or permanent deformation caused by system temperature and pressure variations. Valve hysteresis shall be controlled in a positive manner. Direction of flow shall be clearly marked on the valve body. Internal fluid passages shall be free of extraneous matter that restrict fluid flow. When specified (see 6.2), a strainer shall be furnished to preclude the damaging effects of scale, dirt, and welding chips in the line. Thermal sensing and actuating components shall be so arranged as not to be in direct contact with the fluid through the main valve. The valve assembly shall include the following components:

* 3.8.1 Main valve. The main valve shall be a single- or double-seated, mechanically actuated, gate or globe valve. The valve shall be suitably balanced, and when intended for heating applications, shall be designed for dead-end shutoff. When required for cooling applications, a continuous flow bypass shall be furnished with the main valve. The valve body shall be bronze, brass, cast or ductile iron, or cast or forged steel, as specified (see 6.2). For pressures above 250 PSI, the valve body shall be cast or forged steel. Trim material shall be suitable for the intended service. Unless otherwise specified (see 6.2), the trim shall be as follows:

* 3.8.1.1 Seats. Seats shall be either integral with the valve body or securely attached to the body, and shall be corrosion-resistant steel (CRES), stellite or stellite faced alloy steel, or bronze when the intended operating medium is other than steam. Seat rings shall be renewable and so arranged that leakage between the seat and the body is precluded.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T11:32Z
Check the source to verify that this is the current version before use.

* 3.8.1.2 Disks, plugs, and gates. Disks, plugs, or gates, for service other than steam, shall consist of composition material or alloy steel, hard bronze or CRES, and may be stellite faced. For steam service they shall be alloy steel or CRES and may be stellite faced. Pistons shall be designed for minimum clearance, compatible with nonbinding operation.

* 3.8.1.3 Stems. Valve stems shall be CRES. Valve stems and shafts that pass from a pressure zone to the atmosphere shall be sealed against leakage and shall be designed for nonbinding movement against the thrust loads imposed. Stem lubrication shall be provided when the packing material furnished is subject to extrusion from the stuffing box as a result of stem friction. Lubrication used shall not react chemically with the stuffing box or the packing. When packing is used, a teflon-coated asbestos, teflon cup, or CRES-teflon-asbestos composition shall be furnished.

* 3.8.1.4 Springs. Springs shall be carbon steel or CRES. Carbon steel springs shall be made corrosion-resistant. Helical spring ends shall be ground smooth.

* 3.8.1.5 Diaphragms. Diaphragms shall be made of rubber, leather, synthetic material reinforced with cloth, phospor-bronze, nickel-copper alloy, or CRES. Diaphragm plates and other parts against which the diaphragm flexes shall be smooth and well rounded. The design shall be such that the diaphragm will not be subject to injurious twisting, wrinkling, or cutting.

* 3.8.1.6 Bellows. Bellows shall be of nickel-copper alloy, manganese-bronze, phosphor-bronze, CRES, or brass. When the bellows is in contact with steam, and in all cases when phosphor-bronze or brass is used, the bellows shall be of seamless two-ply construction.

* 3.8.2 Pilot valve. The pilot valve shall be either integral with or connected to the main valve by piping in accordance with the requirements specified herein. The pilot valve shall function with the thermostatic bulb to provide instant response to a sensed temperature change. The valve shall be weight, lever, or spring-loaded, operated by the line pressure of the main valve and sized to provide full-stroke control of the main valve disk, plug, or gate. Interior metal parts shall be CRES. When provided, the body shall be of the same material as the main valve. The seat ring shall be of teflon or composition material suitable for the intended service. Connections shall be leaktight and the operating range shall be preset.

Source: https://assist.dla.mil -- Downloaded: 202640-18T11:32Z
Check the source to verify that this is the current version before use.

3.8.3 Type II valve pressure pilot. The type II valve pressure pilot shall be designed to control discharge pressure from the main valve. After sensing a pressure increase, the pilot shall act mechanically to control the main valve in accordance with the accuracy requirements of 3.7. Internal metal parts shall be CRES. When provided, the valve body shall be of the same material as the main valve. Seats shall be a CRES ring or CRES with a teflon ring. Connections shall be leaktight and the pressure adjustment shall be preset. The internal pilot chamber shall be self-draining.

3.8.4 Thermostatic control. The thermostatic bulb and the capillary tube which connects the bulb to the temperature (pressure-actuated) bellows or diaphragm shall be a hermetically sealed assembly containing either a temperature-sensitive liquid, or a volatile fluid suitable for the temperature range and application specified. The materials of the bulb, capillary tubing, bellows or diaphragm, and the materials used in joining and sealing the assembly, shall not react chemically either with each other or with the fluid with which contact is made. Interior surfaces shall be free of imperfections that affect control function or accuracy. The bulb shall be plain, equipped with a union connection or a separable socket, as specified (see 6.2). The volatile fluid-type bulb shall be sized to preclude vapor from entering the capillary tube. Capillary tubing shall be either extra heavy walled or armored and constructed of copper, nickel-plated copper, or brass. Armored tubing shall be protected by a spirally-wound armor of bronze or brass. A means to prevent coil unwinding shall be furnished. Tubing shall be capable of withstanding, without rupture, repeated slow bending at a radius of 4 inches through a 90-degree angle. Unless otherwise specified (see 6.2), tubing shall be provided in 8-foot lengths. Tubing connections to the main valve shall be leaktight.

* 3.8.5 Electric control. A normally closed solenoid control shall be supplied with the type I, class 3, valve. The solenoid shall be opened (energized) in response to a sensed temperature change and shall cause the main valve to admit or cut off fluid flow as required for the intended application. The control enclosure shall be a general purpose class, type I, in accordance with NEMA ISl.1. The coil shall be selected for high temperature, class H, continuous duty. The control body shall be brass and shall be appropriately sealed to prevent dust and moisture contamination. The control head and seat shall be constructed of CRES. Unless otherwise specified (see 6.2), the electrical supply shall be 120 volts, 60 hertz, alternating current.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T11:32Z
Check the source to verify that this is the current version before use.

* 3.9 Fastening devices. Screws, pins, bolts, and similar parts shall be installed with means for preventing loss of tightness. When subject to removal or adjustment, such parts shall not be swaged, peened, staked, or otherwise permanently deformed.

* 3.10 Identification marking. Assemblies and parts shall be marked for identification in accordance with MSS-SP-25.

* 3.11 Packing and maintenance tools. When specified (see 6.2), packing and maintenance tools shall be furnished.

* 3.12 Workmanship. The quality of workmanship shall be such as to produce valves that are in accordance with the requirements of this specification and that are so constructed as to insure the proper functioning of all parts of the unit.

* 3.12.1 Castings and forgings. All castings shall be free from blowholes, porosity, hard spots, shrinkage defects, cracks, or other defects that may render the casting unsound for use. Forgings shall be free from scale, enclosures, cold shuts, mismatching, and other defects that may affect the structural strength of the forgings. Repair processes, such as welding, peening, plugging, or filling with cold solder or metallic paste shall not be attempted without authorization of the contracting officer.

4. QUALITY ASSURANCE PROVISIONS

* 4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or order, the supplier may use his own or any other facilities suitable for the performance of the inspection requirements specified herein unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure that supplies and services conform to prescribed requirements.

* 4.1.1 Inspection of materials and components. In accordance with 4.1, the supplier is responsible for insuring that materials and components used were manufactured, examined, and tested to the extent specified, in accordance with the requirements of referenced subsidiary specifications and standards. The terms and definitions of MIL-STD-109 shall apply.

Source: https://assist.dla.mil -- Downloaded: 202610-18T11:32Z
Check the source to verify that this is the current version before use.

* 4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.2.1).
b. Quality conformance inspection (see 4.2.2).

* 4.2.1 First article inspection. First article inspection shall be performed on one valve of each type when a first article sample is required (see 3.3). This inspection shall include the examination of 4.5 and the tests of 4.6. Failure of the first article to pass the examination or any of the tests shall be cause for rejection. The first article may be a standard production item from the supplier's current inventory provided that the unit meets the requirements of the specification and is representative of the design, construction, and manufacturing technique applicable to the remaining units to be furnished under the contract.

* 4.2.2 Quality conformance inspection. Quality conformance inspection shall be performed on the sample valves selected in accordance with 4.4. This inspection shall include the examination of 4.5 and the tests of 4.6.

* 4.3 Inspection lot. All units of the same type, style, and class offered to the Government at one time shall be considered a lot for purposes of inspection. The sample unit shall be one complete valve.

4.4 Sampling.

* 4.4.1 Sampling for examination. A random sample of valves shall be selected from each lot offered to the Government in accordance with MIL-STD-105 at inspection level II. The acceptable quality level shall be 2.5 percent for major defects and 4.0 percent for minor defects.

* 4.4.2 Sampling for tests. A random sample of valves shall be selected from each lot offered to the Government in accordance with MIL-STD-105 at inspection level S-2. The acceptable quality level shall be 2.5 percent defective.

* 4.5 Examination. Each unit selected in accordance with 4.4.1 shall be examined to verify compliance with the requirements of this specification. Examination shall be conducted as specified in Table III.

Source: https://assist.dla.mil -- Downloaded: 202610-18T11:32Z
Check the source to verify that this is the currentversion before use.

Table III. Classification of defects

Categories	Defects
Major:	
101	Material not as specified
102	Components improper, damaged, missing, or not interchangeable
103	Clearances not within specified tolerances
104	Inadequate packing, seals
105	Valve seats scratched or distorted
106	Shaft stems or pistons distorted, not designed for nonbinding operation
107	Thermal system not hermetically sealed
108	Temperature or pressure adjustment not as specified
109	Assembly improper, or malfunctioning
Minor:	
201	Poor threading or fastenings
202	Not clean or free from burrs or scratches
203	Fastening devices installed improperly
204	Improper end connections
205	Identification marking missing, improper, or illegible
206	Surfaces not properly finished
207	Spare parts (when required) missing

* 4.6 Tests. Each unit selected in accordance with 4.4.2 shall be tested, and any unit failing to pass the following tests, as applicable, shall be rejected.

* 4.6.1 Leakage tests. Valve pressure containing parts shall be subjected to a hydrostatic test pressure of twice the specified operating pressure (see 6.2) for a minimum of 3 minutes. Any leakage noted shall be cause for rejection. Single seated valves shall be tested for seat leakage at full-line pressure with one of the operating mediums in Table II directed on the upstream side of the valve. The valve shall be in the position it would assume at a temperature of 10°F above or below the temperature at which the valve is set to close, as applicable. Any valve exhibiting a leakage of over 0.01% of rated capacity shall be rejected.

* 4.6.2 Operating test. The valve assembly shall be installed in test piping arranged with the intended application. The valve shall be tested with one of the operating mediums specified in Table II to verify compliance with 3.7. At least three temperature adjustments shall be preset over the specified range to cause the main valve to open and close in a complete cycle. Upon completion of the test, the

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T11:32Z
Check the source to verify that this is the current version before use.

valve assembly shall be removed from the test piping, dismantled, and inspected for defects. Leakage, any permanent deformation, or malfunction of any valve component during the test shall constitute cause for rejection. Type II valves shall also be tested for pressure regulation in accordance with 3.7.

* 4.7 Inspection of preparation for delivery. Preparation for delivery requirements of the valves shall be inspected to determine conformance with the applicable requirements of section 5 of this specification.

5. PREPARATION FOR DELIVERY

* 5.1 Preservation and packaging. Preservation and packaging shall be level A or C, as specified (see 6.2).

5.1.1 Level A.

5.1.1.1 Valves. The valves shall be preserved and packaged in accordance with the applicable level A requirements of MIL-V-3.

5.1.1.2 Electrical components. Electrical components shall be cleaned, preserved, and packaged in accordance with the applicable level A requirements of MIL-E-17555.

5.1.2 Level C. The valves shall be preserved and packaged in accordance with supplier's standard practice.

* 5.2 Packing. Packing shall be level A, B, or C, as specified (see 6.2).

5.2.1 Level A. The valves shall be packed in accordance with the applicable level A requirements of MIL-V-3.

5.2.2 Level B. The valves shall be packed in accordance with the applicable level B requirements of MIL-V-3.

5.2.3 Level C. The valves shall be packed in a manner which will insure arrival at destination in satisfactory condition, and be acceptable to the carrier at lowest rates. Containers and packing shall comply with Uniform Freight Classification rules or National Motor Freight Classification rules.

* 5.3 Marking. In addition to any special marking required by the contract or order (see 6.2), shipping containers shall be marked in accordance with the requirements of MIL-STD-129.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T11:32Z
Check the source to verify that this is the current version before use.

6. NOTES

* 6.1 Intended use. The valves specified herein are intended to control temperatures by varying the fluid flow of a heat-transfer medium which is used to either heat or cool a separate fluid flow. Usually, the valve application involves utilization of steam flow to heat water in instantaneous heaters and storage tanks. In addition to these functions, the type II valve is capable of regulating the heated equipment supply pressure.

* 6.2 Ordering data. Procurement documents should specify the following:

(a) Title, number, and date of this specification.
(b) Type, style, and class of valve required (see 1.2).
(c) Valve operating pressure, temperature, fluid service, and end connections required (see 3.1 and 4.6.1).
(d) When first article is required for inspection and approval (see 3.3).
(e) Temperature calibration, if other than as specified (see 3.6).
(f) When a strainer is required (see 3.8).
(g) Main valve body material required (see 3.8.1).
(h) Trim, if other than as specified (see 3.8.1).
(i) Thermostatic bulb connection required (see 3.8.4).
(j) Capillary tubing length, if other than as specified (see 3.8.4).
(k) Electrical characteristics of type I, class 3, valve, if other than as specified (see 3.8.5).
(l) Packing and maintenance tools, if required (see 3.11).
(m) Level of preservation and packaging and level of packing required (see 5.1 and 5.2).
(n) Marking required (see 5.3).

* 6.3 Options. The size of the temperature regulator should be selected for the intended application, rather than for the pipe size of the heater line, in which the valve is installed. In most applications, the valve will be smaller than the heater piping. For heating fluids with steam, the following approximation may be used to determine the valve size required:

a. For water; lbs. steam / hr.* = $\frac{GPM}{2}$ (temperature rise °F)

b. For fuel oil; lbs. steam / hr.* = $\frac{GPM}{4}$ (temperature rise °F)

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T11:32Z
Check the source to verify that this is the current version before use.

c. For air; lbs. steam / hr.* $= \frac{CFM}{925}$ (temperature rise °F)

d. For radiation; lbs. steam / hr.* $= \frac{\text{Sq. ft. EDR}}{4}$

*Minimum flow at 5 PSI input pressure (saturated steam).
EDR is equivalent direct (steam) radiation.

Final valve size selection should be made in accordance with manufacturer's recommendations for the particular steam flow.

* 6.4 First article. When a first article is required, it shall be tested and approved under the appropriate provisions of paragraph 7-104.55 of the Armed Services Procurement Regulation. The first article may be a standard production item from the supplier's current inventory. The first article should consist of one complete valve. The contracting officer should include specific instruction in all procurement instruments, regarding arrangements for examinations, test, and approval of the first article.

* 6.5 The margin of this specification is marked with asterisks to indicate where changes (additions, modifications, corrections, deletions) from the previous issue were made. This was done as a convenience only, and the government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this document based on the entire content irrespective of the marginal notations and relationship to the last previous issue.

Preparing activity:
Navy - YD

Project No. 4820-N223

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T11:32Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

DEPARTMENT OF THE NAVY

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO. 12503 WASHINGTON D. C.

POSTAGE WILL BE PAID BY THE DEPARTMENT OF THE NAVY

Commanding Officer
Naval Construction Battalion Center (Code 156)
Port Hueneme, CA 93043

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T11:32Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
b. ADDRESS *(Street, City, State, ZIP Code)*	☐ USER
	☐ MANUFACTURER
	☐ OTHER *(Specify)*: _____

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE.

(TO DETACH THIS FORM, CUT ALONG THIS LINE.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T11:32Z
Check the source to verify that this is the current version before use.