INCH-POUND
A-A-55558A
31 August 2023
SUPERSEDING
A-A-55558
18 January 1995

COMMERCIAL ITEM DESCRIPTION

CONNECTOR, RECEPTACLE, ELECTRICAL, UTILITY POWER, 15 AMP, 125 VOLT, 50/60 HERTZ WITH COVER

The General Services Administration has authorized the use of this commercial item description (CID) for all federal agencies.

1. SCOPE. This CID covers the general requirements for a power receptacle with a cover for wet location applications. Parts covered by this CID are intended for commercial/industrial applications and military system applications that do not have stringent environmental and mechanical requirements.

2. CLASSIFICATION. This CID uses a classification system which is included in the Part or Identification Number (PIN) (see 6.1)

3. SALIENT CHARACTERISTICS.

3.1 Configuration and dimensions. Configuration and dimensions shall be as specified on figure 1 and table I.

3.2 Receptacle

General purpose general grade duplex 2 pole 3 wire grounding 15 ampere 125 volt 50/60 hertz NEMA configuration number 5-15R.

Color shall be brown.

Receptacle shall be a qualified connector to W-C-596/12, PIN WC596/12-2.

3.3 Cover

Metallic or non-metallic two door independent self-closing for a standard mounting box and for horizontal mounting.


Cover plate shall be for wet location applications with cover open in accordance with UL 514A for metallic type in accordance with UL 514C for non-metallic type

3.4 Item of supply. One item of supply shall be one receptacle one cover and any related hardware (i.e. screws, gaskets, etc.) necessary for installation in one package.

Comments, suggestions, or questions on this document should be addressed to: DLA Land and Maritime, Attn: VAI, P.O. Box 3990, Columbus, OH 43218-5000, or emailed to RFConnector@dla.mil. Since contact information can change, you may want to verify the currency of this address information using the ASSIST Online database at https://assist.dla.mil.

AMSC N/A
FSC 5935
DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:52Z
Check the source to verify that this is the current version before use.



NOTES:
1. Dimensions are in inches.

FIGURE 1. Configuration and dimensions

4. QUALITY ASSURANCE PROVISIONS

4.1 Contractor certification. The contractor shall certify and maintain objective quality evidence that the product offered meets the requirements of this CID and that the product conforms to the producer's own drawings, specifications, standards, quality assurances, practices and is the same as the product provided as a bid sample if a bid sample is requested. The Government reserves the right to require proof of such conformance prior to the first delivery and thereafter as may be otherwise provided for under the provisions of the contract.


5. PACKAGING.

5.1 Preservation, packaging, packing, labeling, and marking. Preservation, packing, labeling, and marking shall be as specified in the contract or purchase order.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:52Z
Check the source to verify that this is the current version before use.

6. NOTES. This section contains relevant information which is useful to buyers, users, and suppliers in the process of procuring the item but is not mandatory.

6.1 Part Identification Number (PIN). The following part identification numbering procedure is for government purposes and does not constitute a requirement for the contractor:



6.2 Referenced documents

6.2.1 Federal Specification.

W-C-596	-	Connector, Electrical Power, General Specification for
W-C-596/12	-	Connector, Receptacle, Electrical, General Purpose, Deplex, General Grade and Hospital Grade, Grounding, 2 Pole, 3 Wire, 15 Amperes, 125 Volts, 50/60 Hertz

6.2.2 Underwriters Laboratories, Inc. (UL) Standard

UL514A	-	Boxes, Metallic Outlet
UL514C	-	Boxes, Nonmetallic Outlet, Flush Devise boxes, and covers

6.2.3 National Electrical Manufacturers Association (NEMA) Publications

ANSI/NEMA-WD 6-	Wiring Devices – Dimensional Requirements

6.3 Government users. To acquire information on obtaining these connectors from the Government inventory system contact DLA Land and Maritime, Attn: VAI, P.O. Box 3990, Columbus, OH 43218-5000, or emailed to RFConnector@dla.mil.

6.4 Ordering data. Acquisition documents should specify the following:

a. CID document number and CID PIN.
b. Quality assurance provisions.
c. Packaging requirements.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:52Z
Check the source to verify that this is the current version before use.

6.5 Suggested sources of supply. Suggested sources of supply are listed in the table; Additional sources will be added as they become available.

TABLE I. Suggested sources of supply

CID PIN AA55558	Vendor's Commercial PIN	Vendor's CAGE number	NSN
01	5262 w/5205W0	12497	5935-00-716-3297
	30501/2708	2H306	
	5262 w/5205W0	74545	
	WR81C	84258	
	5262 w/5205W0	9A329	

Vendor CAGE number	Vendor name and address
12497	JOHN A. BECKER CO., THE 2341 E FOURTH ST DAYTON, OH 45402-2235
2H306	DOYLESTOWN ELECTRIC SUPPLY CO. 3683 N EASTON RD DOYLESTOWN, PA 18902-1194
74545	HUBBELL INC. WIRING DEVICE DIV 185 PLAINS RD MILFORD, CT 06460
84258	AVON ELECTRICAL SUPPLIES INC. 60 HOFFMAN AVE HAUPPAUGE, NY 11788
9A329	SOUTHERN ELECTRIC SUPPLY CO. DBA REXEL INC. DIV REXEL DAYTON 701 S. PATTERSON BLVD. DAYTON, OH 45401-1690

Changes from previous issue. The margins of this specification are marked with vertical lines to indicate where changes (additions, modifications, corrections, deletions) from the previous issue were made. This was done as a convenience only, and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this document based on the entire content irrespective of the marginal notations and relationship to the previous issue.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:52Z
Check the source to verify that this is the current version before use.

MILITARY INTERESTS:

Custodians:
DLA - CC

CIVIL AGENCY COORDINATING ACTIVITY:

GSA – 7FXE

Preparing activity:
DLA – CC

(Project 5935-2023-072)

NOTE: The activities listed above were interested in this document as of the date of this document. Since organizations and responsibilities can change, you should verify the currency of the information above using the ASSIST Online database at https://assist.dla.mil .

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:52Z
Check the source to verify that this is the current version before use.