COMMERCIAL ITEM DESCRIPTION

SIAMESE CONNECTION, FIRE HOSE
(WYES: PLAIN; TWO- AND THREE-WAY HYDRANT)

The General Services Administration has authorized the use of this commercial item description.

This description covers plain wyes and two- and three-way hydrant wye valves. They are used to divide one main supply line into two or three smaller supply lines. They shall be furnished in the following types, classes, and styles as specified. All sizes shown are in inches.

Type I - Cast brass
Type II - Aluminum, hard-coated

Class A - Plain Wyes

Style	Inlet (Female)	Outlet (Male)
1	2-1/2	2-1/2 x 2-1/2
2	3	"
3	3-1/2	"
4	4	"
5	4-1/2	"
6	5	"
7	6	"

Class B - Valved Wyes, Leader Line

Style	Inlet (Female)	Outlet (Male)
1	1-1/2	1-1/2 x 1
2	1-1/2	1-1/2 x 1-1/2
3	2-1/2	1-1/2 x 1-1/2

Class C - Valved Wyes, Hydrant, Two and Three-Way

Style	Inlet (Female)	Outlet (Male)
1	2-1/2	2-1/2 x 2-1/2
2	3	"
3	3-1/2	"
4	4	"
5	4-1/2	"
6	4-1/2	2-1/2 x 2-1/2 x 2-1/2
7	5	"

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:21Z
Check the source to verify that this is the current version before use.

Salient characteristics.

Inlets shall be swiveled.
Handles shall be parallel with the central axis of the outlet waterways when in the fully open position. (Classes B and C only)
Shall have adjustable seats. (Classes B and C only)
Each outlet branch shall be provided with quarter-turn, full-flow ball valves. (Classes B and C only)

Couplings. Shall be furnished in the following classes and styles, unless otherwise specified.
Classes A, B, C, Styles 1, 2, and 3, couplings shall be provided with rocker lugs.
Class A, Styles 4 thru 7, couplings shall be provided with long handles.
Class C, Styles 5 and 6, couplings shall be provided with rocker lugs for the female outlet and long handles for the female outlet.
Class C, Styles 4 and 7, couplings shall be provided with long handles or Storz quick connect on the female inlet and rocker lugs on the female outlet.
All threads shall be of the NH series, unless otherwise specified.

Conformance Testing.

Dry Torque Test. The valve shall be dry and without hydrostatic pressure. A torque wrench shall be installed in place of the valve handle, and the valve turned to its open and closed position. The peak torque shall not exceed 150 pound-inches.

Hydrostatic Pressure Torque Test. The valve shall be connected to a hydrostatic pressure source and 400 psig pressure will be applied. The valve discharge ends shall be open. The torque wrench shall be turned to the valve open and closed positions. The peak torque shall not exceed 200 pound-inches.

Working Pressure Test. After the hydrostatic pressure torque test, the pressure shall be increased to 600 psig. No leakage is permissable.

Proof Pressure Test. After the working pressure test, the pressure shall be increased to 1000 psig and the valve examined for any distortion, mechanical damage, failures, or leaks.

Workmanship. Cast parts shall be fine-grained, free from blowholes, porosity, hard spots, shrinkage, cracks, and other defects. Exterior surfaces shall be smooth. Excessive material on edges shall not be allowed. Valve shall be free of any defects which may affect the durability, appearance, or serviceability.

Regulatory requirements. The offeror/contractor is encouraged to use recovered materials in accordance with Public Law 94-580 to the maximum extent practicable.

Preservation, packaging, packing, labeling, and marking. The preservation, packaging, packing, labeling, and marking shall be as specified in the contract or order.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:21Z
Check the source to verify that this is the current version before use.

Note. When this commercial item description is used for procurement, the commercial item certification clause must appear in the solicitation.

Purchaser should specify type, class, and style and if coupling threads are to be other than NH series (Class A, Styles 4 and 7 only).

MILITARY INTERESTS:

Review Activity

Army - ME

PREPARING ACTIVITY:

GSA - FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:21Z
Check the source to verify that this is the current version before use.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:21Z
Check the source to verify that this is the current version before use.