DETAIL SPECIFICATION SHEET

FUSE BOXES, FEEDER DISTRIBUTION, TOTALLY ENCLOSED, 125 VOLTS, ALTERNATING CURRENT, SINGLE AND THREE PHASE BUSES, SINGLE PHASE BRANCHES, 0-30 AMPERE MIDGET FUSES, SYMBOLS 600, 601, 612, 612.1, 613, 613.1 AND 614

This specification is approved for use by all Departments and Agencies of the Department of Defense.

The requirements for acquiring the product described herein shall consist of this specification and MIL-DTL-24646.





FIGURE 1. Fuse box assembly, typical. Item No. 01, 02, 03, 04, 05, 06, 07
(Symbol 612, 612.1 shown)

NOTES:
1. Dimensions are in inches.
2. Unless otherwise specified herein, tolerances shall be as follows:
   Two place decimals - plus or minus 0.02.
   Three place decimals - plus or minus 0.005.

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:25Z
Check the source to verify that this is the current version before use.





SYMBOL NO	DIMENSIONS (REF)		
	A	B	C
600	14.16	10.16	4.25
601	16.16	10.16	4.25
612	14.16	10.16	4.75
612.1	14.16	10.16	4.75
613	18.16	10.16	4.25
613.1	18.16	10.16	4.25
614	22.16	10.16	4.25

FIGURE 2. Enclosure, overall dimensions. Item No. 08, 09, 10, 11, 12, 13, 14
(Symbols 600, 601, 612, 612.1, 613 and 614)

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:25Z
Check the source to verify that this is the current version before use.

A. Symbols 600, 601, 612, 612.1 and 613






B. Symbol 614

SYMBOL NO	DIMENSIONS	
	A	B
600	5.00	10.00
601	6.50	13.00
612	5.00	10.00
612.1	5.00	10.00
613	6.50	13.00
613.1	6.50	13.00

FIGURE 3. Mounting dimensions, ref.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:25Z
Check the source to verify that this is the current version before use.




SYMBOL NO	DIMENSIONS (MAX)		
	A	B	C
600	7.25	5.00	2.30
601	12.38	5.00	2.30
612	7.25	5.75	2.30
612.1	7.25	5.75	2.30
613	12.38	5.75	2.30
613.1	12.38	5.75	2.30
614	17.25	5.75	2.30


FIGURE 4. Fuse block assembly, typical. Item No. 15, 16, 17, 18, 19
(Symbols 600, 601, 612, 612.1, 613, 613.1 and 614)

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:25Z
Check the source to verify that this is the current version before use.


A. Four single-phase branches (Symbol 600)




B. Eight single-phase branches (Symbol 601)



C. Four single-phase branches (Symbol 612, and 612.1)



D. Eight single-phase branches (Symbol 613, and 613.1)



E. Twelve single-phase branches (Symbol 614)




FIGURE 5. Wiring diagrams. 20, 21, 22, 23, 24

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:25Z
Check the source to verify that this is the current version before use.

REQUIREMENTS

Symbol numbers: See table I.

Design:

Electrical rating: 125 volts ac, 0-30 ampere, 60 Hz.
Dimensions and configuration: See figures 1, 2, 3 and 4.
Wiring diagrams: See figure 5.
Mounting dimensions: See figure 3.
Degree of enclosure: Totally enclosed.
Nonmagnetic enclosure: Nonmagnetic enclosures shall be aluminum as specified in MIL-E-24142. Attaching hardware shall be nonmagnetic and shall have a magnetic permeability not greater than 2.0.

Designation and marking: See MIL-DTL-24646.
Parts: The parts listed in table II and specified in MIL-DTL-24646 shall be used in the construction of the fuse boxes specified herein.

General information:
Military part numbers and general information are as specified in table I.

TABLE I. Military part number and general information.

Military part no.	Symbol no.	Weight in pounds	No. of circuits	Feeder MCM	Branch MCM	Fuse size	Bus bar size	Supersedes	
								Drawing no.	Type
M24646/1-001	600	20.1	4	75	14	midget 0-30A	0.62 x 0.25	9-S-5348-L	-
M24646/1-002	601	22.9	8	75	14	midget 0-30A	0.62 x 0.25	9-S-5349-L	D-29A
M24646/1-003 1/	612.1	10.0	4	75	14	midget 0-30A	0.62 x 0.25	9000-S-6202-74440	-
M24646/1-004	613	24.5	8	75	14	midget 0-30A	0.62 x 0.25	9-S-5214-L	-
M24646/1-005 1/	613.1	14.5	8	75	14	midget 0-30A	0.62 x 0.25	9-S-5214-L	-
M24646/1-006	614	18.25	12	75	14	midget 0-30A	0.62 x 0.25	9-S-4755-L	18-S
M24646/1-007	612	10.0	4	75	14	midget 0-30A	0.62 x 0.25	9000-S-6202-74440	-

1/ Non-magnetic, see requirements.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:25Z
Check the source to verify that this is the current version before use.

TABLE II. Parts list.

Item no. 1/	Description	QTY M /-							Material/ specification	Remarks
		001	002	003	004	005	006	007		
01	Fuse box assembly (sym 600)	1							MIL-DTL-24646/1	See fig. 1
02	Fuse box assembly (sym 601)		1						MIL-DTL-24646/1	See fig. 1
03	Fuse box assembly (sym 612)							1	MIL-DTL-24646/1	See fig. 1
04	Fuse box assembly (sym 612.1)			1					MIL-DTL-24646/1	See fig. 1
05	Fuse box assembly (sym 613)				1				MIL-DTL-24646/1	See fig. 1
06	Fuse box assembly (sym 613.1)					1			MIL-DTL-24646/1	See fig. 1
07	Fuse box assembly (sym 614)						1		MIL-DTL-24646/1	See fig. 1
08	Enclosure (10 x 14 x 3.5)	1							M24142/16-001	See fig. 2
09	Enclosure (10 x 16 x 3.5)		1						M24142/16-002	See fig. 2
10 2/	Enclosure (10 x 14 x 4.0)			1					M24142/16-001 Mod	See fig. 2 Non-magnetic
11	Enclosure (10 x 18 x 3.5)				1				M24142/16-003 Mod	See fig. 2
12 2/	Enclosure (10 x 18 x 3.5)					1			M24142/16-003 Mod	See fig. 2 Non-magnetic
13	Enclosure (10 x 22 x 3.5)						1		M24142/18-002	See fig. 2
14	Enclosure (10 x 14 x 4.0)							1	M24142/16-001 Mod	See fig. 2
15	Fuse block assembly	1							MIL-DTL-24646/1	See fig. 4
16	Fuse block assembly		1						MIL-DTL-24646/1	See fig. 4
17	Fuse block assembly			1					MIL-DTL-24646/1	See fig.4
18	Fuse block assembly				1	1			MIL-DTL-24646/1	See fig. 4
19	Fuse block assembly						1		MIL-DTL-24646/1	See fig. 4
20	Wiring diagram	1							MIL-E-2036	See fig. 5
21	Wiring diagram		1						MIL-E-2036	See fig. 5
22	Wiring diagram			1					MIL-E-2036	See fig. 5
23	Wiring diagram				1	1			MIL-E-2036	See fig. 5
24	Wiring diagram						1		MIL-E-2036	See fig. 5
25	Fuse clip (midget 0-30A)	16	32	16	32	32	48		AA55507/1-04	N/A
26	Identification plate	1	1	1	1	1	1		3/	N/A
27	Information plate	4	8	4	8	12	12		3/	N/A

1/ Item numbers after the figure title are the same as the item numbers shown in this table.
2/ Nonmagnetic, see requirements.
3/ For steel panels the plates shall be brass in accordance with ASTM B36/B36M and ASTM B121/B121M, for aluminum panels (symbols 612.1, 613.1) the plates shall be CRES types A, B, or C as specified in MIL-DTL-15024 and severe service of MIL-P-15024/5.

Custodian:
Navy - SH
DLA - CC

Preparing activity:
DLA - CC

(Project 5920-0758-01)

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:25Z
Check the source to verify that this is the current version before use.