MILITARY SPECIFICATION

FILTER PARTICULATE, 200 CPM (MODULAR COLLECTIVE PROTECTION EQUIPMENT' (MCPE) /SIMPLIFIED COLLECTIVE PROTECTION EQUIPMENT (SCPE) APPLICATIONS)

This specification is approved for use within U.S. Army Chemical Research, Development and Engineering Center, Department of the Army, and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers one type of cylindrical particulate filter with an airflow rating of 200 cubic feet per minute (cfm).

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Standards. The following standards form a part of this specification to the extent specified herein. Unless otherwise specified, the issues of these documents shall be those listed in the issue of the Department of Defense Index of Specifications and Standards (DODISS) and supplement thereto, cited in the solicitation.

STANDARDS

MILITARY

MIL-STD-105 - sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-282 - Filter Units, Protective Clothing, Gas-Mask Components and Related Products: Performance Test Methods.

: Beneficial comments (recommendations, additions, deletions) and any perti- : : nent data which may be of use in improving this document should be addressed: : to: Commander, U.S. Army Chemical Research, Development and Engineering : : Center, ATTN: SMCCR-SPT-S, Aberdeen Proving Ground, MD 21010-5423 by using: : the self-addressed Standardization Document Improvemnt proposal (DD Form : . : 1426) appearing at the end of this document or by letter.

AMSC N/A

FSC 4240

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:03Z
Check the source to verify that this is the current version before use.

2.1.2 Government drawings. The following Government drawings form a part of this specification to the extent specified herein. Unless othewise specified, the issues shall be those in effect on the date of the solicitation.

U.S. ARMY ARMAMENT, MUNITIONS AND CHEMICAL COMMAND

CHEMICAL RESEARCH, DEVELOPMENT AND ENGINEERING CENTER

DRAWINGS

5-19-6262 - Filter particulate.
76-2-641-0 - Penetrometer, Filter Testing, IMP, Q107.

SPECIAL PACKAGING INSTRUCTIONS (SPI)

P5-19-6262 - Filter, Particulate.

(Copies of specifications, standards, and drawings required by contractors in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting activity.)

2.2 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein, the text *of* this specification shall take precedence. Nothing in this specification, however, shall supersede applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3.1 Materials and components.

3.1.1 Materials. All materials cited on Drawing 5-19-6262 and on the subsidiary drawings, shall conform to the specifications listed thereon and to the specific characteristics set forth on the drawings.

3.1.2 Components. All components of the particulate filter shall conform to the specifications and drawings listed on Drawing 5-19-6262 and subsidiary drawings.

3.2 Manufacture and assembly. The particulate filter shall be manufactured and assembled in accordance with Drawing 5-19-6262.

3.3 Performance.

3.3.1 Airflow resistance. The airflow resistance of the particulate filter shall not exceed 2.0 inches water gauge (iwg) at an airflow rate of 200 + 10 cfm when tested as specified in 4.4.4.1.

3.3.2 Dioctylphthalate (DOP) smoke penetrations The DOP smoke penetration shall be no greater than 0.03 percent at an airflow rate of 200 ± 10 cfm when tested as specified in 4.4.4.1.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:03Z
Check the source to verify that this is the current version before use.

3.3.3 Resistance to rough handling. After rough handling as specified in 4.3.3 for 15 minutes at 3/4 inch amplitude and a frequency of 200 cycles *per* minute with the filter pleats, faces and separators in the vertical position, the filter shall comply with the airflow resistance and DOP penetration requirements of 3.3.1 and 3.3.2.

3.4 Preproduction. Prior to the start of regular production, a preproduction sample of filters shall be produced in accordance with this specification for examination and test (see 4.3).

3.5 Workmanship. The particulate filter shall be free from foreign matter (dirt, oil, or viscous materials) and abraided gaskets.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perfom any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Responsibility for compliance. All items must meet all requirements or sections 3 and 5. The inspection set forth in this specification shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the specifications shall not relieve the contractor of the responsibility *of* assuring that all products or supplies submitted to the Government *for* acceptance comply with all requirements of the contract. Sampling in quality conformance does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to acceptance of defective material.

4.1.2 Objective evidence. The contractor shall provide objective evidence acceptable to the contracting officer that the requirements of 3.1 and section 5 for which specific inspection has not been provided in this specification have been satisfied.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

(a) Preproduction inspection (see 4.3)
(b) Quality conformance inspection (see 4.4)

4.3 Preproduction inspection.

4.3.1 Sample. a preproduction lot of 20 Particulate filters shall be manufactured using the same methods, materials, equipment and processes as will be used during regular production (see 6.2).

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:03Z
Check the source to verify that this is the current version before use.

4.3.2 Inspection procedure.

4.3.2.1 For examination. Each particulate filter in the preproduction sample shall be examined for all requirements of the applicable drawings and this specification.

4.3.2.2 For tests. Each particulate filter in the preproduction lot shall be tested in accordance with 4.4.4.1. After the lot has passed the examination, and airflow and DOP penetration test, eight particulate filters from the preproduction lot shall be tested in accordance with 4.3.3.

4.3.3 Rough handling test. The particulate filter shall be rough handled in accordance with method T105.10 of MIL-STD-282 and then tested for airflow resistance (3.3.1) and DOP smoke penetration (3.3.2) in accordance with 4.4.4.1.

4.3.4 Acceptance/rejection criteria. The preproduction sample of particulate filters shall comply with all the requirements of this specification when examined and tested as specified in 4.3.2 to be acceptable. The contractor shall obtain written approval from the contracting activity before proceeding with regular production.

4.4 Quality conformance inspection.

4.4.1 Lotting. A lot shall consist of the particulate filter assemblies of one type produced by one manufacturer, from the same materials, at the same location, under essentially the same manufacturing conditions, and at essentially the same time. However, no more than one lot of filter medium shall be represented in any one lot of finished filters.

4.4.2 Sampling for examination. Sampling shall be conducted in accordance with MIL-STD-105.

4.4.3 Inspection procedure.

4.4.3.1 For examination and tests. Sample particulate filters shall be examined and tested in accordance with the classification of defects (4.4.3.3) and MIL-STD-105.

4.4.3.2 Critical defects. Each filter in the lot shall be inspected for critical characteristics listed in the classification of defects.

4.4.3.3 Classification of defects.

(a) Filter, particulate, 200 cfm, (Dug 5-19-6262).

Categories	Defects	Acceptance standards
Critical:		
1	Airflow resistance (3.3.1)	4.4.4.1
2	DOP smoke penetration (3.3.2)	4.4.4.1

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:03Z
Check the source to verify that this is the current version before use.

Major: AQL 1.0 percent defective

101	Component missing, incorrect, or incorrectly assembled
102	Gasket damaged, improperly secured, or improperly located
103	Overall dimensions Incorrect
104	Pleat spacing incorrect
105	Marking incorrect
106	Dents or bulges 0.25 inch or larger

Minor: AQL 2.5 percent defective

201	Workmanship (3.5)

(b) Packaging inspection (section 5).

Categories	Defects
Critical:	None defined
Major: AQL	4.0 percent defective
101	Unit packing incorrect
102	Packing incorrect
103	Marking missing, illegible, or incorrect

4.4.4 Tests.

4.4.4.1 Airflow resistance and DOP smoke penetration. The airflow resistance and DOP smoke penetration of the particulate filter shall be determined with the Q107 Penetrometer, or equivalent, at an airflow rate of 200 + 10 cfm.

5. PACKAGING

5.1 Packaging. packaging shall be as specified in SPI P5-19-6262.

6. NOTES

6.1 Intended use. This specification covers a particulate filter intended for use with MCPE/SCPE components.

6.2 Ordering data. Acquisition documents should specify the following:

(a) Title, number, and date of this specification.
(b) Level of unit packing and packing required.
(c) Preproduction:

(1) Time allowed for contractor submission of samples for Government test and evaluation after award of contract.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:03Z
Check the source to verify that this is the current version before use.

(2) Name and address of test facility and shipping instructions when testing is performed by the Government.)

(3) Time required for the Government to notify the contractor whether or not to proceed with production.

6.3 Subject term (key word) listing.

Airflow resistance
DOP smoke penetration
Filter, particulate
Media, filter
Penetrometer filter testing

6.4 Supersession data. This specification supersedes Chemical systems Laboratory Purchase Description EA-F-l125A, dated 23 June 1980.

Custodian:

Army-EA

Preparing activity:

Army-EA

(Project 4240-A832)

Source: https://assist.dla.mil -- Downloaded: 2026l0-22T21:03Z
Check the source to verify that this is the currentversion before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO. 4966 Alexandria, VA

POSTAGE WILL BE PAID BY

Commander
U.S. Army Chemical Research, Development
and Engineering Center
ATTN: SMCCR-SPT-S
Aberdeen Proving Ground, MD 21010-5423

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:03Z
Check the source to verify that this is the current version before use.

(TO DETACH THIS FORM, CUT ALONG THIS LINE.)

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE
MIL-F-51526(EA)	FILTER PARTICULATE, 200 CFM MCPE/SCPE APPLICATIONS

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR ☐ USER ☐ MANUFACTURER ☐ OTHER *(Specify)*: _____
b. ADDRESS *(Street, City, State, ZIP Code)*	

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:03Z
Check the source to verify that this is the current version before use.