MILITARY SPECIFICATION

SERVICE UNIT, REFRIGERATION SYSTEM (MUST)

This amendment forms a part of Military Specification MIL-S-52774A(ME), dated 11 December 1975, and is approved for use by the Mobility Equipment Research and Development Command, Department of the Army and is available for use by all Departments and Agencies of the Department of Defense.

PAGE 1

2.1, under SPECIFICATIONS, FEDERAL, delete:

"QQ-S-698	- Steel, Sheet and Strip, Low Carbon.
WW-T-755	- Tube, Copper, Seamless, (for Refrigeration and General Use)."

2.1, under SPECIFICATIONS, MILITARY, delete:

"MIL-P-116	- Preservation-Packaging, Methods of."

and add:

"MIL-P-116	- Preservation, Method of."

PAGE 2

Under STANDARDS, FEDERAL, add:

"FED-STD-H28	- Screw-Thread Standards for Federal Services."

Under STANDARDS, MILITARY, add:

"MIL-STD-1188	- Commercial Packaging of Supplies and Equipment.
MIL-STD-1474	- Noise Limits for Army Materiel."

PAGE 3

2.2, under Other publications, delete in their entirety: "AMERICAN NATIONAL STANDARDS INSTITUTE, INC. ANSI)," "UNIFORM CLASSIFICATION COMMITTEE, AGENT," "NATIONAL MOTOR FREIGHT TRAFFIC ASSOCIATION, INC., AGENT," AND "NATIONAL BUREAU OF STANDARDS."

and add:

"AMERICAN SOCIETY FOR TESTING AND MATERIAL (ASTM).

B280 - Small Copper Tubing.

FSC 4130

Source: https://assist.dla.mil -- Downloaded: 202640-22T21:32Z
Check the source to verify that this is the currentversion before use.

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.)

"AMERICAN SOCIETY OF HEATING, REFRIGERATING, AND AIR CONDITIONING ENGINEERS

ANSI/ASHRAE 15 - Safety Code for Mechanical Refrigeration.

(Application for copies should be addressed to the American Society of Heating, Refrigerating, and Air Conditioning Engineers, Inc., 345 East 47th Street, New York, NY 10017.)

"SOCIETY OF AUTOMOTIVE ENGINEERS

ANSI/SAE J513 - Refrigeration Tube Fittings.

(Application for copies should be addressed to the Society of Automotive Engineers, 400 Commonwealth Drive, Warrendale, PA 15096.)"

PAGE 4

3.4.1, line 4, delete "Handbook H28" and substitute "FED-STD-H28".

3.4.2, delete "WW-T-775" and substitute "ASTM-B280".

PAGE 5

3.4.4, line 2 delete: "QQ-S-698 or".

3.6, last line, delete "ANSI B9.1" and substitute "ANSI/ASHRAE 15".

PAGE 6

3.9.1, line 4, delete "ANSI B70.1" and substitute ANSI/SAE J513".

PAGE 9

3.9.5.3, line 2, delete "B9.1" and substitute "ANSI/ASHRAE 15".

PAGE 11

3.9.9, under list of items furnished with each unit, change the Quantity of "Vacuum Pump Oil" from: "1" to "3".

3.9.9, second line from last, delete "ANSI B70.1" and substitute ANSI/SAE J513".

Source: https://assist.dla.mil -- Downloaded: 202640-22T21:32Z
Check the source to verify that this is the currentversion before use.

PAGE 14

Add the following new paragraph:

"3.14 Noise level. The noise level of an open service unit with the vacuum pump operating shall be less than 85 dB(A) two feet from the front of the unit and at an elevation of 3 feet."

4.2(d), delete: "Inspection of Preparation for Delivery" and substitute "Inspection of Packaging".

PAGE 17

Table I; add under the following columns:

Inspec. Sequence	Pre-prod.	Qual. Conf.	Init. Prod.	Examination or test	Inspec. para.	Requirement para.
"15	X	-	-	Noise Level	4.6.3.14	3.14"

PAGE 21

Add:

"4.6.3.14 Noise level. The refrigeration service unit shall be tested in accordance with 5.1.2.5 of MIL-STD-1474. Certification that the service unit meets the requirements of 3.14 may be furnished in lieu of conducting the test. A noise level equal to or greater than 85 dB(A) shall constitute failure of this test."

PAGE 22

4.8, delete "Inspection of Preparation for Delivery" and substitute "Inspection of Packaging."

4.8.1.3, defect 125, delete "C" and substitute "Commercial."

4.8.1.3, defect 130, delete "Level C" and substitute "Commercial."

5., delete "PREPARATION FOR DELIVERY" and substitute "PACKAGING."

5.1, delete in its entirety and substitute:

"5.1 Preservation. Preservation shall be level A or commercial, as specified (see 6.2)."

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:32Z
Check the source to verify that this is the current version before use.

PAGE 23

5.1.2, delete in its entirety and substitute:

"5.1.2 Commercial. The enclosure, containing all the components comprising the complete service unit, positioned and secured as provided for, shall be preserved in accordance with MIL-STD-1188."

5.2, delete "C" and substitute "Commercial."

5.2.1 and 5.2.2, line 2, delete "and packaged".

5.2.3, delete in its entirety and substitute:

"5.2.3 Commercial. The enclosure containing all the components of the service unit, preserved as specified in 5.1, and secured to prevent pilferage of contents, shall be packed in accordance with MIL-STD-1188."

5.3, delete the period and add at the end of sentence "for level A or B and in accordance with MIL-STD-1188 for commercial."

PAGE 24

6.2(e), delete and substitute:

"(e) Degree of preservation and degree of packing required (see 5.1 and 5.2)."

Custodian:
Army - ME

Preparing activity:
Army - ME

Project 4130-A269

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:32Z
Check the source to verify that this is the currentversion before use.