J-C-103b

OCT 6 - 1960

INTERIM AMENDMENT-1

FEDERAL SPECIFICATION

CABLE, POWER, ELECTRICAL, (RUBBER-INSULATED, BUILDING-TYPE)
AND
WIRE ELECTRICAL
(RUBBER-INSULATED, BUILDING TYPE)

This Interim Amendment was developed by General Services Administration, Federal Supply Service. Its use is authorized in procurement by GSA as a part of Federal Specification J-C-103b, Cable, Power, Electrical, (Rubber-Insulated, Building-Type) And Wire, Electrical, (Rubber-Insulated, Building-Type) dated May 2, 1960. It will be converted to a regular amendment after further coordination.

Page 6, paragraph 4.4.1, delete entire paragraph and substitute:

4.4.1 Nonmilitary. - The label of Underwriters' Laboratories, Inc., (see 3.3.1, may be accepted by the purchaser as proof that the wire and cable delivered conform to the requirements of this specification. If further testing is desired, it shall be so stated in the invitation for bids and the material shall be tested in accordance with 4.4.3 through 4.4.7.3, as described in the referenced methods of Federal Specification J-C-98.

Page 10, paragraph 6.1, add:

(d) Tests nonmilitary. (See paragraph 4.4.1).

FSC 6145

Source: https://assist.dla.mil -- Downloaded: 202640-26T11:07Z
Check the source to verify that this is the current version before use.