J-C-71e
July 17, 1964
SUPERSEDING
Int. Fed. Spec. J-C-0071d(GSA-FSS)
April 24, 1963 and
Fed. Spec. J-C-71c
July 31, 1957

FEDERAL SPECIFICATION

CABLE, POWER, ELECTRICAL (ARMORED, INCLUDING LEAD-COVERED TYPES AND ARMORED CORD)

This specification was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

1. SCOPE AND CLASSIFICATION

1.1 Scope. This specification covers multiple-conductor armored cables for use at 600 volts or less; at temperatures not higher than 60, 75, or 90 degrees C., depending upon the temperature limit of the insulated conductors used; and in accordance with the National Electrical Code.

1.2 Classification.

1.2.1 *Types, classes, and kinds.* Armored cable furnished under this specification shall be of the following types and conductor classes and kinds, as specified (see 6.1).

Types:

AC* — Code grade rubber insulation, 60 degrees C. operation.

ACH* — Heat resistant grade rubber insulation, 75 degrees C. operation.

ACHH — Heat resistant grade rubber insulation, 90 degrees C. operation.

ACT — Thermoplastic insulation, 60 degrees C. operation.

Classes:

Class 1 — Solid conductor (AWG 14–AWG 8 only).

Class 2 — Stranded conductor of standard flexibility conforming to type C, class B of QQ-W-343 or class B of ASA C7.21.

Class 3 — Stranded conductor of greater flexibility, conforming to type C, class C of QQ-W-343 or class C of ASA C7.21.

Class 4 — Stranded conductor of extreme flexibility, conforming to type RC, class C of QQ-W-343.

*L — Used as a suffix indicates that a lead sheath has been applied over the conductor assembly.

FSC 6145

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:07Z
Check the source to verify that this is the current version before use.

Kinds:

Kind A — Aluminum conductor.

Kind C — Copper conductor.

1.2.2 *Number of conductors.* Armored cables shall be furnished in 2, 3, or 4 conductors, as specified (6.1).

2. APPLICABLE SPECIFICATIONS, STANDARDS, AND OTHER PUBLICATIONS

2.1 Specifications and standards. The following specifications and standards, of the issues in effect on date of invitation for bids, form a part of this specification.

Federal Specifications:

QQ–W–343 — Wire, Electrical and Non-electrical, Copper, (Uninsulated).

UU–P–271 — Paper, Wrapping, Waterproofed, Kraft.

PPP–B–601 — Boxes, Wood, Cleated-Plywood.

PPP–B–621 — Boxes, Wood, Nailed and Lock-Corner.

PPP–B–636 — Box, Fiberboard.

Federal Standards:

Fed. Std. No. 102 — Preservation, Packaging, and Packing Levels.

Fed. Std. No. 123 — Marking for Domestic Shipment (Civilian Agencies).

(Activities outside the Federal Government may obtain copies of Federal Specifications, Standards, and Handbooks as outlined under General Information in the Index of Federal Specifications and Standards and at the prices indicated in the Index. The Index, which includes cumulative monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U. S. Government Printing Office, Washington, D.C. 20402.

(Single copies of this specification and other product specifications required by activities outside the Federal Government for bidding purposes are available without charge at the General Services Administration Regional Offices in Boston, New York, Washington, D.C. Atlanta, Chicago, Kansas City, Mo., Dallas Denver San Francisco Los Angeles and Seattle, Wash.

(Federal Government activities may obtain copies of Federal Specifications, Standards, and Handbooks and the Index of Federal Specifications and Standards from established distribution points in their agencies.)

Military Specifications:

MIL–C–12000 — Cable, Cord, and Wire, Electric, Packaging and Packing.

(Copies of Military Specifications and Standards required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification. Unless otherwise indicated, the issue in effect on date of invitation for bids shall apply:

Underwriters' Laboratories, Inc. Standard:

UL–4 — Standard for Armored Cable.

(Copies may be obtained from Underwriters' Laboratories, Inc., Walt Whitman Road, Mellville, N.Y., 11749; 207 E. Ohio Street, Chicago, Illinois, 60611; and 1655 Scott Blvd., Santa Clare, California, 95050.)

American Standards Association, Inc. Standard:

C7.8 — Concentric-Lay-Stranded Copper Conductors, Hard, Medium-Hard, or Soft, Specifications for.

(Copies may be obtained from the American Standards Association, Inc., 10 East 40th Street, New York 16, N.Y.)

3. REQUIREMENTS

3.1 Armored cable furnished under this specification shall conform to the applicable requirements of Underwriters' Laboratories, Inc., Standard UL–4 for Armored Cable.

3.2 Conductor size. The size of armored cable conductors shall be limited to the range AWG–14 to AWG–1, inclusive, as specified (see 6.1).

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:07Z
Check the source to verify that this is the current version before use.

3.3 Fire and casualty hazards.

3.3.1 Each contractor shall submit to the contracting agency proof that the armored cable he proposes to supply under this specification conforms to the requirements of the Underwriters' Laboratories, Inc., UL–4 for Armored Cable. The label, or listing with reexamination, of the Underwriters' Laboratories, Inc., may be accepted as evidence that the armored cable conforms to this requirement.

3.3.2 Compliance with the above preliminary requirements in regard to fire and casualty hazards does not absolve the contractor from complete compliance with the requirements of this specification in order to secure acceptance of his material.

4. SAMPLING, INSPECTION, AND TEST PROCEDURES

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified, the supplier may utilize his own facilities or any commercial laboratory acceptable to the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure that supplies and services conform to prescribed requirements.

4.2 Sampling, inspection, and tests shall be in accordance with UL–4 to determine compliance with 3.1.

5. PREPARATION FOR DELIVERY

(For civil agency procurement the definitions and applications of levels of packaging and packing shall be in accordance with Fed. Std. No. 102).

5.1 Packaging and packing. Packaging and packing shall be level A, B, or C, as specified (see 6.1).

5.1.1 *Level A, B, or C.* The cable shall be packaged and packed in accordance with the requirements of MIL–C–12000.

5.2 Marking. The cable shall be marked in accordance with the requirements of MIL–C–12000 with the following additional requirement.

5.2.1 *Civil agencies.* In addition to markings required by the contract or order, the packages and shipping containers shall be marked in accordance with Fed. Std. No. 123.

6. NOTES

6.1 Ordering data. Purchasers should exercise any desired options offered herein and procurement documents should specify the following:

(*a*) Title, symbol, and date of this specification.

(*b*) Type, class, and kind of cable required (1.2.1).

(*c*) Number of conductors required (1.2.2).

(*d*) Conductor size (3.2).

(*e*) Responsibility for inspection, if other than specified (4.1).

(*f*) Level of packaging and packing (5.1).

(*g*) Special marking, if required (5.2).

6.2 If laboratory tests by the Government are required, purchasing officers should order cable for test purposes in addition to the number of feet required for installation.

6.3 Transportation description. Transportation description and minimum weights applicable to this commodity are:

Rail:

Cable, Electric, Armored, Lead Covered. Carload Minimum Weight 30,000 pounds.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:07Z
Check the source to verify that this is the current version before use.

Motor:

Cable, Electric, Armored, Lead Covered. Truckload Minimum Weight 30,000 pounds, Subject To Rule 115, National Motor Freight Classification.

MILITARY CUSTODIANS:

Army—MO

Navy—YD

Air Force—ROA

Review Interest:

MO, EL, YD, 88

User Interest:

MI, MC

Copies of this specification may be purchased for 5 cents each.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:07Z
Check the source to verify that this is the current version before use.