INCH-POUND

A-A-55810
3 April 1996
SUPERSEDING
WW-C-566C
21 October 1975

COMMERCIAL ITEM DESCRIPTION

CONDUIT, METAL, FLEXIBLE

The General Services Administration has authorized the use of this commercial item description as a replacement for WW-C-566C for all federal agencies.

1. SCOPE.

1.1 Scope. This commercial item description (CID) covers flexible aluminum and steel conduit.

1.2 Intended use. Flexible metal conduit covered by this CID is designed for use as metal raceway for wires and cables in accordance with the National Electrical Code.

2. CLASSIFICATION.

2.1 Classification. Flexible metal conduit shall be of the following types and sizes. The types and sizes to be furnished shall be as specified (see 7.2).

2.2 Type. Type I - Aluminum standard wall
Type II - Aluminum reduced wall
Type III - Steel standard wall
Type IV - Steel reduced wall

Beneficial comments, recommendations, additions, deletions, clarifications, etc. and any other data which improve this document should be sent to: Defense Supply Center Richmond, ATTN: DSCR-VBD, 8000 Jefferson Davis Highway, Richmond, VA 23297-5610.

AMSC N/A FSC 5975

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:57Z
Check the source to verify that this is the current version before use.

2.3 Size. Size 01 - Trade size 5/16 in. (Not available for types II and IV)
Size 02 - Trade size 3/8 in.
Size 03 - Trade size 1/2 in.
Size 04 - Trade size 3/4 in.
Size 05 - Trade size 1 in.
Size 06 - Trade size 1-1/4 in.
Size 07 - Trade size 1-1/2 in.
Size 08 - Trade size 2 in.
Size 09 - Trade size 2-1/2 in
Size 10 - Trade size 3 in.
Size 11 - Trade size 3-1/2 in. (Not available for types II and IV)
Size 12 - Trade size 4 in. (Not available for types II and IV)

3. SALIENT CHARACTERISTICS.

3.1 General requirements. The flexible metal conduit shall be listed with UL as meeting the requirements of UL 1. Unless otherwise specified (see 7.2), conduit shall be furnished in the following continuous coil lengths:

Trade Size (in.)	Coil Length (ft.)
5/16	250
3/8	100
1/2	100
3/4	100
1	50
1-1/4	50
1-1/2	25
2	25
2-1/2	25
3	25
3-1/2	25
4	25

4. REGULATORY REQUIREMENTS.

4.1 Recycled, recovered or environmentally preferable materials. Recycled, recovered or environmentally preferable materials should be used to the maximum extent possible, provided that the material meets or exceeds the operational and maintenance requirements and promotes economically advantageous life cycle costs.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:57Z
Check the source to verify that this is the current version before use.

5. QUALITY ASSURANCE PROVISIONS.

5.1 Contractor certification. The contractor shall certify and maintain substantiating evidence that the product offered meets the salient characteristics of this commercial item description and that the product conforms the producer's own drawings, specifications, and quality assurance practices, and is the same product offered for sale in the commercial marketplace. The government reserves the right to require proof of such conformance prior to first delivery, and thereafter, as may be otherwise provided under the provisions of the contract.

5.2 Examination. The flexible metal conduit shall be examined to determine compliance with all requirements specified in this CID.

6. PACKAGING.

6.1 Packaging requirements. Preservation, packing, and marking shall be as specified in the contract or order.

7. NOTES.

7.1 Referenced documents.

7.1.1 Government documents. Copies of Military and Federal documents may be obtained from DODSSP, Standardization Document Order Desk, 700 Robbins Avenue Bldg. 4D, Philadelphia, PA 19111-5094.

7.1.2 Industry documents. Copies of industry standards referenced in this CID may be obtained from the following address:

Underwriters Laboratories (UL), Inc., 333 Pfingsten Road, Northbrook, IL 60062

7.2 Ordering data. Acquisition documents must specify the following:

a. Title, number, and date of this document.
b. Type of flexible metal conduit required (see 2.2).
c. Size of flexible metal conduit (see 2.3).
d. Coil length, if different (see 3.1).

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:57Z
Check the source to verify that this is the current version before use.

7.3 Part identification number (PIN). The following part identification numbering procedure is for government purposes and does not constitute a requirement for the contractor.

A-A-55810-XXXXX

Size: 01 - Trade size 5/16 in.
02 - Trade size 3/8 in.
03 - Trade size 1/2 in.
04 - Trade size 3/4 in.
05 - Trade size 1 in.
06 - Trade size 1-1/4 in.
07 - Trade size 1-1/2 in.
08 - Trade size 2 in.
09 - Trade size 2-1/2 in
10 - Trade size 3 in.
11 - Trade size 3-1/2 in.
12 - Trade size 4 in.

Type: I - Type I (Aluminum standard wall)
II - Type II (Aluminum reduced wall)
III - Type III (Steel standard wall)
IV - Type IV (Steel reduced wall)

MILITARY INTERESTS:

Custodians
Army - AL
Air Force - 99

Reviewers
Air Force - 84
Navy - SH, YD-1

CIVIL AGENCY COORDINATING ACTIVITY:
GSA/FSS - 7FXE

PREPARING ACTIVITY:
DLA - GS

(Project 5975-1150)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:57Z
Check the source to verify that this is the current version before use.