INCH-POUND

A-A-55810A
13 February 2018
SUPERSEDING
A-A-55810
3 April 1996

COMMERCIAL ITEM DESCRIPTION

CONDUIT, METAL, FLEXIBLE

The General Services Administration has authorized the use of this commercial item description as a replacement for WW-C-566C for all federal agencies.

1. SCOPE. This commercial item description (CID) covers flexible aluminum and steel conduit.

1.1 Intended use. Flexible metal conduit covered by this CID is designed for use as metal raceway for wires and cables in accordance with the National Electrical Code.

2. CLASSIFICATION. Flexible metal conduit shall be of the following types and sizes:

2.1 Type. The type of flexible metal conduit to be furnished shall be as specified (see 7.3(b)).

Type I - Aluminum standard wall
Type II - Aluminum reduced wall
Type III - Steel standard wall
Type IV - Steel reduced wall

2.2 Size. The size of flexible metal conduit to be furnished shall be as specified (see 7.3(c)).

Size 01 - Trade size 5/16 in. (Not available for types II and IV)
Size 02 - Trade size 3/8 in.
Size 03 - Trade size 1/2 in.
Size 04 - Trade size 3/4 in.
Size 05 - Trade size 1 in.

Beneficial comments, recommendations, additions, deletions, clarifications, etc. and any data that may improve this document should be sent to: DLA Aviation, ATTN: DLA-VEB, 8000 Jefferson Davis Highway, Richmond, VA 23297-5616 or e-mailed to STDZNMGT@dla.mil. Since contact information can change, you may want to verify the currency of this address information using the ASSIST Online database at https://assist.dla.mil.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:57Z
Check the source to verify that this is the current version before use.

Size 06 - Trade size 1-1/4 in.

Size 07 - Trade size 1-1/2 in.

Size 08 - Trade size 2 in.

Size 09 - Trade size 2-1/2 in.

Size 10 - Trade size 3 in.

Size 11 - Trade size 3-1/2 in. (Not available for types II and IV)

Size 12 - Trade size 4 in. (Not available for types II and IV)

3. SALIENT CHARACTERISTICS.

3.1 General requirements. The flexible metal conduit shall be listed with Underwriters Laboratories (UL) as meeting the requirements of UL 1. Unless otherwise specified (see 7.3(d)), conduit shall be furnished in the following continuous coil lengths (see table I):

TABLE I. Coil Length.

Size	Trade size (in.)	Coil length (ft.)
01	5/16	250
02	3/8	100
03	1/2	100
04	3/4	100
05	1	50
06	1-1/4	50
07	1-1/2	25
08	2	25
09	2-1/2	25
10	3	25
11	3-1/2	25
12	4	25

4. REGULATORY REQUIREMENTS.

4.1 Recovered materials. The offeror/contractor is encouraged to use recovered materials to the maximum extent practicable, in accordance with paragraph 23.403 of the Federal Acquisition Regulation (FAR).

5. PRODUCT CONFORMANCE PROVISIONS.

5.1 Product conformance. The products provided shall meet the salient characteristics of this commercial item description, conform to the producer's own drawings, specifications, standards, and quality assurance practices, and be the same product offered for sale in the

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:57Z
Check the source to verify that this is the current version before use.

commercial market. The government reserves the right to require proof of such conformance prior to first delivery, and thereafter, as may be otherwise provided under the provisions of the contract.

5.1.1 Contractor certification. The contractor shall certify and maintain substantiating evidence that the product offered conforms to all the requirements specified in this CID.

5.1.2 Examination. The flexible metal conduit shall be examined to determine compliance with all requirements specified in this CID.

5.2 Market acceptability. The product offered must have been previously sold to the government or the commercial market.

6. PACKAGING.

6.1 Packaging requirements. Preservation, packing, and marking shall be as specified in the contract or order (see 7.3(e)).

7. NOTES.

7.1 Part or identification number (PIN). The following PIN procedure is for government purposes and does not constitute a requirement for the contractor.



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:57Z
Check the source to verify that this is the current version before use.

7.2 Source of documents.

7.2.1 Copies of the FAR may be obtained online from https://www.acquisition.gov/far.

7.2.2 Copies of Military and Federal documents may be obtained online at http://quicksearch.dla.mil.

7.2.3 Copies of Underwriters Laboratories (UL) documents may be obtained online at https://www.ul.com/.

7.3 Ordering data. Acquisition documents should specify the following:

a. Title, number, and date of this CID.
b. Type of flexible metal conduit required (see 2.1).
c. Size of flexible metal conduit (see 2.2).
d. Coil length, if different (see 3.1).
e. Packaging requirements (see 6.1).

MILITARY INTERESTS:

Custodians:
Army – AR
Navy – SH
Air Force – 99
DLA – GS

Review activities:
Air Force – 84
Navy – YD

CIVIL AGENCY COORDINATING ACTIVITY:

GSA/FAS

Preparing Activity:
DLA – GS8

(Project 5975-2018-001)

NOTE: The activities listed above were interested in this document as of the date of this document. Since organizations and responsibilities can change, you should verify the currency of the information above using the ASSIST Online database at https://assist.dla.mil.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:57Z
Check the source to verify that this is the current version before use.