W-F-396c
AMENDMENT—2
July 22, 1965

SUPERSEDING
Int. Amendment—1
January 7, 1965

FEDERAL SPECIFICATION

FIRE ALARM SYSTEM; LOCAL, ELECTRIC, SUPERVISED, SELECTIVE CODED, SHUNT NONINTERFERING TYPE

This amendment, which forms a part of Federal Specification W-F-396c, dated November 27, 1963, was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

PAGE 2

Paragraph 2.2, between lines 7 and 8: Insert the following:

UL-38—Manually Actuated Signalling Boxes For Use With Fire-Protective Signalling Systems.

Paragraph 2.2, between lines 9 and 10: Insert the following:

UL-632—Electrically Actuated Transmitters.

PAGE 3

Paragraph 3.2.1, line 5: After "of" delete entire balance of line and substitute the following:

UL-38, UL-464, UL-521, UL-632, and UL-864.

PAGE 4

Paragraph 3.4.1: At end of sentence, delete period and add "and UL-38."

PAGE 6

Paragraph 3.6.1: At end of sentence, delete period and add "and UL-632."

PAGE 9

Paragraph 3.12.1.1: Delete in its entirety and substitute the following:

3.12.1.1 *Stations and transmitters.* The following requirements shall conform to NEMA standard:

SB1—1962, part 4, section 1:

(a) Vibration
(b) Jarring
(c) Insulation resistance

3.12.1.1.1 *Stations.* In addition to the requirements of 3.12.1.1, the following requirements shall conform to UL-38:

(a) Normal operation
(b) Over-and under-current operation
(c) Overload and endurance
(d) Dielectric strength
(e) Spray (style D stations only)
(f) Humidity (style D stations only)

3.12.1.1.2 *Transmitters.* In addition to the requirements of 3.12.1.1, the following requirements shall conform to UL-632:

(a) Normal operation
(b) Circuit-emergency operation
(c) Input and output current and voltage
(d) Over-and under-voltage operation
(e) Overload
(f) Endurance
(g) Dielectric strength

Paragraphs 3.12.1.2 and 3.12.2: Delete "Unless otherwise specified (see 6.1)."

PAGE 10

Paragraph 3.12.3: Delete "Unless otherwise specified"

PAGE 12

Paragraph 6.1: Delete (*u*) in its entirety.
Notice: Delete in its entirety.

FSC 6350

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:26Z
Check the source to verify that this is the current version before use.