MIL-F-43093E(ME)
15 August 1985
SUPERSEDING
MIL-F-43093D(ME)
5 June 1985

MILITARY SPECIFICATION

FUEL SYSTEM SUPPLY POINT: PORTABLE

This specification is approved for use by the USA Belvoir Research and Development Center, Department of the Army, and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers an improved portable fuel system which when combined with three collapsible fabric tanks (in any combination of 3000, 10,000, and 20,000 gallon capacities); two 350 GPM pumps; and two 350 GPM filter separators, is capable of receiving, dispensing, and storing automotive gasoline, aviation gasoline, jet fuel, or diesel fuel.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standards. The following specifications, standards, and component parts list form a part of this specification to the extent specified herein. Unless otherwise specified, the issues of these documents shall be those listed in the issue of the Department of Defense Index of Specifications and Standards (DoDISS) and supplement thereto, cited in the solicitation.

SPECIFICATIONS

FEDERAL

PPP-B-601	- Boxes, Wood, Cleated-Plywood.
PPP-B-621	- Boxes, Wood, Nailed and Lock-Corner.
PPP-B-636	- Boxes, Shipping, Fiberboard.

MILITARY

MIL-V-3	- Valves, Fittings, and Flanges (Except for Systems Indicated Herein): Packaging of.

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: USA Belvoir Research and Development Center, ATTN: STRBE-DS, Fort Belvoir, VA 22060-5606 by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

FSC 4930

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T20:31Z
Check the source to verify that this is the current version before use.

MIL-C-104	- Crates, Wood; Lumber and Plywood Sheathed, Nailed and Bolted.
MIL-P-116	- Preservation-Packaging, Methods of.
MIL-T-704	- Treatment and Painting of Materiel.
MIL-P-775	- Packaging of Hose, Hose Assemblies, Rubber, Plastic, Fabric or Metal (Including Tubing); and Fittings, Nozzles and Strainers.
MIL-C-3774	- Crates, Wood; Open 12,000- and 16,000-Pound Capacity.
MIL-S-7916	- Sealing Compound, Thread and Gasket, Fuel, Oil, and Water-resistant.
MIL-G-20241	- Gasket Material, Wool Felt, Impregnated, Adhesive, Pressure-Sensitive.
MIL-C-27487	- Coupling Halves, Quick Disconnect, Cam Locking Type.
MIL-C-46168	- Coating, Aliphatic Polyurethane, Chemical Agent Resistant.
MIL-P-52144	- Pumping Assembly, Flammable Liquid, Bulk Transfer, Diesel Engine Driven, 350 GPM Capacity, 275 Total Head, Wheel Mounted.
MIL-F-52666	- Filter-Separators, Liquid Fuel: Frame Mounted, 350 GPM Capacity.
MIL-T-52983	- Tanks, Fabric, Collapsible: 3,000, 10,000, 20,000, and 50,000 Gallon, Petroleum.
MIL-S-81733	- Sealing and Coating Compound, Corrosion Inhibitive.

STANDARDS

FEDERAL

FED-STD-595	- Colors.

MILITARY

MIL-STD-105	- Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129	- Marking for Shipment and Storage.
MIL-STD-889	- Dissimilar Metals.
MIL-STD-1186	- Cushioning, Anchoring, Bracing, Blocking, and Waterproofing; with Appropriate Test Methods.

COMPONENT PARTS LIST

MILITARY

CPL 85203	- Improved Fuel System Supply Point.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T20:31Z
Check the source to verify that this is the current version before use.

(Copies of specifications, standards, handbooks, publications, and other Government documents required by contractors in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting activity.)

2.2 Other publications. The following document(s) form a part of this specification to the extent specified herein. Unless otherwise specified, the issues of the documents which are DOD adopted shall be those listed in the issue of the DoDISS specified in the solicitation. Unless otherwise specified, the issues of documents not listed in the DoDISS shall be the issue of the nongovernment documents which is current on the date of the solicitation.

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

ASTM D 3951 - Standard Practice for Commercial Packaging.

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.)

(Nongovernment standards and other publicatins are normally available from the organizations which prepare or which distribute the documents. These documents also may be available in or through libraries or other informational services.)

2.3 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein, (except for associated detail specifications, specification sheets or MS standards), the text of this specification shall take precedence. Nothing in this specification, however, shall supersede applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3.1 Description. The fuel system supply point shall consist of hoses, valves, manifolds, nozzles, various other components and associated tanks, pumps and filter/separators in quantities specified herein.

3.2 First article. When specified in the contract or purchase order, a sample shall be subjected to first article inspection (see 4.3 and 6.3). Any changes or deviations of the fuel system supply point from the approved first article during production will be subject to the approval of the contracting officer. Approval of the first article will not relieve the contractor of his obligation to furnish the fuel system supply point conforming to this specification.

3.3 Material. Material shall be as specified herein. Materials not specified shall be selected by the contractor and shall be subject to all provisions of this specification.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T20:31Z
Check the source to verify that this is the current version before use.

3.3.1 Material deterioration and control. The components of the fuel system supply point shall be fabricated from compatible materials, inherently corrosion and deterioration resistant or treated to provide protection against the various forms of corrosion and deterioration that may be encountered in any of the applicable storage and operating environments to which the components of the fuel system supply point may be exposed.

3.3.1.1 Dissimilar metals. Dissimilar metals, as defined in MIL-STD-889, shall be electrically insulated from one another to minimize or prevent galvanic corrosion. Insulation may be provided by an insulating barrier such as a corrosion inhibiting sealant conforming to MIL-S-81733 or chromate tape conforming to MIL-G-20241. Protection against corrosion could also be obtained by exclusion of the electrolyte if feasible.

3.3.1.2 Identification of materials and finishes. The contractor shall identify the specific material, material finish or treatment for use with components and sub-components, and shall make information available, upon request, to the contracting officer or designated representative.

3.3.2 Recovered materials. For the purpose of this requirement, recovered materials are those materials which have been collected from solid waste and reprocessed to become a source of raw materials, as distinguished from virgin raw materials. The components, pieces and parts incorporated in the fuel system supply point may be newly fabricated from recovered materials provided the fuel system supply point produced meets all other requirements of this specification. Used, rebuilt or remanufactured components, pieces and parts shall not be incorporated in the fuel system supply point.

3.4 Storage tanks. The 10,000 gallon, and the 20,000 gallon storage tanks shall conform to MIL-T-52983. Unless otherwise specified (see 6.2), the tanks shall not be furnished by the contractor.

3.5 Pumps. The pumps shall conform to MIL-P-52144. Unless otherwise specified (see 6.2), the pumps shall not be furnished by the contractor.

3.6 Filter-separators. The filter-separators shall conform to MIL-F-52666. Unless otherwise specified (see 6.2), the filter-separators shall not be furnished by the contractor.

3.7 Cam-locking couplings. Cam-locking couplings shall conform to MIL-C-27487. Cam-locking couplings shall be anodized and dyed to match color number 34052 of FED-STD-595.

3.8 Components. The sizes, types, and quantities of components shall be as specified in CPL 85203.

3.9 Sealing compound. Sealing compound conforming to MIL-S-7916 shall be applied to the male threads of all parts and fittings prior to assembly.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T20:31Z
Check the source to verify that this is the current version before use.

3.10 Plastic caps and plugs. Each cam-locking fitting, except those fittings equipped with aluminum dust caps or plugs (see 5.2.1.6) shall be covered with a tight-fitting, fuel-resisting plastic dust cap or plug. The caps for the male fittings shall snap in place and shall not fall off when the fitting is inverted (cap down). The plugs for the female fittings shall be held in place by the cam-locking mechanism. The caps and plugs shall be removable and replaceable without tools and shall provide a positive dust seal when in place.

3.11 Bulk materials and special tools. Bulk materials and special tools in the quantitites shown in CPL 85203, shall be supplied with each fuel system.

3.12 Treatment and painting. The portions of the fuel system supply point normally painted internally and externally shall be cleaned, treated, and painted in accordance with MIL-T-704, type F or G, as applicable. Unless otherwise specified (see 6.2) top coat color shall be camouflage green 383 conforming to MIL-C-46168.

3.13 Workmanship. All parts and components of the fuel system shall be clean and free from extraneous material. Any necessary rework shall be limited to procedures which will not affect the strength or functioning of parts or components.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Responsibility for compliance. All items must meet all requirements of sections 3 and 5. The inspection set forth in this specification shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the specification shall not relieve the contractor of the responsibility of assuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling in quality conformance does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to acceptance of defective material.

4.1.2 Component and material inspection. The contractor is responsible for insuring that components and materials used are manufactured, examined, and tested in accordance with referenced specifications, standards, and drawings, as applicable.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T20:31Z
Check the source to verify that this is the current version before use.

4.2 Classification of inspection. Inspection requirements specified herein are classified as follows:

a. First article fuel system (see 4.3).
b. Quality conformance inspection (see 4.4).
c. Inspection of packaging (see 4.6).

4.3 First article fuel system inspection.

4.3.1 Sampling. From each first article fuel system, a random sample of not less than one each component furnished by the contractor shall be selected for examination and test.

4.3.2 Examination. The first article samples selected in accordance with 4.3.1 shall be examined as specified in 4.5.1. Presence of one or more defects shall be cause for rejection.

4.3.3 Tests. The first article samples selected in accordance with 4.3.1 shall be tested as specified in 4.5.2. Failure of any test shall be cause for rejection.

4.4 Quality conformance inspection.

4.4.1 Sampling. From each fuel system offered for delivery, a random sample of not less than one each component furnished by the contractor shall be selected for examination and test.

4.4.2 Examination. Samples selected in accordance with 4.4.1 shall be examined as specified in 4.5.1. Presence of one or more defects shall be cause for rejection.

4.4.3 Tests. Samples selected in accordance with 4.4.1 shall be tested as specified in 4.5.2. Failure of any test shall be cause for rejection.

4.5 Inspection procedure.

4.5.1 Examination. The fuel system shall be examined as specified herein for the following major defects:

101. Material not as specified.
102. Materials are not resistant to corrosion and deterioration or treated to be resistant to corrosion and deterioration for the applicable storage and operating environments.
103. Dissimilar metals as defined in MIL-STD-889 are not effectively insulated from each other.
104. Contractor does not have documentation available for identification of material, finishes or treatment.
105. Tanks not as specified, when applicable.
106. Pumps not as specified, when applicable.
107. Filter assemblies not as specified, when applicable.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T20:31Z
Check the source to verify that this is the current version before use.

108. Components missing or not as specified.
109. Fitting assemblies not as specified.
110. Valve assemblies not as specified.
111. Nozzles not as specified.
112. Accessories and replacement parts missing or not as specified.
113. Anodizing not as specified.
114. Color not as specified.
115. Workmanship not as specified.
116. Plastic caps and plugs missing or not as specified.
117. Cam-locking couplings missing or not as specified.
118. Sealing compound missing or not as specified.
119. Recovered materials not as specified.
120. Treatment and painting not as specified.
121. Paint color not as specified.

4.5.2 Functional test. The samples shall be assembled together to form a continuous hose and manifold system. Assembly and disassembly of the test samples shall be accomplished by hand without the use of tools. The hose and manifold assembly shall be subjected to a water pressure of 150 pounds per square inch (psi). While under pressure the entire system shall be examined for leaks, imperfections in any hose or fitting, or slippage or pullout of the hose fittings. Each valve and nozzle shall be individually activated. Inability to assemble the system by hand, evidence of leakage, imperfections in the hose or fittings, slippage or pullout of the hose fittings, or inability to operate any valve or nozzle shall constitute failure of this test.

4.6 Inspection of packaging.

4.6.1 First article pack inspection.

4.6.1.1 Examination. The first article pack shall be examined for the defects specified in 4.6.2.3. Presence of one or more defects shall be cause for rejection.

4.6.1.2 Test. The first article pack of crated components comprising the fuel system packed for level A, shall be subjected to the rail-impact test in accordance with MIL-STD-1186, appendix A. Crates not exceeding 9.5 feet in length shall be subjected to tests on each end and each side, a total of 8 impacts. At the conclusion of the first article pack test, the pack shall be examined. Any shifting of contents, loosening or breaking of holddowns, ties, stays, blocking or bracing, or any visual damage to the components shall constitute failure of the first article pack and shall be cause for rejection.

4.6.2 Quality conformance inspection of pack.

4.6.2.1 Unit of product. For the purpose of inspection, a completed pack prepared for shipment shall be considered a unit of product.

4.6.2.2 Sampling. Sampling for examination shall be in accordance with MIL-STD-105.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T20:31Z
Check the source to verify that this is the current version before use.

4.6.2.3 Examination. Samples selected in accordance with 4.6.2.2 shall be examined for the following defects. AQL shall be 2.5 percent defective.

122.	Storage tanks not preserved and packed in accordance with the referenced document for level A or commercial.
123.	Pumps not preserved and packed in accordance with the referenced document for level A or commercial.
124.	Filter-separators not preserved and packed in accordance with the referenced document for level A or commercial.
125.	Hose and nozzles not preserved in accordance with the referenced document for level A.
126.	Valves and fittings not preserved in accordance with the referenced document for level A.
127.	Fittings and hose assemblies not sealed with caps or plugs as specified for level A or commercial.
128.	Gaskets not preserved as specified for level A.
129.	Gaskets and sealing compound not placed together as specified for level A.
130.	Consolidation not as specified for level A.
131.	Packing not as specified for level A.
132.	Marking missing, illegible, incorrect, or incomplete for level A or commercial.

5. PACKAGING

5.1 First article pack. The contractor shall furnish a first article pack for examination and test within the time frame specified (see 6.2) to prove, prior to starting production packaging that the applied preservation, packing, and marking comply with the packaging requirements of this specification. Examination and test shall be as specified in section 4 and shall be subject to surveillance and approval by the Government (see 6.4). The first article pack may be accomplished utilizing either the first article fuel system or a production fuel system. If the first article fuel system is utilized, any preservation, and packing shall be removed by the contractor at no expense to the Government, when requested by the Government, to facilitate comparison between the first article fuel system and the production fuel system.

5.2 Preservation. Preservation shall be level A or commercial as specified (see 6.2).

5.2.1 Level A.

5.2.1.1 Storage tanks. Each storage tank shall be preserved in accordance with the level A requirements of MIL-T-52983 when applicable.

5.2.1.2 Pumps. Each pump shall be preserved in accordance with the level A preservation and packaging requirements of MIL-P-52144, when applicable.

5.2.1.3 Filter-separators. Each filter-separator shall be preserved in accordance with the level A preservation and packaging requirements of MIL-F-52666, when applicable.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T20:31Z
Check the source to verify that this is the current version before use.

5.2.1.4 Hoses and nozzles. Hoses with attached fittings and nozzles shall each be preserved in accordance with the level A preservation and packaging requirements of MIL-P-775.

5.2.1.5 Valves and fittings. Valves and fittings shall be preserved in accordance with the level A preservation and packaging requirements of MIL-V-3.

5.2.1.6 Caps and plugs. The aluminum caps and plugs, specified in CPL 85203 shall be placed at random on the fittings and hose assemblies until exhausted. The remainder of the fittings or hose assemblies shall be sealed with plastic cups or plugs, as specified in 3.10.

5.2.1.7 Gaskets and sealing compound. Gaskets shall be individually preserved, in a flat position, in accordance with MIL-P-116, method IC-1 or IC-3. the gaskets and the sealing compound shall then be placed together in a close-fitting box conforming to PPP-B-636, W6c. The sealing compound shall be secured within the box in a manner to avoid damage to the gaskets.

5.2.1.8 Tools. The preservative application criteria and applicable method(s) of preservation contained in MIL-P-116 shall be used to preserve the tools.

5.2.1.9 Nuts, screws, and washers. Loose nuts, screws, and washers of like size shall be preserved together in accordance with MIL-P-116, method IC-1 or IC-3 and then all placed together in a close-fitting box conforming to PPP-B-636, W6c, style optional.

5.2.1.10 Consolidation. Preserved and unpreserved components, except for the tanks, pumps, and filter separators, shall be consolidated together in boxes conforming to PPP-B-601, overseas type, style optional or PPP-B-621, class 2, style optional. When practical, the boxes shall contain only components of like description. The boxes shall be of a size and configuration to most conveniently accomplish the packing specified in 5.3.1. The components shall be blocked, braced, anchored, or cushioned, as applicable, within the boxes to prevent movement or damage to the contents. Box closure shall be in accordance with the appendix to the applicable box specification. Strapping shall not be required.

5.2.2 Commercial. The components of the fuel system shall be preserved in accordance with ASTM D 3951 and, in addition, fittings and hose assemblies shall be sealed as specified in 5.2.1.6. When storage tanks, pumps, and filter-separators are furnished they shall be preserved in accordance with the level C or commercial requirements of MIL-T-52983, MIL-P-52144, or MIL-F-52666, as applicable.

5.3 Packing. Packing shall be level A or commercial as specified (see 6.2).

5.3.1 Level A. The components of the fuel system, except for the storage tanks, pumps, and filter-separators (see 5.3.1.1), preserved as specified in 5.2, shall be packed together in a crate conforming to MIL-C-104, type I or II,

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T20:31Z
Check the source to verify that this is the current version before use.

class 1 or 2, style B or in a crate conforming to MIL-C-37774, nailed assembly, skid type base. The contents shall be secured to the crate base to provide minimum cube and shall be blocked, braced and anchored in accordance with the appendix to the applicable crate specification and in accordance with MIL-STD-1186.

5.3.1.1 Storage tanks, pumps, and filter-separators. When applicable, the storage tanks, pumps, and filter-separators shall be packed in accordance with the level A requirements of MIL-P-52144 or MIL-F-52666, as applicable. The storage tanks, pumps, and filter-separators shall be shipped separately from, but at the same time as, the crate containing the other components of the fuel system.

5.3.2 Commercial. Components of the fuel system preserved as specified in 5.2 shall be packed in accordance with ASTM D 3951.

5.4 Marking.

5.4.1 Military. Marking for level A shall be in accordance with MIL-STD-129.

5.4.2 Commercial. Marking for commercial packaging shall be in accordance with ASTM D 3951 and in addition shall indicate the weight and cube.

6. NOTES

6.1 Intended use. The fuel system is intended to refuel convoys, fill 5- and 55-gallon containers, and perform the following functions:

a. Receive fuel from tank trucks to fill the storage tanks.
b. Pump fuel from the storage tanks to the dispensing points.
c. Bypass the storage tanks and pump directly from the tank trucks to the dispensing points.

6.2 Ordering data. Procurement documents should specify the following:

a. Title, number, and date of this specification.
b. Time frame required for submission of the first article fuel and the number of fuel systems required (see 3.2).
c. When the Government will conduct any or all of the first article examination and tests. When the Government will conduct some but not all of the first article examination and tests, the contracting officer should specify which examination and tests will be conducted by the Government and which examination and tests shall be conducted by the contractor (see 3.2).
d. When the 10,000 and 20,000 gallon tanks will be furnished by the contractor (see 3.4).
e. When the pumps will be furnished by the contractor (see 3.5).
f. When the filter-separators will be furnished by the contractor (see 3.6).
g. Color required when other than as specified (see 3.12).
h. Time frame required for submission of first article pack (see 5.1).
i. Degree of preservation and degree of packing required (see 5.2 and 5.3).

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T20:31Z
Check the source to verify that this is the current version before use.

6.3 First article. When a first article inspection is required, the items should be a preproduction item. The first article should consist of one unit. The contracting officer should include specific instructions in acquisition documents regarding arrangements for examination tests and approval of the first article test results and disposition of the document's first article.

6.4 First article pack. Any changes or deviations of production packs from the approved first article pack will be subject to the approval of the contracting officer. Approval of the first article pack will not relieve the contractor of his obligation to preserve, pack, and mark the fuel systems in accordance with this specification.

Custodian:
Army - ME

Preparing activity:
Army - ME

Review activity:
DLA - CS

Project 4930-A251

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T20:31Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

DEPARTMENT OF THE ARMY

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO. 12062 WASHINGTON D. C.
POSTAGE WILL BE PAID BY THE DEPARTMENT OF THE ARMY

Commander
US Army Belvoir R&D Center
ATTN: STRBE-DS
Fort Belvoir, VA 22060-5606

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T20:31Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE
MIL-F-43093E(ME)	Fuel System Supply Point: Portable

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
b. ADDRESS *(Street, City, State, ZIP Code)*	☐ USER
	☐ MANUFACTURER
	☐ OTHER *(Specify)*: _____

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T20:31Z
Check the source to verify that this is the current version before use.