[INCH-POUND]
A-A-55518/3
March 1, 1996


COMMERCIAL ITEM DESCRIPTION

FUSEHOLDER, BLOCK, 30 AMPERES (A), 250 VOLTS (V) AC, 1 THROUGH 12 POLE ACCOMMODATES 4AG OR 4AB TYPE FUSE CARTRIDGES

The General Services Administration has authorized the use of this commercial item description (CID) for all federal agencies

1 SCOPE This CID covers the general requirements for fuseholder blocks with 1 through 12 poles which accommodates 4AG or 4AB type fuse cartridges Fuseholder blocks covered by this CID are intended for commercial/industrial applications

2 CLASSIFICATION This CID uses a classification system which is included in the Part or Identification Number (PIN) The PIN shall be AA55518/03- (plus a dash number from table I) Complete PIN example AA55518/03-002 (see 6 1)



3 SALIENT CHARACTERISTICS

3 1 Design and construction Fuseholder blocks supplied to this CID shall be as specified

3 2 Ampere rating The ampere rating shall be 30 A maximum


3 3 Voltage rating The voltage rating shall be 250 V ac maximum


3 4 Fuse accommodation This fuseholder accommodates 4AG or 4AB type fuse cartridges with dimensions of 7 14 mm x 31.75 mm (281 inch x 1 25 inch)

Beneficial comments, recommendations, additions, deletions, clarifications, etc, and any data which may improve this document should be sent to Defense Electronics Supply Center, ATTN DESC-ELDM, 1507 Wilmington Pike, Dayton, OH 45444-5765, or telephone (513) 296-6189, or facsimile (FAX) (513) 296-8868

AMSC N/A FSC 5920
DISTRIBUTION STATEMENT A Approved for public release, distribution is unlimited

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:50Z
Check the source to verify that this is the current version before use.





mm	Inches	mm	Inches
0 80	031	11 20	440
1 52	060	20 60	.810
4 34	171	30 23	1 190
5 59	220	32 51	1 280
6 35	250	60 45	2 380
6 86	270		

NOTES

1 Dimensions are in millimeters

2 Tolerance is ±0 13 mm (005 inch), unless otherwise specified

3 The following notes apply to width A of the fuseholders (see table I)

   a The longitudinal centerline of single pole and outer pairs of fuse clips on multiple pole fuseholders shall be located 9 9 mm (39 inch) from the edge of the fuseholder block

   b The distance between longitudinal centerlines of adjacent pairs of fuse clips shall be 23 1 mm (91 inch)

   c A minimum of two mounting holes shall be provided on multiple pole fuseholders These holes shall be one each centrally located between the fuse clips on the longitudinal centerline of the outer pairs of fuse clips

4 The US government preferred system of measurement is the metric SI system However, this item was originally designed using inch-pound units of measurement In the event of conflict between the metric and inch-pound units, the inch-pound units shall take precedence

Figure 1 Configuration and dimensions (screw terminals)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:50Z
Check the source to verify that this is the current version before use.

TABLE I Characteristics

CID dash number AA55518/03-	Number of poles	Dimension A (see figure 1)
001	1	19 8 (78)
002	2	42 9 (1 69)
003	4	88 9 (3 50)
004	9	204 0 (8 03)

3 5 Fuseholder base The fuseholder base shall be molded or laminated plastic

3 6 Fuse clips This fuseholder shall be supplied with Commercial Item Description (CID) number AA55507/01-02 fuse clips

3 7 Marking Fuseholder blocks supplied to this CID shall be marked with the manufacturer's standard commercial PIN

4 QUALITY ASSURANCE PROVISIONS Quality assurance provisions shall be as specified in A-A-55518

5 PACKAGING Packaging shall be as specified in A-A-55518

6 NOTES

6 1 PIN The PIN should be used for Government purposes to buy commercial products to this CID See section 2 for PIN format

6 2 CAGE code For ordering purposes, inventory control, and submission of these instruments to DESC under the Military Parts Control Advisory Group (MPCAG) evaluation program, CAGE code 58536 should be used

6 3 Source of documents

Commercial Item Description

A-A-55518 - Fuseholder, Block, General Requirements

A-A-55507/01 - Clip, Electrical, Fuse, 30 and 60 Ampere, For Fuse Diameters 1/4" Thru 13/16"

(Copies of commercial item descriptions are available from the Defense Printing Service Detachment Office, Building 4D (Customer Service), 700 Robbins Avenue, Philadelphia, PA 19111-5094)

6 4 Ordering data Ordering data shall be as specified in A-A-55518

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:50Z
Check the source to verify that this is the current version before use.

6 5 Commercial products As part of the market analysis and research effort, this CID was coordinated with the following manufacturers of commercial products At the time of CID preparation and coordination, these manufacturers were known to have commercial products that would meet the requirements of this CID (NOTE This information should not be considered as a list of approved manufacturers or be used to restrict procurement to only the manufacturers shown)

MFGR's CAGE	MFGR's name and address
71400	Bussmann P O Box 14460 St Louis, MO 63178-4460 (314) 527-1253

6 6 Part number (P/N) supersession data This CID supersedes the following manufacturer's P/Ns as shown This information is being provided to assist in reducing proliferation in the government inventory system

Dash number (see table I) AA55518/03-	MFGR CAGE	MFGR P/N 1/
001	71400	FH22AM
002	71400	FH22BM
003	71400	FH22EM
004	71400	FH24LM

1/ The manufacturer's P/N shall not be used for procurement to the requirements of this CID At the time of preparation of this CID, the aforementioned commercial products were reviewed and could be replaced by the CID PIN shown

6 7 Government users To acquire information on obtaining these fuseholder blocks from the Government inventory system, contact Defense Electronics Supply Center, ATTN DESC-EOM, 1507 Wilmington Pike, Dayton, OH 45444-5519, or telephone (513) 296-5106

MILITARY INTERESTS

Custodians
Army - ER
Navy - SH
Air Force - 85

Review Activities
Army - AR, AT, EA, MI
Navy - AS, CG, EC
Air Force - 17, 19, 99

CIVIL AGENCY COORDINATING ACTIVITY

GSA - 7FXE

Preparing Activity

DLA - ES

Project 5920-0534-03

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:50Z
Check the source to verify that this is the current version before use.