A-A-53984
15 September 1989

COMMERCIAL ITEM DESCRIPTION

WIRE TWISTER, DENTAL, BLUNT

The General Services Administration has authorized the use of this Commercial Item Description.

This commercial item description covers a wire twister clamp suitable for clamping and twisting ligature wire for use in maxillofacial, oral, orthodontic, and orthopedic procedures.

Salient characteristics:

The wire twister shall be capable of gripping, clamping, holding, and twisting ligature wire without slippage or defacement of the operative surfaces.

Material. The wire twister shall be fabricated from class 4, type 410 or 420A or 420B martensitic stainless steel in accordance with ASTM Standard F899. The mating surfaces of the jaws shall have tungsten carbide inserts.

Hardness. The wire twister shall have a Rockwell hardness of C40 to C45, with the exception of the screw or pin, when tested as specified in ASTM E18 or E92. The tungsten carbide insert shall have a Rockwell hardness of A80, minimum, when removed from the jaw of a completed instrument.

Style, design and dimensions. The wire twister shall be of box joint construction with finger rings and ratchet lock. Jaws shall properly match, be of a blunted, rectangular shape with inner operative surfaces faced with tungsten carbide. The wire twister shall be as shown in Defense Personnel Support Center (DPSC) Drawing 24585.

Finish. Except for the mating surfaces of the jaws, the wire twister shall have a mirror or matte finish.

AMSC N/A FSC 6520

DISTRIBUTION STATEMENT A: Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:27Z
Check the source to verify that this is the current version before use.

Corrosion resistance. Corrosion resistance tests in accordance with ASTM F1089 shall be applicable. The entire instrument shall meet the boil test requirement and copper sulfate test requirement.

Identification marking. Wire twisters shall be permanently and legibly marked with the name or registered trademark of the contractor and the word "stainless". Instruments of foreign manufacture shall bear the name of the country of origin.

Workmanship. The wire twister shall be free from defects which detract from its appearance or impair its serviceability.

Unit. Each (EA). One wire twister, as specified, constitutes one unit.

Unit package. Each wire twister shall be packaged in a suitable box.

Quality Assurance Provisions.

Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

Records. Records of examinations and tests performed by or for the contractor shall be maintained by the contractor and made available to the Government upon the Government's request, at any time, or from time to time, during the performance of the contract and for a period of three years after delivery of the supplies to which such records relate.

Inspection. Inspection, as used herein, is defined as both examination (such as visual or auditory investigation without the use of special laboratory appliances or procedures) and testing (determination by technical means of physical and chemical properties) of the item.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:27Z
Check the source to verify that this is the current version before use.

Sampling for inspection. Sampling for inspection shall be conducted in accordance with MIL-STD-105. Where feasible, the same sample shall be used for the determination of two or more inspection characteristics. The unit of product for inspection purposes shall be one wire twister. Unless otherwise specified, sampling for examination shall be conducted at inspection level II, except for dimensions, which shall be conducted at inspection level S-1, and sampling for tests (when applicable) shall be conducted at inspection level S-1. For tests, the acceptance number shall be zero (0) for all sample sizes.

Examination. The wire twisters shall be examined for defects including, but not limited to, those listed below.

Defects

Style and design of wire twister not as specified.
Dimensions of wire twister not as specified.
Finish of wire twister not as specified.
Wire twister not free from cracks, pits, burs, sharp edges, scale, rough areas or corrosion.
Wire twister not free from dirt, oil, polishing compound, or foreign matter.
Identification markings not present, not complete, not correct or not legible.

Tests. Tests shall be conducted to determine compliance with specification requirements.

Contractor certification. The contractor shall certify that the product offered meets the salient characteristics of this description and conforms to the producer's own drawings, specifications, standards, and quality assurance practices. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

Metric products. Products manufactured to metric dimensions will be considered on an equal basis with those manufactured using inch/pounds units, providing they fall within the tolerances specified using conversion tables contained in the latest revision of Federal Standard No. 376, and all other requirements of this document are met. If a product is manufactured to metric dimensions and those dimensions exceed the tolerances specified in the inch/pound units, a request should be made to the contracting officer to determine if the product is acceptable. The contracting officer has the option of accepting or rejecting the product.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:27Z
Check the source to verify that this is the current version before use.

Regulatory requirements.

Federal Food, Drug and Cosmetic Act. If the product covered by this document has been determined by the U.S. Food and Drug Administration to be under its jurisdiction, the offeror/contractor shall comply, and be responsible for compliance by its subcontractors/suppliers, with the requirements of the Federal Food, Drug and Cosmetic Act, as amended, and regulations promulgated thereunder. In addition, the offeror/contractor shall comply, and be responsible for compliance by its subcontractors/suppliers, with the requirements of all other applicable Federal, State, and local statutes, ordinances, and regulations.

Recovered materials. The offeror/contractor is encouraged to use recovered material in accordance with Public Law 94-580, as amended, and as implemented by Federal Acquisition Regulation Subpart 23.4 to the maximum extent practical.

Preservation, packaging, packing, labeling, and marking. Unless otherwise specified, preservation, packaging and packing shall be to a degree of protection to preclude damage to containers and/or contents thereof under normal shipping conditions, handling, etc., involving shipment from the supply source to the receiving activity, plus reshipment from receiving activity, and shall conform to applicable carrier's rules and regulations. Intermediate and exterior package quantities and labeling and marking shall be as specified in the contract and/or order.

NOTE: The following National Stock Number is covered by this document:

National Stock Number	Item Identification
6520-01-164-9377	WIRE TWISTER, DENTAL, Blunt, 7 inch (17.8 cm) Long, 5/8 by 1/4 inch (16 by 6 mm) Jaws

Ordering data. Intermediate/exterior package quantities, labeling and marking must be as specified in the contract and/or order.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:27Z
Check the source to verify that this is the current version before use.

MILITARY INTERESTS:

Custodians:

Army-MD
Navy-MS
Air Force-03

PREPARING ACTIVITY:

DoD-MB

Agent:

DLA-DM

CIVIL AGENCY COORDINATING ACTIVITIES:

VA-OSS
PHS
FDA-MPQAS

PROJECT NO. 6520-2284
LOCATION: NCR DISK 2

53240

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:27Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE
A-A-53984	WIRE TWISTER, DENTAL, BLUNT

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
b. ADDRESS *(Street, City, State, ZIP Code)*	☐ USER
	☐ MANUFACTURER
	☐ OTHER *(Specify)*:

5. PROBLEM AREAS

a. Paragraph Number and Wording

b. Recommended Wording

c. Reason/Rationale for Recommendation

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:27Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS. In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

DEFENSE LOGISTICS AGENCY

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO 4966 WASHINGTON D C

POSTAGE WILL BE PAID BY THE DEFENSE LOGISTICS AGENCY

Commander
Defense Personnel Support Center
ATTN. DPSC- RSTE
2800 South 20th Street
Philadelphia, Pennsylvania 19101-8419

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:27Z
Check the source to verify that this is the current version before use.