INCH-POUND
A-A-52026
10 May 1991

COMMERCIAL ITEM DESCRIPTION

PUMPS, CENTRIFUGAL; SUMP, PNEUMATIC-MOTOR-DRIVEN, 210 GPM AT 25 FOOT TOTAL HEAD

The General Services Administration has authorized the use of this commercial item description in preference to Military specification MIL-P-556.

This item description covers lightweight pneumatic-motor-driven sump pumps of the following classes:

Class 1 - Regular
Class 2 - Nonsparking

Salient characteristics.

1. General. When specific requirements are not stated herein, all items listed as standard equipment in the manufacturers published specifications, brochures, and catalogs which are normally furnished to the commercial customer as standard equipment shall be furnished. In addition, the pumps shall be equipped with optional equipment and accessories as required to comply with the performance requirements specified herein. For the purpose of this item description, optional equipment may be defined as equipment not standard and not normally furnished with the pumps but which is available to the commercial customer on an optional basis. Any additional equipment or accessories needed to satisfy military requirements shall be specified in the contract or order. The additional equipment shall be constructed, assembled, and equipped with all components (whether or not specified herein) necessary to enable the unit to function reliably and efficiently in sustained operation. The pumps shall conform to all Federal laws and regulations applicable for this type equipment which are in effect on date of contract award.

Beneficial comments, recommendations, additions, deletions, clarifications, etc. and other data which may improve this document should be sent by letter to: Commander, US Army Belvoir Research, Development and Engineering Center, ATTN: STRBE-TSE, Fort Belvoir, VA 22060-5606.

AMC N/A FSC 4320

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:04Z
Check the source to verify that this is the current version before use.

2. Design and performance.

Pumps. The pumps shall be the volute centrifugal type. The pump and pneumatic motor shall be contained in a single housing or shall be contained in separate housings bolted together to form a single unit. All moving parts shall be enclosed. The suction inlet shall be located in the base of the pump and shall be provided with a strainer. The pump impeller shall be of the removable semi-open or enclosed-vane nonclogging type. The pumps shall operate in a dry sump for not less than 30 minutes without damage. The pumps shall deliver 210 GPM at 25 feet total head when pumping water. This capacity shall not cause the pneumatic motor to exceed the maximum allowable air consumption rate.

Class 1, regular. The class 1 sump pump shall pump water, sewage, and sludge when completely submerged. The weight of the pump unit shall not be more than 70 pounds.

Class 2, nonsparking. The class 2 sump pump shall pump hydrocarbons having specific gravities from 0.68 to 0.935, at a temperature from +40 to +80 °F. The weight of the pump unit shall not be more than 80 pounds. All parts of the pump in contact with the hydrocarbons shall be composed of non-sparking materials and certified for use with flammable liquids.

3. Pneumatic motor: The pneumatic motor shall be the rotary-vane type. Air consumption at 80 pounds per square inch gage (psig) shall not be more than 140 cubic feet per minute (cfm) when pumping at rated capacity. The no-load speed in revolutions per minute shall not exceed the air motor manufacturer's recommendations. The air inlet shall be equipped with a pipe-to-hose adapter and a 3/4-inch pneumatic hose coupling. The air inlet shall be internally threaded NPT and shall have a zinc-free removable 24-to-60 mesh strainer. The air exhaust shall be 1-1/4-inch internally threaded NPT and shall be provided with a 1-1/4 inch-NPSH pipe-to-hose adapter.

4. Material: The sump pumps shall be fabricated from compatible materials which are inherently corrosion resistant or treated to provide corrosion resistance to all applicable operating environments. Dissimilar metals shall not be used in intimate contact with each other unless protected against galvanic corrosion.

5. Safety. All rotating parts shall be guarded to prevent accidental contact by personnel. Guard devices shall not impair the operating function. External surfaces shall be free of sharp edges and corners except where necessary and not detrimental to safety.

6. Human factors engineering. The sump pump shall conform to accepted human factors engineering design criteria as specified in the applicable sections of MIL-STD-1472.

Contractor certification. The contractor shall certify and maintain substantiating evidence that the product offered meets the salient characteristics of this Commercial Item Description, and that the product conforms to the producer's own drawings, specifications, standards, and quality assurance practices. The Government reserves the

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:04Z
Check the source to verify that this is the current version before use.

right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

Regulatory requirements. In accordance with Federal Acquisition Regulation, section 23.403, the Government's policy is to acquire items composed of the highest percentage of recovered materials practicable, consistent with maintaining a satisfactory level of competition without adversely affecting performance requirements or exposing the supplier's employees to undue hazards from the recovered materials.

Preservation, packaging, packing, labeling, and marking: The preservation, packaging, packing, labeling, and marking shall be as specified in the contract or order.

Quality Assurance: The sump pumps shall be examined for the following defects. Presence of one or more defects shall be cause for rejection.

1. Optional/additional equipment or accessories not as specified in the contract or order.
2. Pump design not as specified.
3. Pump performance not as specified.
4. Pneumatic motor design not as specified.
5. Pneumatic motor performance not as specified.
6. Class not as specified in contract or order.
7. Material not corrosion resistant.
8. Dissimilar metals not protected against galvanic corrosion.
9. Safety not as specified.
10. Preservation, packaging, packing, labeling not as specified in the contract or order.

Notes: The procuring agency should specify the preferred options permitted herein and include the following information in procurement documents:

1. Title, number, and date of this item description.
2. Class of pump being procured.
3. What optional/additional equipment or accessories are needed to satisfy military requirements.
4. Level of preservation, packaging and packing required.
5. Any special marking.
6. When this commercial item description is used for certification clause must appear in the solicitation.

MIL-STD-1472 is available from the Standardization Documents Order Desk, Building 4D, 700 Robbins Avenue, Philadelphia, PA 19111-5094.

The following are suggested sources of supply (competition is not limited to these sources):

Superior Engineering and Electronics Company, Inc., 7380 Convoy Court, San Diego, CA 92111.
Tait-Toran, Inc., Fourin Corporation, 500 Wester Street, Dayton, OH 45404-1525.
Martin-Miser Associates, Inc., 17500 Redhill Avenue, Suite 170, Irvine, CA 92714.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:04Z
Check the source to verify that this is the current version before use.

Fluid Conditioning Products, Inc., Kleine and Warwick Streets, P.O. Box 407, Lititz, PA 17543-0407.
Ingersoll-Rand Company, Athens Plant, 101 N. Main Street, Athens, PA 18810-1707.

The preparing activity for this item description is the US Army Belvoir Research, Development, and Engineering Center, ATTN: STRBE-TSE, Ft. Belvoir, VA 22060-5606.

Custodian:
Army - ME
Air Force - 99

Review activity:
Air Force - 84

User activity:
Navy - MC

Preparing activity:
Army - ME

Project 4320-0325

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:04Z
Check the source to verify that this is the current version before use.