NOTICE: When Government drawings, specifications, or other data are used for any purpose other than in connection with a definitely related Government procurement operation, the United States Government thereby incurs no responsibility, nor any obligation whatsoever; and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

This military standard is approved by the Department of Defense and is mandatory on all activities. Selection for all new engineering and design applications and for repetitive use shall be made from this document.

FED SUP CLASS
4210



MS Part Number	FIIN	Container Data		Over-all Height Maximum
		Material	Cylinder Diameter Maximum	
			Inches	Inches
MS 39083 -1	251-790/	Steel Galvanized Finish	8½	27
MS 39083 -2		**	8½	27
MS 39083 -3 *	240-	Steel Galvanized Finish	8½	27

Extinguishing / ing action.
* The Standard F) with CHARGE, FIRE EXTINGUISHER, ANTIFREEZE.
** When the req rrosive construction, material for the tank and pump shall be fu th Specification FED-O-E-940

NOTES:
1. Materia as, inherent characteristics, and test for extinguishers shall pe I of Specification FED-O-E-940
2. This e over documents referenced herein.
3. Refe e the issue in effect on the date of invitation for bids.
4. Ill. otherwi. fication and is not intended to restrict designs which will fication requirements.

This document has bee. gated by the Department of Defense as the Military Standard to limit the selection of the em, product, or design covered herein in engineering, design and procurement. This standard shall become effective not later than 90 days after the latest date of approval shown.

APPROVED 16 APRIL 1959 REVISED (A) 15 SEPTEMBER 1959 (B) 14 AUGUST 1975

(B) CANCELLED AFTER 14 AUGUST 1975
USE O-E-940

P.A. CE Other Cust Docks ARDC	MILITARY STANDARD EXTINGUISHER, FIRE, WATER PUMP TYPE, HAND; 2½ GAL, CYLINDRICAL	MS 39083
PROCUREMENT SPECIFICATION FED-O-E-940.	SUPERSEDES:	SHEET 1 OF 1

DD FORM 1 OCT 52 672

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T17:45Z
Check the source to verify that this is the current version before use.