MIL-F-51213D(EA)
29 March 1988
SUPERSEDING
MIL-F-51213C(EA)
3 February 1982

MILITARY SPECIFICATION

FILTERS, GAS, (60, 120 AND 250 CFM MODULES), C10, C31 AND C21

This specification is approved for use within U.S. Army Chemical Research, Development and Engineering Center, Department of the Army, and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers three types of filter modules for protection from toxic gases in fixed installations.

1.2 Types. The gas filters shall be furnished in the following types as specified (see 6.2):

Type	Capacity
C10	60 cfm
C31	120 cfm
C21	250 cfm

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standards. The following specifications and standards form a part of this specification to the extent specified herein. Unless otherwise specified, the issues of these documents shall be those listed in the issue of the Department of Defense Index of Specifications and Standards (DODISS) and supplement therto, cited in the solicitation.

: Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed: to: Commander, U.S. Army Chemical Research, Development and Engineering Center, ATTN: SMCCR-SPT-S, Aberdeen Proving Ground, MD 21010-5423 by using: the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter. :

AMSC N/A FSC 4240

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T20:53Z
Check the source to verify that this is the current version before use.

SPECIFICATIONS

FEDERAL

BB-F-1421 - Fluorocarbon Refrigerants.

MILITARY

MIL-C-13724 - Charcoal, Activated, Impregnated, ASC.
MIL-F-46032 - Fungus - Resistant Treatment For Sandbags: Copper Processes.

STANDARDS

FEDERAL

FED-STD-191 - Textile Test Methods.

MILITARY

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-282 - Filter Units, Protective Clothing, Gas Mask Components and Related Products, Performance Test Methods.
MIL-STD-414 - Sampling Procedures and Tables for Inspection by Variables for Percent Defective.

2.1.2 Drawings. The following documents form a part of this specification to the extent specified herein. Unless otherwise specified, the issues shall be those in effect on the date of the solicitation.

U.S. ARMY ARMAMENT, MUNITIONS AND CHEMICAL COMMAND

CHEMICAL RESEARCH, DEVELOPMENT AND ENGINEERING CENTER

DRAWINGS

5-19-2014 - Filter, Gas, 250 CFM, C21.
5-19-2032 - Filter, Gas, 60 CFM, C10.
5-19-2069 - Filter, Gas, 120 CFM, C31.

(Copies of specifications, standards, and drawings required by contractors in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting activity.)

2.2 Other publications. The following document forms a part of this specification to the extent specified herein. Unless otherwise specified, the issues of the documents which are DOD adopted shall be those listed in the issue of

Source: https://assist.dla.mil -- Downloaded: 202640-22T20:53Z
Check the source to verify that this is the current version before use.

the DODISS specified in the solicitation. Unless otherwise specified, the issues of documents not listed in the DODISS shall be the issue of the nongovernment document which is current on the date of the solicitation.

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

ASTM D 2867 - Moisture in Activated Carbon.

(Application for copies should be addressed to ASTM, 1916 Race Street, Philadelphia, PA 19103.)

(Nongovernment standards and other publications are normally available from the organizations which prepare or which distribute the documents. These documents also may be available in or through libraries or other informational services.)

2.3 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein, the text of this specification shall take precedence. Nothing in this specification, however, shall supersede applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3.1 Materials and components.

3.1.1 Materials. All materials cited on the applicable top drawing (see 3.2) shall conform to the specifications listed therein or to the specific characteristics set forth on its subsidiary drawings.

3.1.2 Components. All components of the filter shall conform to the specifications and drawings listed for its applicable top drawing (see 3.2).

3.2 Manufacture and assembly. The filter shall be manufactured, assembled and marked in accordance with the applicable top drawing listed below (see 6.4). The perforated plate shall be properly aligned with the frame. A continuous bead of sealant shall cover the nail heads and the frame-perforated plate joint (see 6.9).

C10 - Drawing 5-19-2032
C31 - Drawing 5-19-2069
C21 - Drawing 5-19-2014

3.3 Airflow resistance. The airflow resistance of each cell of the filter shall be 1.0 $\pm$ 0.1 inch of water at an airflow rate of 60 cubic feet per minute (cfm) when tested as specified in 4.4.4.1.

3.4 Moisture content. The moisture content of the charcoal in the filter shall not exceed 2 percent by weight when tested in accordance with 4.4.4.3.

Source: https://assist.dla.mil -- Downloaded: 202610-22T20:53Z
Check the source to verify that this is the current version before use.

3.5 Leakage. Each cell of each filter module shall not leak when dichlorodifluoromethane (R-12) conforming to type 12 of BB-F-1421 is introduced at the influent side of the cell as specified in 4.4.4.2 at the following test parameters:

Airflow rate	12 ± 0.5 cfm
Airstream relative humidity	less than 30 percent
Airstream temperature	24 ± 3°C
R-12 influent concentration	1000 volume parts per million (Vppm)

A leak is defined as the detection of more than 1 Vppm at the effluent side of the filter within 2 minutes after the introduction of R-12.

3.6 Airflow resistance and dimethylmethylphosphonate (DMMP) gas life after rough handling. After the cell has been rough-handled in accordance with 4.4.4.6, the cell shall show no evidence of cracks, dents or charcoal granule leakage. The cell shall comply with airflow resistance requirements (3.3) and the DMMP gas life shall be no less then 35 minutes when tested in accordance with 4.4.4.4, at the following test parameters:

Airflow rate	60 ± 3 cfm
Airstream temperature	43 ± 3°C
DMMP influent concentration	5.0 ± 0.1 mg/L
DMMP break concentration	0.04 ug/L

The DMMP gas life is defined as the time from the introduction of DMMP at the influent side of the cell to the detection of the specified break concentration at the effluent side of the filter.

3.7 CK gas life of charcoal sorbent. After the completion of all manufacturing steps, the filter's charcoal shall comply with the cyanogen chloride (CK) gas sorption requirement of MIL-C-13724 for Grade IV unaged charcoal when tested in accordance with 4.4.4.5.

3.8 Preproduction. Prior to the start of regular production, a preproduction lot of filters shall be produced in accordance with this specification for examination and test (see 4.3).

3.9 Workmanship. The filters shall be free from foreign matter (dirt, grease, oily or viscous material) and damage, such as distorted or cracked frame, ripped or torn cloth.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the

Source: https://assist.dla.mil -- Downloaded: 202610-22T20:53Z
Check the source to verify that this is the current version before use.

right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to insure that supplies and services conform to prescribed requirements.

4.1.1 Responsibility for compliance. All items must meet all requirements of sections 3 and 5. The inspection set forth in this specification shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the specification shall not relieve the contractor of the responsibility of assuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling in quality conformance does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to acceptance of defective material.

4.1.2 Government responsibility. Unless otherwise specified, the Government will be responsible for performance of the tests specified in 4.4.4.4 and 4.4.4.5 for both preproduction and production.

4.1.3 Objective evidence. The contractor shall provide evidence acceptable to the contracting officer that the requirements of 3.1 and section 5 for which specific inspection has not been provided in this specification have been satisfied.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

(a) Preproduction inspection (see 4.3).
(b) Quality conformance inspection (see 4.4).

4.3 Preproduction inspection.

4.3.1 Preproduction lot. A preproduction lot of 52 C10 filter modules, 28 C31 filter modules, and 48 C21 filter modules shall be manufactured using the same methods, equipment, and processes as will be used during regular production (see 6.2).

4.3.2 Sampling.

4.3.2.1 For examination. Each cell of each filter module in the preproduction lot shall be inspected for compliance with the applicable drawings and the classification of defects.

4.3.2.2 For nondestructive tests.

(a) Airflow resistance. Each cell of each filter module in the preproduction lot shall be tested for airflow resistance.

(b) R-12 leakage. Each cell of each filter module in the preproduction lot shall be tested for R-12 leakage.

Source: https://assist.dla.mil -- Downloaded: 202610-22T20:53Z
Check the source to verify that this is the current version before use.

(c) Moisture content. A sample of charcoal sorbent shall be taken during the filling of four modules and placed in an open container. The samples shall experience the same conditions that their respective modules experience.

4.3.2.3 For destructive tests. Sampling for destructive tests shall be in accordance with table I.

TABLE I.

Module type	Sample modules required	DMMP gas life (cells per module)1/	CK gas life (cells per module)2/
C10	12	1	1
C31	8	2	1
C21	8	2	1

3/

NOTES: 1/ A total of eight cells will be tested for airflow resistance and DMMP gas life after rough handling for each type of module.
2/ A total of four cells will be tested for CK gas life of charcoal sorbent for each type of module.
3/ The cells being tested shall be diagonally opposite.

4.3.3 Inspection procedure.

4.3.3.1 For examination. Cells shall be examined for the defects listed in the classification of defects (4.4.3.4).

4.3.3.2 For nondestructive tests.

(a) Airflow resistance. Airflow resistance testing shall be performed in accordance with 4.4.4.1.

(b) R-12 leakage. R-12 leakage testing shall be performed in accordance with 4.4.4.2.

(c) Moisture content. Moisture content shall be determined in accordance with 4.4.4.3. The test shall be performed immediately before packaging the module.

4.3.3.3 For destructive tests.

(a) Airflow resistance and DMMP gas life after rough handling. After rough handling in accordance with 4.4.4.6, sample cells shall be tested for airflow resistance and DMMP gas life in accordance with 4.4.4.1 and 4.4.4.4.

Source: https://assist.dla.mil -- Downloaded: 202640-22T20:53Z
Check the source to verify that this is the currenversion before use.

(b) CK gas life of charcoal sorbent. Sample cells shall be tested in accordance with 4.4.4.5.

4.3.4 Acceptance/rejection criteria. The preproduction lot shall comply with all requirements of this specification when examined and tested in accordance with 4.3.3 to be acceptable. The contractor shall obtain written approval from the contracting officer prior to proceeding with regular production.

4.4 Quality conformance inspection.

4.4.1. Lotting. A lot shall consist of the gas filter modules of one type, produced by one manufacturer, at one plant, from the same materials, under essentially the same conditions. However, no more than 316 modules from one lot of charcoal shall be represented in any one lot of finished filter modules. The unit of product for DMMP and CK gas life testing shall be a cell.

4.4.2 Sampling.

4.4.2.1 For examination. Sampling shall be conducted in accordance with MIL-STD-105.

4.4.2.2 For nondestructive tests.

(a) Airflow resistance. Each cell of the filter module shall be tested for airflow resistance.

(b) R-12 leakage. Each cell of the filter module shall be tested for R-12 leakage.

(c) Moisture content. A sample of charcoal sorbent shall be taken during the filling of the first and last filter module manufactured each day and placed in an open container. The samples shall experience the same condition that their respective filters experience.

4.4.2.3 For destructive tests.

(a) Airflow resistance and DMMP gas life after rough handling. Sampling shall be performed in accordance with MIL-STD-414, level II, AQL 1.0%.

(b) CK gas life of charcoal sorbent. Sampling shall be four cells (from four separate modules) chosen randomly from each production lot.

4.4.3 Inspection procedure.

4.4.3.1 Examination. Sample filter modules shall be examined in accordance with the classification of defects and MIL-STD-105.

Source: https://assist.dla.mil -- Downloaded: 20261O-22T20:53Z
Check the source to verify that this is the current version before use.

4.4.3.2 For nondestructive tests.

(a) Airflow resistance. Each cell shall be tested for airflow resistance in accordance with 4.4.4.1. Any cell failing to meet the requirements of 3.3 shall be cause to reject its filter module.

(b) R-12 leakage. Each cell shall be tested for R-12 leakage in accordance with 4.4.4.2. Any cell failing to meet the requirements of 3.5 shall be cause to reject its filter module.

(c) Moisture content. Immediately before packaging of the filter module, the moisture content of the charcoal samples shall be determined in accordance with 4.4.4.3. If any sample fails to comply with the moisture content requirement 3.4, the filters represented by the sample shall be dried in accordance with 4.4.4.3(c).

4.4.3.3 For destructive tests.

(a) Airflow resistance and DMMP gas life after rough handling. Sample cells shall be tested for airflow resistance and DMMP gas life in accordance with 4.4.4.1 and 4.4.4.4. The production lot of filter modules shall be rejected if any cell fails to meet the requirements of 3.6.

(b) CK gas life of charcoal sorbent. Sample cells shall be tested for CK gas life in accordance with 4.4.4.5. The production lot of filter modules shall be rejected if any cell fails to meet the requirements of 3.7.

4.4.3.4 Classification of defects.

Filters, gas, 60, 120, 250 cfm (Drawing 5-19-2032, 5-19-2069 and 5-19-2014).

Categories	Defects	Acceptance standards
Critical:	None defined	
Major:	AQL 1.0 percent defective	
101	Component missing	
102	Component incorrectly assembled	
103	Overall dimensions incorrect	
104	Sealant incorrectly applied or missing	
105	Marking incorrect	
106	Workmanship (3.9)	
Minor:	AQL 2.5 percent defective	
201	Protective finish missing	
202	Marking illegible	

Source: https://assist.dla.mil -- Downloaded: 202610-22T20:53Z
Check the source to verify that this is the current version before use.

4.4.4 Tests. Tests shall be conducted as follows:

4.4.4.1 Airflow resistance. Determine the pressure drop across the filter at the rated airflow evenly distributed over the face of the filter. Keep the up and down stream static pressure measuring tubes as close as possible to the filter, and not on a section of duct having a changing cross sectional area.

4.4.4.2 Leakage. Test for leakage as follows:

(a) Position the filter rigidly in the vertical position. Connect the filter to a source of forced air having a mixing chamber at the influent side of the filter.

(b) Regulate the airflow to 12 ± 0.5 cfm.

(c) Introduce R-12 into the intake of the blower. Monitor and maintain a concentration of 1000 ppm by volume of R-12 in air at the specified test parameters for the specified period of time (see 3.5).

(d) Determine the leakage using a suitable leak detector (see 6.5) for sampling R-12 at the influent side of the filter.

(e) Purge the filter by passing fresh air in the reverse direction through the filter at its rated flow for 1 minute.

4.4.4.3 Moisture content. Test for moisture content as follows:

(a) The moisture content of the charcoal sorbent shall be determined in accordance with ASTM D 2867.

(b) If the moisture content of the charcoal sorbent samples does not comply with the requirements (3.4), the lot represented by the samples shall be unacceptable.

(c) Filters not meeting the moisture requirement may be dried at a temperature not to exceed 100°C. After drying, the first and last filter modules shall be disassembled and the moisture content of the charcoal sorbent from these filter modules shall be redetermined according to ASTM D 2867.

4.4.4.4 Dimethylmethylphosphonate (DMMP value) after rough handling. After the filter module has been rough handled in accordance with 4.4.4.6, determine its DMMP value as follows:

(a) Preheat sample filter to 120 ± 10°F for a minimum of 30 minutes.

(b) While in the bypass mode adjust the controls until rated airflow is reached and temperature is 110 ± 5°F. Generate the DMMP until the influent concentration detector (see 6.6) indicates 5.0 ± 0.1 milligrams DMMP per liter air.

Source: https://assist.dla.mil -- Downloaded: 202610-22T20:53Z
Check the source to verify that this is the current version before use.

(c) Insert preheated sample filter using applicable test fixture if necessary.

(d) Switch to test mode and start timer. Make final adjustments to airflow, temperature, and DMMP concentration.

(e) Stop the test and record the time when the effluent concentration detector (see 6.7) indicates a concentration of 0.04 microgram per liter air.

4.4.4.5 CK gas life of charcoal sorbent. The CK gas life shall be determined as follows:

(a) Disassemble each sample module and remove a charcoal specimen of 250 ± 5 mL from each sample module.

(b) Prepare four M11 canisters in accordance with MIL-C-13724 using the charcoal specimens. Care shall be taken not to mix the specimens from different modules.

(c) Test the four M11 canisters for CK gas life in accordance with MIL-C-13724.

4.4.4.6 Rough handling. Place the unpackaged filter on the vibrating machine in an upright position. Rough handle the filter in accordance with test method T105.10 of MIL-STD-282.

5. PACKAGING

5.1 Interplant shipment (see 6.8). The gas filter modules shall be packaged and packed to afford adequate protection from the supply source to the first receiving activity for immediate use or further processing (see 6.3). Shipping containers shall comply with the rules and regulations applicable to the mode of transportation. Marking shall be in accordance with FED-STD-123.

6. NOTES

6.1 Intended use. The gas filter modules covered by this specification are components of gas filters that are used for protecting fixed installations against toxic gases. The following is a list of the gas filter modules and their respective assemblies:

Type	Assembly
C10	Filter, Gas, 600 CFM, C22R1
C31	Filter, Gas, 1200 CFM, C32R1
C21	Filter, Gas, 2500 CFM, C29R1
C21	Filter, Gas, 5000 CFM, C23R1

Source: https://assist.dla.mil -- Downloaded: 202610-22T20:53Z
Check the source to verify that this is the current version before use.

6.2 Ordering data. Acquisition documents should specify the following:

(a) Title, number, and date of this specification.
(b) Type of gas filter module required (see 1.2).
(c) Preproduction:

(1) Time allowed for contractor to submit samples for Government test and evaluation after award of contract.
(2) Name and address of test facility and shipping instructions when testing is performed by the Government.
(3) Time required for the Government to notify the contractor whether or not to proceed with production.

6.3 Precautions. Precautions should be taken by the manufacturer to insure that modules are protected from moisture or foreign matter prior to their assembly into filters for shipment. Filter modules selected for R12 testing should be protected against moisture pickup since this may result in lower R12 values.

6.4 Manufacture. The following method of manufacture has been found to produce a satisfactory filter module. This procedure is furnished with the distinct understanding:

(a) That the contractor is not required to follow the method.
(b) That the provisions of the specification must be met regardless of the method of manufacture.
(c) That the Government makes no warranty that material made in accordance with this method will pass the specification requirements.

Filling sorbent filter modules.

(1) A filter module frame with the bottom perforated sheet, fines filter and draw-bolt assembly in position for filling should be placed in a suitable filling machine.

(2) A measured amount of properly screened sorbent should be fed gradually and uniformly from the three-foot height into each cell of the filter frame by means of the filling machine. The weight of sorbent required to properly fill one cell will vary according to its bulk density and moisture content. The required weight has been found to be approximately 16 pounds per cell. It is advisable to predetermine experimentally the required amount of sorbent to fill a cell. (A volumetric measure would vary considerably less than a weight measure). This is done by visual inspection of the mound made as described in paragraph (3) below and proved satisfactory by the R12 value of the filter cell tested in accordance with 4.4.4.3.

(3) After filling, the frame should be placed on a table, and the surface sorbent should be carefully brushed from the edges of each cell to about 2 inches from the outer edges so as to form bed levels 20 inches square, elevated 1/4 to 3/8 inch above the wood frame.

Source: https://assist.dla.mil -- Downloaded: 202640-22T20:53Z
Check the source to verify that this is the current version before use.

(4) A fines filter perforated sheet, cup washer gasket, and cup washer should be positioned on the draw bolt with the edges of each fines filter and perforated sheet properly aligned with the filter frame. The washers and nuts should be assembled to the draw bolts and tightened to a torque of 40 ± 5 inch-pounds. The edges of the perforated sheet should be clamped to the wooden frame with a suitable mechanical press. The perforated sheets shall then be nailed in place as specified on the applicable assembly drawing. The gas module should be vibrated for 1 minute while in the horizontal plane at a frequency of 200 cfm with a vertical amplitude of 3/4 inch.

(5) The assembly should be removed from the press and the draw bolt nuts tightened to a torque of 80 inch-pounds. (This is an approximate value only, the draw bolt may require a greater or lesser torque. The nuts should be tightened to the highest torque that will not cause splitting of the perforated sheets at the time of tightening or when the filter is rough handled.)

(6) The gas module shall then be vibrated as in (4) above.

(7) Steps (5) and (6) shall be repeated until the torque loss upon vibration is less than 10 percent.

(8) The assembly shall be completed as shown on the applicable assembly drawing.

6.5 Leak detector. The General Electric Company Type H-2 Halogen Leak Detector can be modified for use as a suitable leakage detector.

6.6 DMMP influent concentration detector. The Beckman L/B Infrared Analyzer, model 15a, has been found to be a suitable influent DMMP concentration detector.

6.7 DMMP effluent concentration detector. The Malloy Laboratories sulfur, phosphorous, and hydrocarbon analyzer, model no. SH 202 with the phosphorous filter has been found to be a suitable DMMP effluent concentration detector.

6.8 Interplant shipment. Interplant shipment is defined as packaging for supplies and materials which will not enter the military supply system. Typical examples are shipments from a vendor to a subcontractor or a prime contractor or from a subcontractor to a prime contractor or from a vendor or contractor to a military arsenal or plant.

6.9 Assembly. Dow-Corning RTV-732 or General Electric RTV 102 or 108 has been found a satisfactory sealant for this purpose.

6.10 International interest. Certain provisions of this specification are the subject of international standardization agreement QSTAG-214. When amendment, revision, or cancellation of this specification is proposed that will

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T20:53Z
Check the source to verify that this is the current version before use.

modify the international agreement concerned, the preparing activity will take appropriate action through international standardization channels including departmental standardization offices to change the agreement or make other appropriate accommodations.

6.11 Subject term (key word) listing.

Airflow resistance
Charcoal, activated
CK gas life
DMMP gas life
Filter, gas
R-12 leakage

6.12 Changes from previous issue. Asterisks are not used in this revision to identify changes with respect to the previous issue due to the extensiveness of the changes.

Custodian:

Army - EA

Preparing activity:

Army - EA

Project No. 4240-A925

☆U.S. GOVERNMENT PRINTING OFFICE: 1988 - 505-033/91233

Source: https://assist.dla.mil -- Downloaded: 202610-22T20:53Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO. 4966 Alexandria, VA

POSTAGE WILL BE PAID BY

Commander
U.S. Army Chemical Research, Development
and Engineering Center
ATTN: SMCCR-SPT-S
Aberdeen Proving Ground, MD 21010-5423

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T20:53Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE
MIL-F-51213D(EA)	FILTERS, GAS, (60, 120 AND 250 CFM MODULES), C10, C31 AND C21

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR ☐ USER ☐ MANUFACTURER ☐ OTHER *(Specify)*: _____
b. ADDRESS *(Street, City, State, ZIP Code)*	

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE.

(TO DETACH THIS FORM, CUT ALONG THIS LINE.)

Source: https://assist.dla.mil -- Downloaded: 202610-22T20:53Z
Check the source to verify that this is the current version before use.