MILITARY SPECIFICATION

FUEL MONITORS: FRAME MOUNTED, 100- AND 350-GALLON PER MINUTE CAPACITIES

This specification is approved for use by U. S. Marine Corps, Department of the Navy, and is available for use by all Departments and Agencies of the Department of Defense

1. SCOPE

1.1 Scope. This specification covers requirements for fuel monitors for use downstream of 100 gallon per minute (gal/min) and 350 gal/min filter-separators.

1.2 Classification. Fuel monitors covered by this specification shall be of the following types, as specified (see 6.2):

Type I - 100-gal/min Capacity

Type II - 350-gal/min Capacity

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standards. Unless otherwise specified, the following specifications and standards of the issue listed in that issue of the Department of Defense Index of Specifications and Standards (DODISS) specified in the solicitation, form a part of this specification to the extent specified herein.

SPECIFICATIONS

FEDERAL

L-P-378	-	Plastic Sheet and Strip, Thin Gauge, Polyolefin.
QQ-P-416	-	Plating, Cadmium (Electrodeposited).
QQ-Z-325	-	Zinc Coating, Electrodeposited, Requirements for.
PPP-B-601	-	Boxes, Wood, Cleated-Plywood
PPP-B-636	-	Boxes, Shipping, Fiberboard.

Benefical comments (recommendations, additions, deletions), and any pertinent data which may be of use in improving this document, should be addressed to Commandant of the Marine Corps, Headquarters Marine Corps (Code LMA-1), Washington, DC 20380, by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426), appearing at the end of this document, or by letter.

Source: https://assist.dla.mil -- Downloaded: 202610-23T06:50Z
Check the source to verify that this is the current version before use.

MILITARY

MIL-T-704	-	Treatment and Painting of Materiel.
MIL-C-5541	-	Chemical Conversion Coatings on Aluminum and Aluminum Alloys.
MIL-A-8625	-	Anodic Coatings, for Aluminum and Aluminum Alloys.
MIL-T-22085	-	Tape, Adhesive, Preservation and Sealing.
MIL-W-22248	-	Weldments, Aluminum and Alluminum Alloy.
MIL-E-52798	-	Enamel, Alkyd, Camouflage.
MIL-M-81380	-	Monitor, Contamination, Fuel Dispensing Systems.

STANDARDS

FEDERAL

FED-STD-H28	-	Screw-Thread Standards for Federal Services.

MILITARY

MIL-STD-105	-	Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129	-	Marking for Shipment and Storage.
MIL-STD-130	-	Identification Marking of U.S. Military Property.
MIL-STD-810	-	Environmental Test Methods.
MIL-STD-889	-	Dissimilar Metals.
MIL-STD-1188	-	Commercial Packaging of Supplies and Equipment.
MIL-STD-1472	-	Human Engineering Design Criteria for Military Systems, Equipment and Facilities.

2.1.2 Other Government documents, drawings, and publications. The following other Government documents, drawings, and publications form a part of this specification to the extent specified herein.

DRAWINGS

MARINE CORPS

DL805016A0000	-	Fuel Monitor Assy, Frame Mounted, 100 gal/min.
DL805017A0000	-	Fuel Monitor Assy, Frame Mounted, 350 gal/min.

(Copies of specifications, standards, and drawings required by manufacturers in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting officer.)

2.1.3 Order of precedence. In the event of a conflict between the text of this specification and the reference cited herein, the text of this specification shall take precedence.

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. The issues of the documents which are indicated as DoD adopted shall be the issue listed in the current DODISS and the supplement thereto, if applicable.

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T06:50Z
Check the source to verify that this is the current version before use.

ALUMINUM ASSOCIATION (AA)

Aluminum Construction Manual, Section 1, Specifications for Aluminum Structures, 7.2 Welding Fabrication.

(Application for copies should be addressed to the Aluminum Association, 420 Lexington Avenue, New York, NY 10017.)

AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)

Boiler and Pressure Vessel Code, Section IX, Welding and Brazing Qualifications.

(Application for copies should be addressed to the American Society of Mechanical Engineers, 345 East 47th Street, New York, NY 10017.)

AMERICAN WELDING SOCIETY, INC. (AWS)

D.1.1- Structural Welding Code, Section 5, Qualification.

(Application for copies should be addressed to the American Welding Society, Inc., 2501 NW Seventh Street, Miami, FL 33125.)

(Industry association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

3. REQUIREMENTS

3.1 First article. When specified (see 6.2), a sample shall be subjected to first article inspection as soon as practicable after award of contract or order and prior to starting regular production. The contractor shall furnish a fuel monitor for examination and test within the time frame specified (see 6.2), to prove, prior to starting production, that production methods will produce fuel monitors that comply with the requirements of this specification. The first article shall be representative of the construction, workmanship, components and materials to be used during production. When the contractor is in continuous production of the fuel monitors from contract to contract, submission of further first articles on the new contract may be waived at the discretion of the acquiring activity.

3.2 Materials. Materials shall be as specified herein and as shown on Drawing Nos. DL805015A0000 and DL805017A0000. Materials used shall be free from defects which would adversely affect the performance or maintainability of individual components or of the overall assembly. Materials not specified herein shall be of the same quality used for the intended purpose in commercial practice. Unless otherwise specified herein, all equipment, material, and articles incorporated in the work covered by this specification are to be new and fabricated using materials produced from recovered materials to the maximum extent possible without jeopardizing the intended end use of the item. The term "recovered materials" means materials which have been collected or recovered from solid waste and reprocessed to become a source of raw materials, as opposed to virgin raw materials.

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T06:50Z
Check the source to verify that this is the current version before use.

3.2.1 Housing. The fuel monitor housings shall be fabricated of aluminum-alloy as specified on Drawing Nos. DL805015A0000 and DL805017A0000. The type I and type II housings shall withstand a hydrostatic pressure of 225 pounds-force per square inch (psi) without leakage, permanent deformation, or other defects that could harmfully affect the performance and serviceability of the fuel monitors.

3.2.2 Deckplate. The deckplates for the type I and type II housings shall be fabricated of aluminum-alloy of the thickness specified on Drawing Nos. DL805016A0000 and DL805017A0000. The deckplates shall withstand a hydrostatic pressure of 225 psi without leakage, permanent deformation, or other defects that could harmfully affect the performance and serviceability of the fuel monitors.

3.2.3 Hardware. Bolts, nuts and washers shall be fabricated from materials as specified on Drawing Nos. DL805016A0000 and DL805017A0000. When ferrous materials are specified, the bolts, nuts, and washers shall be cadmium plated in accordance with QQ-P-416, type III, class 2 or zinc coated in accordance with QQ-Z-325, type III, class 3. Threads shall conform to FED-STD-H28, Sections 2, 7, 8, or 21, as applicable.

3.3 Design. The type I and type II fuel monitors shall be in accordance with Drawing Nos. DL805016A0000 and DL805017A0000 and as specified herein. The fuel monitors shall consist essentially of a horizontal aluminum housing with a removable flat cover, a manually operated air vent, inlet and outlet connections, fuel contaminant monitoring elements, and a differential pressure gage. The general requirements and operating conditions shall be in accordance with MIL-M-81380. The type I fuel monitor shall have a rated flow of 100 gal/min and a maximum working pressure of 150 psi. The type II fuel monitor shall have a rated flow of 350 gal/min and a maximum working pressure of 150 psi.

3.3.1 Fuel contaminant monitoring elements.

3.3.1.1 Type I. The type I fuel monitor shall be in accordance with DL805016A0000 and as specified herein. The type I fuel monitor requires eight elements conforming to MIL-M-81380. A total of sixteen elements shall be overpacked with each fuel monitor, eight to be used for the initial fillup and eight as replacements.

3.3.1.2 Type II. The type II fuel monitor shall be in accordance with DL805017A0000 and as specified herein. The type II fuel monitor requires wenty elements conforming to MIL-M-81380. A total of forty elements shall be overpacked with each fuel monitor, twenty to be used for the initial fillup and twenty as replacements.

3.3.2 Differential pressure dial gage. The differential pressure gage shall conform to the dimensions shown and the requirements specified on Drawing No. 805015A0003. The gage shall provide direct reading of the differential pressure across the fuel monitor and shall perform without structural failure or leakage. The accuracy of the gage shall be such that any error shall not exceed ±2 psi.

Source: https://assist.dla.mil -- Downloaded: 202610-23T06:50Z
Check the source to verify that this is the currentversion before use.

3.3.3 Gasket replacement. One extra coupling gasket shall be furnished with each fuel monitor as a replacement item as specified on Drawing Nos. DL805016A0000 and DL 805017A0000.

3.4 Construction.

3.4.1 Welders. Before assigning any welder to manual welding work covered by this specification, the contractor shall provide the contracting officer with certification that the welder has passed qualification tests as prescribed by the following listed codes for the type of welding operations to be performed and that such qualification is effective as defined by the following codes:

Welding Qualification of the ASME, Boiler and Pressure Vessel Code, Section IX.

AWS D1.1, Structural Welding Code, Section 5, Qualification.

AA, Aluminum Construction Manual, Section 1, for Specifications for Aluminum Structures, 7.2 Welding Fabrication.

3.4.2 Welding (aluminum). Welding performed in the fabrication of fuel monitors shall be in accordance with MIL-W-22248. Classes of welds shall be as specified on Drawing Nos. DL805016A0000 and DL 805017A0000. Welds shall transmit stress without permanent deformation or failure when the parts connected by the welds are subjected to proof and service loading.

3.5 Maintainability. Each component, part, and fitting of the monitor assembly shall be accessible for maintenance, repair, and replacement without the removal of other components, parts, and fittings or interference from the frame assembly.

3.6 Transportability. The fuel monitors shall withstand the dynamic vibrational stresses encountered in transportation and service. The fuel monitors shall operate as specified herein when tested as specified in 4.6.4.

3.7 Human factors. The fuel monitors shall conform to the applicable human factors engineering criteria as specified in MIL-STD-1472.

3.8 Performance.

3.8.1 Operating temperatures. The fuel monitors shall permit rated flow in any ambient temperature in the range of +125°F to -25°F(+52°C to -32°C) (see 4.6.2).

3.8.2 Storage temperatures. The fuel monitors shall not be damaged by storage at ambient temperatures from +160°F to -50°F (+71°C to -46°C) (see 4.6.2).

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T06:50Z
Check the source to verify that this is the current version before use.

3.9 Finish.

3.9.1 Treatment and painting. The exterior of the fuel monitors normally painted shall be cleaned, treated, and painted in accordance with MIL-T-704, type B. The color of the finish paint shall be forest green in accordance with MIL-E-52798.

3.9.2 Chemical coating. The interior of the fuel monitor housings and all components fabricated from aluminum alloy which are in direct contact with the petroleum fuels, shall be anodized in accordance with MIL-A-8625, type II, class 1, or coated in accordance with MIL-C-5541, class 1A.

3.9.3 Dissimilar metals. The use of dissimilar metals in intimate contact with each other shall be avoided wherever possible. When the use of dissimilar metals cannot be avoided, an interposing material which will eliminate or minimize galvanic corrosion shall be used. Dissimilar metals shall be defined in MIL-STD-889. All metal surfaces shall be treated and finished in accordance with MIL-T-704, type B.

3.10 Identification marking. Each fuel monitor shall be identified in accordance with MIL-STD-130. The identification, instruction, and warning plates and markings shall be in accordance with Drawing Nos. 805016A0006 through 805016A0010.

3.11 Workmanship. The fuel monitors shall be free from defects such as misaligned components, incomplete welds, cracks, burns, leaks, and other defects that could impair operation and serviceability. All parts shall be clean and free from dirt, sand, grease, oil and metal chips. Nonfunctional sharp edges and projecting points, which might present a hazard to personnel, shall be avoided.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Component and material inspection. The contractor is responsible for insuring that components and materials used are manufactured, examined, and tested in accordance with referenced specifications and standards.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T06:50Z
Check the source to verify that this is the current version before use.

a. First article inspection (see 4.3).

b. Quality conformance inspection (see 4.4)

c. Inspection of packaging (see 4.7).

4.3 First article inspection. Examination and tests shall be as follows and, unless otherwise specified herein, all examinations and tests shall be conducted by the contractor subject to surveillance and approval by the Government (see 6.2). Approval of the first article does not preclude the requirements for performing the quality conformance inspections.

4.3.1 Examination. The first article shall be examined as specified in 4.5.1. Presence of one or more major defects shall be cause for rejection.

4.3.2 Tests. The first article shall be subjected to tests specified in 4.6.1 through 4.6.5. Failure of any test shall be cause for rejection or shall be cause for performing the inspection specified in 4.3.3.

4.3.3 Disassembly inspection. Failure of a performance test by the first article fuel monitors shall require disassembly of the fuel monitors in the presence of a Government representative. Each disassembled part shall be inspected in detail for compliance with this specification and referenced drawings in regard to materials, dimensions, tolerances, and workmanship. Parts not complying with such requirements shall be rejected.

4.4 Quality conformance inspection.

4.4.1 Sampling. Sampling for examination shall be as specified in MIL-STD-105, inspection level II.

4.4.2 Examination. Samples selected as specified in 4.4.1 shall be examined for the major and minor defects specified in 4.5. Acceptable quality level (AQL) shall be 2.5 percent defective for major defects and 4.0 percent defective for minor defects.

4.4.3 Tests. Each fuel monitor shall be subjected to tests specified in 4.6.1 and 4.6.5. Failure of either test shall be cause for rejection.

4.5 Visual examination. Fuel monitors shall be examined as specified herein for the following defects:

Major.

101. Dimensions not as specified (see 3.3).
102. Materials not as specified (see 3.2).
103. Hardware such as bolts, nuts, washers, and screw threads not as specified (see 3.2.3).
104. Aluminum parts and components not coated as specified (see 3.9.2).
105. Weldings and castings not as specified (see 3.4.2).
106. Fuel monitors not cleaned and air-dried after testing (see 4.6.6).

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T06:50Z
Check the source to verify that this is the current version before use.

107. Elements and gaskets not as specified (see 3.3.1 and 3.3.3).
108. Workmanship not as specified (see 3.11).

Minor.

201. Identification marking incorrect, illegible or missing (see 3.10).
202. Instruction plates not as specified (see 3.10).
203. Treatment and painting not as specified (see 3.9.1).)

4.6 Tests

4.6.1 Hydrostatic pressure test. The fuel monitor shall be subjected to the hydrostatic pressure test specified in MIL-M-81380. Nonconformance to requirements specified in 3.2.1 and 3.2.2 or to the applicable requirements of MIL-M-81380 shall constitute failure of this test.

4.6.2 Temperature. Temperature tests shall be conducted as follows:

4.6.2.1 High temperature. The fuel monitors shall be tested as specified in MIL-STD-810, Method 501.1, Procedure I (see 4.6.2.2). The maximum test temperature for storage shall be +160°F (+71°C) and the maximum operating temperature shall be +125°F (+52°C). The operating period of Procedure I shall be 1 hour, or the operating time required to check for any component failure due to high temperatures whichever is greater.

4.6.2.2 Low temperature. The fuel monitors shall be tested as specified in MIL-STD-810, Method 502.1, Procedure I. The minimum test temperature for storage shall be -50°F(-46°C) and minimum operating temperature shall be -25°F (-32°C). The operating period of Procedure I shall be 1 hour, or the operating time required to check for any component failure due to low temperatures, whichever is greater. Nonconformance to 3.6 or to the applicable requirements of MIL-STD-810 shall constitute failure of either temperature test.

4.6.3 Human factors. The fuel monitors shall be evaluated to determine conformance to 3.7. Nonconformance to 3.7 shall constitute failure of this test.

4.6.4 Transportability. The fuel monitors, in their shipping containers, shall be transported by a 2-1/2-ton cargo truck cross-country at an average speed of 15 miles per hour for a total of 100 miles. Damage to the fuel monitors or components or nonconformance to 3.6 shall constitute failure of this test.

4.6.5 Differential pressure dial gage. Subject the gage to a hydrostatic pressure equal to the maximum scale pressure, and hold at this pressure for a minimum of 30 minutes. Within 10 minutes after the pressure is released and without recalibration or adjustment, readings shall be taken at three intervals on the scale; the anticipated initial operating pressure, the pressure at which the elements are changed, and the maximum scale pressure. The gage shall be tapped sharply with the finger at approximately the center

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T06:50Z
Check the source to verify that this is the current version before use.

of the scale area before each reading. A dead weight tester or mercury manometer with air pressure or calibrated check gage shall be used in calibrating the gage. Testing of the gage shall be in a temperature range of +68°F or -10°F (+20°C or -5.6°C). Nonconformance to 3.3.2 shall constitute failure of this test.

4.6.6 Cleaning and drying after tests. After conclusion of all tests, and after removal of the elements, each fuel monitor shall be wiped clean and air-dried at room temperature to exhaust all traces of fuel and water.

4.7 Inspection of packaging.

4.7.1 Unit of product. For the purpose of inspection, a completed pack prepared for shipment shall be considered a unit of product.

4.7.2 Sampling. Sampling for examination shall be as specified in MIL-STD-105.

4.7.3 Examination. Samples selected as specified in 4.7.2 shall be examined for the following major defects. AQL shall be 2.5 percent defective for major defects.

101. Materials and containers not as specified for level A or commercial. Each incorrect material or container shall be considered one defect.
102. Air vent valve not opened as specified for level A or commercial.
103. Dust plug and dust cap not installed.
104. Elements not protected as specified for level A or commercial.
105. Extra coupling gasket not protected as specified for level A or commercial.
106. Contents not blocked and braced within the box to prevent movement or damage for level A or commercial.
107. Marking missing, illegible, incorrect, or incomplete for level A or commercial.

5. PACKAGING

5.1 Preservation. Preservation shall be level A or commercial as specified (see 6.2).

5.1.1 Level A.

5.1.1.1 Fuel monitor. The fuel monitor shall be dry and clean and shall not require preservation for packaging. The air vent valve shall be opened; all other openings shall be closed. The ground rod and cable shall be secured to the frame with tape in a manner to assure minimum cubage as specified in MIL-T-22085, type II.

5.1.1.1.1 Fuel contaminant monitoring element. Each element shall be inserted into a polyethylene bag fabricated as specified in L-P-378, type I,

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T06:50Z
Check the source to verify that this is the current version before use.

class 1, grade and finish options, thickness 0.0040, and closed by heat sealing. The bag containing the element shall be placed in a close fitting box conforming to PPP-B-636, W6c, style optional. Box closure shall be as specified in the appendix to the box specification.

5.1.1.1.2 Extra coupling gasket. The extra coupling gasket shall be laid flat between two pieces of fiberboard. The fiberboard shall be slightly larger than the gasket. The gasket and fiberboard shall then be inserted into a close fitting polyethylene bag and sealed as specified in 5.1.1.1.1.

5.1.2 Commercial. The fuel monitor, with required components, shall be preserved as specified in MIL-STD-1188.

5.2 Packing. Packing shall be level A or commercial as specified (see 6.2). Exterior container (see 5.2.1 and 5.2.2) shall be of a minimum tare and cube consistent with the protection required and shall contain the required quantities of elements and coupling gasket.

5.2.1 Level A. Each complete fuel monitor with required elements and coupling gasket shall be packed in a close fitting box conforming to PPP-B-601, overseas type, style optional. The contents shall be blocked and braced within the box to prevent movement or damage. Box closure and strapping shall be as specified in the appendix to the box specification.

5.2.2 Commercial. Each complete fuel monitor with required elements and coupling gasket shall be packed as specified in MIL-STD-1188.

5.3 Marking.

5.3.1 Level A. In addition to any special or other identification markings required by the contract, each unit pack, intermediate and exterior container and unitized load shall be marked as specified in MIL-STD-129.

5.3.2 Commercial. Commercial marking shall be as specified in the requirements of MIL-STD-1188.

6. NOTES

6.1 Intended use. The fuel monitors are intended for use downstream of filter separators of comparable flow rates to interrupt the flow of contaminated fuel. The type I fuel monitor is intended for use in the Helicopter Expedient Refueling System (HERS) and the Fuels Storage Transporting and Handling System (SIXCON). The type II fuel monitor is intended for use in the Tactical Airfield Fuel Dispensing System (TAFDS) and the Amphibious Assault Fuel System (AAFS).

6.2 Ordering data.

6.2.1 Acquisition requirements. Acquisition documents should specify the following:

a. Title, number and date of this specification.
b. Type fuel monitor required (see 1.2).

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T06:50Z
Check the source to verify that this is the current version before use.

c. Time frame required for submission of first article sample(s) (see 3.1).

d. When first article is required for inspection and approval (see 3.1).

e. When temperature tests are required (see 4.5.2.2).
f. Levels of preservation and packing required (see 5.1 and 5.2).

6.2.2 Data requirements. When this specification is used in an acquisition which incorporates a DD Form 1423, Contract Data Requirements List (CDRL) the data requirements identified below shall be developed as specified by an approved Data Item Description (DD Form 1664) and delivered in accordance with the approved CDRL incorporated into the contract. When the provisions of DAR 7-104.9 (n) (2) are invoked and the DD Form 1423 is not used, the data specified below shall be delivered by the contractor in accordance with the contract or purchase order requirements. Deliverable data required by this specification is cited in the following paragraphs.

Paragraph no.	Data requirements	Applicable DID no.	Options
4.3	First Article Inspection Procedures	DI-T-4901	-
4.3	First Article Inspection Report	DI-T-4902	-

(Copies of DID's required by contractors in connection with specific acquisition functions should be obtained from the Naval Publications and Forms Center or as directed by the contracting officer.)

6.3 First article. Any changes or deviations of production fuel monitors from the approved first article during production will be subject to the approval of the contracting officer. Approval of the first article will not relieve the contractor of his obligation to furnish fuel monitors conforming to this specification.

6.4 Changes from previous issue. Asterisks are not used in this revision to identify changes with respect to the previous issue, due to the extensiveness of the changes.

Preparing activity:
Navy - MC
Project No. 4930-N233

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T06:50Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

OMB Approval
No. 22-R255

INSTRUCTIONS: The purpose of this form is to solicit beneficial comments which will help achieve procurement of suitable products at reasonable cost and minimum delay, or will otherwise enhance use of the document. DoD contractors, government activities, or manufacturers/vendors who are prospective suppliers of the product are invited to submit comments to the government. Fold on lines on reverse side, staple in corner, and send to preparing activity. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements. Attach any pertinent data which may be of use in improving this document. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity.

DOCUMENT IDENTIFIER AND TITLE

MIL-F-82165B(MC), FUEL MONITORS: FRAME MOUNTED, 100- AND 350-Gal., etc.

NAME OF ORGANIZATION AND ADDRESS

CONTRACT NUMBER

MATERIAL PROCURED UNDER A

☐ DIRECT GOVERNMENT CONTRACT ☐ SUBCONTRACT

1. HAS ANY PART OF THE DOCUMENT CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?

A. GIVE PARAGRAPH NUMBER AND WORDING.

B. RECOMMENDATIONS FOR CORRECTING THE DEFICIENCIES

2. COMMENTS ON ANY DOCUMENT REQUIREMENT CONSIDERED TOO RIGID

3. IS THE DOCUMENT RESTRICTIVE?

☐ YES ☐ NO *(If "Yes", in what way?)*

4. REMARKS

SUBMITTED BY *(Printed or typed name and address - Optional)*

TELEPHONE NO.

DATE

DD FORM 1 JAN 72 1426

REPLACES EDITION OF 1 JAN 66 WHICH MAY BE USED

S/N 0102-LF-014-1802

Source: https://assist.dla.mil -- Downloaded: 202640-23T06:50Z
Check the source to verify that this is the current version before use.

FOLD

DEPARTMENT OF THE NAVY
Headquarters, U.S. Marine Corps
Washington, DC 20380

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

POSTAGE AND FEES PAID
DEPARTMENT OF THE NAVY
DOD-317

U.S.MAIL

COMMANDANT OF THE MARINE CORPS
HEADQUARTERS, U.S. MARINE CORPS
(CODE LMA-1)
WASHINGTON, D.C. 20380

FOLD

Source: https://assist.dla.mil -- Downloaded: 202610-23T06:50Z
Check the source to verify that this is the current version before use.