MIL-A-52670A
AMENDMENT 1
22 August 1983

MILITARY SPECIFICATION

AIR-CONDITIONING COMPONENT: FAN-COIL ROOM UNITS

This amendment forms a part of Military Specification MIL-A-52670A, dated 29 October 1982, and is approved for use by all Departments and Agencies of the Department of Defense.

PAGE 4

Paragraph 3.8.2, delete first sentence and substitute: "Fans and scrolls shall be galvanized steel or aluminum. Nonmetallic materials of suitable reinforced compounds may be used for the fans and scrolls except when prohibited by UL 883."

Custodians:

Army - ME
Navy - YD

Preparing Activity:

Navy - YD

Project No. 4130-0276

FSC 4130

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:29Z
Check the source to verify that this is the current version before use.