A-A-1279A
May 13, 1981
SUPERSEDING
A-A-1279
May 22, 1980

COMMERCIAL ITEM DESCRIPTION

# CHARGER, BATTERY
# (FOR KR142/XXX, KR257/XXX, KR334/XXX, AND 1604NC BATTERIES)

The General Services Administration has authorized the use of this commercial item description.

This commercial item description covers battery chargers for KR142/XXX (NEDA 15NC), KR257/XXX (NEDA 14NC), KR334/XXX (NEDA 13NC or 16NCD) and NEDA 1604NC nickel-cadmium secondary batteries.

Salient characteristics:

These characteristics concisely describe the essential physical and functional/performance characteristics of the commercially available item.

Solid state circuitry.
Reverse polarity protection for batteries.
Chargers shall provide average rated capacity in 16 hours at 25°C for batteries discharged to 0.9V or 5.4V (1604NC).
Listing mark in accordance with Underwriters Laboratories Standard No. 1236.

Table I. Sizes of Chargers

| Type | Unit | Batteries |
|---|---|---|
| A | Modular | Class 1 - KR334/XXX (NEDA 13NC) Adapter with two batteries<br>Class 2 - KR257/XXX (NEDA 14NC) Adapter with two batteries<br>Class 3 - KR142/XXX (NEDA 15NC) Adapter with two batteries<br>Class 4 - NEDA 1604NC Adapter with one battery or one 1604NC battery attached to charging module.<br>Class 5 - Charging module for adapters. |
| B | Combination | Charges 2 or 4 KR142/XXX (NEDA 15NC), KR257/XXX (NEDA 14NC) or KR334/XXX (NEDA 13NC) or may charge 1 or 2 1604NC batteries. |
| C | Multi-unit | 48 position charger for KR257/XXX batteries (NEDA 14NC). |
| D | Multi-unit | 48 position charger for Type 1 KR334/XXX batteries (NEDA 13NC). |
| E | Multi-unit | 48 position charger for Type 2 (H.D.) KR334/XXX batteries (NEDA 16NCD). |

The issue of UL Standard 1236 in effect on the date of the solicitation shall be used to determine compliance with this requirement.

Certification. The contractor shall certify that the product offered meets the salient characteristics of this description, and that the product conforms to the producer's own drawings, specifications, standards, and quality assurance practices, and is the same product sold in the commercial marketplace. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

Regulatory requirements. The manufacturer shall utilize recovered materials to the maximum extent practicable.

FSC 6130

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:12Z
Check the source to verify that this is the current version before use.

Packaging, packing, and marking. The items shall be packaged in accordance with normal commercial practice and packed to assure acceptance by common carrier and provide product protection against loss and damage during multiple shipments, handling, and storage. The shipping container shall be in compliance with the National Motor Freight Classification and Uniform Freight Classification. Shipping containers shall be marked as specified in the contract or order.

UL Standard No. 1236 is available from Underwriters Laboratories, Inc., Publications Stock, 333 Pfingsten Road, Northbridge, IL 60062.

NEDA Battery indexes are available from National Electronic Distributors Association, 1480 Renaissance Drive, Suite 214, Park Ridge, IL 60068.

MILITARY INTERESTS:

Custodian:

Air Force - 99

Preparing activity:

GSA-FSS



GSA DC-01104121

Source: https://assist.dla.mil -- Downloaded: 202610-26T08:12Z
Check the source to verify that this is the current version before use.