INTERIM AMENDMENT

TO

FEDERAL SPECIFICATION

FIXTURE, LIGHTING (FLUORESCENT, ALTERNATING CURRENT, RECESSED AND SURFACE CEILING)

This interim amendment was developed by the General Services Administration, Federal Supply Service, Washington, DC 20405, based upon currently available technical information. It is recommended that Federal agencies use it in procurement, and forward recommendations for changes to the preparing activity at the address shown above.

The General Services Administration has authorized Federal agencies to use this interim amendment as a part of Federal Specificaton W-F-1662A, dated July 1, 1974.

PAGE 3

Under "Federal Standards:", delete the reference to "Fed. Test Method Std. No. 151" in its entirety and replace with:

"Fed. Test Method Std. No. 141 - Paint, Varnish, Lacquer, and related materials; Methods of Inspection, Sampling, and Testing."

PAGE 4

Under the heading "American Society for Testing and Materials (ASTM) Standards:," add the following reference:

"No. B 117 - Standard Method of Salt Spray (Fog) Testing."

PAGE 9

Paragraph 3.4.4.1, delete in its entirety and substitute the following:

"3.4.4.1 Class I, II and IV. Class I, II, and IV luminaires shall have flat bottom closures of the lens type, with lens being self supporting and of one piece construction. Bottom closures shall be either flush with or regressed into bottom of fixture housing. The lens of bottom closure shall be of plastic or glass and shall have a uniform overall pattern of prisms or spherical segments on either one or both sides. Side panels, if provided on Class IV luminaires, shall also be of the lens type and constructed of plastic or glass. All plastic lenses shall be of acrylic, meeting ASTM D-788 requirements (see 3.8). Glass side panels and size 1 and 2 luminaire glass lenses may be tempered or annealed, unless tempered glass only is specified. If tempered glass only is desired, the specificaton user shall so indicate (see 6.1). On size 4 luminaires, glass bottom closure lenses shall be tempered. The overall cross sectional thickness of plastic side panels and size 1 and 2 luminaire plastic bottom closure lenses shall be a nominal 0.125 inch (minimum 0.115 inch). The overall cross sectional thickness of size 4 luminaire plastic lenses shall be a nominal 0.187 inch (minimum 0.182 inch). The overall cross sectional thickness of glass side panels and bottom closures lenses shall be as indicated in UL Standard 57. For plastic bottom closures, lens sag - the vertical distance that bottom center of lens sags below lens periphery, when fixture with bottom closure installed is mounted in a normally functioning position - shall not exceed 1/8 inch for size 1 fixtures; 1/4 inch for size 2 fixtures; and 1/2 inch for size 4 fixtures. Bottom closure and engaging latches shall be constructed in such manner as to preclude accidental (unitentional) release or disassembly of bottom closure, or portions thereof, from fixture housing when in either the latched or open position. The fixture housing and bottom closure shall incorporate a light trap for preclusion of light leaks. Additionally, lens frame(s) shall be constructed in such manner as to permit the replacement of lenses without the use of tools other than screwdrivers or pliers. Also, lens frames shall be sufficiently rigid so as to preclude sag of more than 0.047 inch below lumininaire housing flanges. Bottom closure and side panel lenses may be tinted, provided that photometric and other requirements of this specification are adhered to."

PAGE 16

Paragraph 4.5.2, first sentence, delete reference to "Method 811.1 of Fed. Test Method No. 151" and replace with "ASTM Standard No. B 117."

FSC 6210

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.