A-A-1702
August 25, 1991

COMMERCIAL ITEM DESCRIPTION

SAFETY CAN (SPRING CLOSING TYPE)

The General Services Administration has authorized the use of this commercial item description in preference to Federal Specification RR-S-30

This commercial item description covers metal safety cans for temporary storage or handling of flammable liquids

Salient characteristics

Type and capacity - as specified

Type I - short, fixed, valved pour spout
Capacity - 1 pint, 1 quart, 2 quart, 1 gallon, 2 gallon or 5 gallon

Type II - with metallic flexible pour spout and a separate valved fill fitting
Capacity - 1 gallon, 3 gallon, or 5 gallon

Grade B - galvanized steel (prior to coating, grit, loose scale, and rust shall be removed from parts parts to be coated or

Grade C - terne metal, as specified

Construction - body - cylindrically shaped
top - domed shaped
carrying handle - attached to domed top
openings - fitted with flame arresters to prevent the flame of a hydrocarbon gas-air mixture from reaching the gas source
pouring spout - for Type II, a minimum of 6 inches long Minimum inside diameter 3/8 inch for 1 gallon can and 3/4 inch for 3 and 5 gallon cans.

Finish - Exterior surfaces shall be prepared for painting and enameled red with a yellow band

Instructions - furnished with each safety can, including assembly and parts list.

Safety - In addition to the salient characteristics of this description, the safety cans shall meet the requirements of

Underwriters Laboratories, Inc		Factory Mutual Research
UL Standard UL 30 Metal Safety Cans	AND	Safety Containers and Filling, Supply and Disposal Containers Class Number 6051 and 6052

Workmanship No loose handles, rough edges, burrs, loose or missing components No unpainted or uncoated areas, sags or runs, free from foreign material, and cracks Soldering and welding shall be adherent, free from pits, acid and flux. Spot welds, shall be adherent and free from craters

The issue of the UL - 30 and FM 6051 and 6052 Standards in effect on the date of the solicitation for bids shall be used to determine compliance with the stated requirements.

Certification The contractor shall certify that the product offered meets the salient characteristics of this description, and that the product conforms to the producer's own drawings, specifications, standards and quality assurance practices, and is the same product solde in the commercial marketplace The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract

Regulatory requirements The manufacturer shall utilize recovered materials to the maximum extent practicable

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:16Z
Check the source to verify that this is the current version before use.

A-A-1702

Packaging, packing, and marking Packaging, packing, and marking shall be as specified in the contract or order

U L 30 is available from Underwriters Laboratories, Inc
333 Pfingsten Road
Northbrook, Illinois 60062

FM Standards are available from Factory Mutual
1151 Boston-Providence Turnpike
Norwood, MA 02062

MILITARY INTERESTS

Military Coordinating Activity

Army - GL

Custodians

Army - GL
Navy - YD
Air Force - 99

User Activities

Navy - MC, CG OS

Preparing activity

GSA - FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:16Z
Check the source to verify that this is the current version before use.