A-A-732
February 20, 1981

COMMERCIAL ITEM DESCRIPTION

GENERATOR SET, GASOLINE ENGINE (STATIONARY, 120/240 V, 60 HERTZ, SINGLE PHASE)

The General Services Administration has authorized the use of this commercial item description.

This commercial item description covers gasoline or gas driven, stationary, air cooled, electric generator set with an electrical rating of 120/240 volts, 60 Hertz.

Salient characteristics:

Mounted control box with reverse current cutout.
Battery terminals.
Remote control terminals.
Start-stop switch.
Flexible exhaust connection.
Fuel line.
Battery cables.
Vibration isolators.
Four cycle engine with air cleaner.
Automatic choke.
Five percent speed regulation at rated load.
Muffler.
Starting battery.
Temperature rise for alternator at rated load in accordance with NEMA MG-1-22.40.
Insulation system in accordance with class B for 2,500 W and class F for 4,000 W and above of NEMA MG-1-1.65.
Electrical ratings shall be as follows:

Type	Watts	Amperes	Volts
A	2,500	20.8/10.8	120/240
B	4,000	34.0/17.0	120/240
C	5,000	42.0/21.0	120/240
D	6,000	54.2/27.1	120/240
E	7,500	62.5/32.0	120/240
F	10,000	84.0/42.0	120/240
G	12,500	104.0/52.0	120/240
H	15,000	125.0/63.0	120/240

The issue of NEMA MG-1 in effect at the date of the solicitation shall be used to determine compliance with stated requirements.

Certification. The contractor shall certify that the product offered meets the salient characteristics of this description, and that the product conforms to the producer's own drawings, specifications, standards and quality assurance practices and is the same product sold in the commercial marketplace. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

Regulatory Requirements. The manufacturer shall utilize recovered materials to the maximum extent practicable.

Packaging, Packing, and Marking. The items shall be packaged in accordance with normal commercial practice and packaged to assure acceptance by common carrier and provide product protection against loss and damage during multiple shipments, handling, and storage. The shipping container shall be in compliance with National Motor Freight Classification and Uniform Freight Classification. Shipping containers shall be marked as specified in the contract or order.

Copies of NEMA MG-1 are available from the National Electrical Manufacturers Association, 2101 L Street, NW, Washington, DC 20037.

FSC 6115

GSA DC-01102525

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:10Z
Check the source to verify that this is the current version before use.