Fed. Std. No. 237a
January 28, 1966
(W-L-101, Issue in effect)

SUPERSEDING
Int. Fed. Std. No. 00237 (GSA-FSS)
April 14, 1965

FEDERAL STANDARD

LAMP, INCANDESCENT (10-300 WATT)

Authority. *This standard is issued pursuant to the Federal Property and Administrative Services Act of* 1949, *as amended, and its application to the purchase of commodities referred to herein is mandatory on all Federal agencies.*

S1. Purpose and scope. This standard establishes the available 10 through 300-watt incandescent lamps of optimum characteristics and adopts them as standard items for use in general lighting where the nominal supply voltage is 120 volts. Its purpose is to achieve greater economy in providing light where incandescent lamps are used. Those agencies interested in the technical and cost data upon which this standard is based, may obtain it by writing the Standardization Division, Federal Supply Service, General Services Administration, Washington, D.C., 20406.

S2. Application. Purchases from commercial sources under Federal Specification W-L-101, Lamp, Incandescent, (Electric, Large, Tungsten-Filament), of the issue in effect on date of invitation for bids, should be limited to items which conform to the characteristics specified below for each of the applications shown.

S3. Standard characteristics and item identification. The standard items with their applicable Federal Stock Numbers should conform to the characteristics listed below for each of the indicated applications.

Currently in use 120-volt lamps		Replace by 130-volt lamps (1)		Replace by 125-volt lamps (1)	
FSN	Wattage	FSN	Wattage	FSN	Wattage
6240-196-4522	10	6240-504-0557	15		
6240-143-3071	15	6240-782-5258	25(e.s.)*		
6240-143-3059	25	6240-702-6959	40(e.s.)*		
6240-155-8655	40	6240-689-7009	50		
6240-155-8005	50	6240-500-3125	75		
6240-635-4480	60	6240-500-3125	75		
6240-268-3061	75	6240-246-5049	100		
6240-143-3124	100			6240-143-3133	150
6240-635-4482	150			6240-143-3133	150
6240-635-4475	200			6240-519-0950	200
6240-143-3156	300			6240-255-6968	300

*(e.s.) — extended service lamps

(1) Exceptions:

1. When the existing fixture will not accommodate the larger wattage lamp in the 130- (or 125-) volt rating, use 130- (or 125-) volt lamp of same wattage as the 120-volt lamp, unless the amount of light available after the sub titution would be insufficient for the purpose.
2. When the circuit capacity is reached and the addition of more 130- (or 125-) volt higher wattage lamps would overload the distribution system, use 130- (or 125-) volt lamps of the same wattage unless light available after the substitution would be insufficient for the purpose.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:55Z
Check the source to verify that this is the current version before use.

S4. Changes. When a Federal agency considers that this standard does not provide for its essential needs, written request for changing or adding to the standard, supported by adequate justification, shall be sent to the Administration. This justification shall explain wherein the standard does not provide for essential needs. The request shall be sent in duplicate to the General Services Administration, Federal Supply Service, Standardization Division, Washington, D.C., 20406. The Administration will determine the appropriate action to be taken and will notify the agency.

S5. Conflict with referenced specifications. Where the requirements stated in this standard conflict with any requirement in a referenced specification, the requirements of the standard shall apply. Nature of conflict between the standard and the referenced specification shall be submitted in duplicate to the General Services Administration, Federal Supply Service, Standardization Division, Washington, D.C., 20406.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:55Z
Check the source to verify that this is the current version before use.