INCH-POUND
MIL-C-24746(SH)
AMENDMENT 1
8 November 1996

MILITARY SPECIFICATION

COOLERS, UNIT FORCED AIR
FOR SHIP'S REFRIGERATED STORES

This amendment forms a part of MIL-L-24746, dated 31 December 1990, and is approved for use by the Naval Sea Systems Command, Department of the Navy, and is available for use by all Departments and Agencies of the Department of Defense.

PAGE 2

2.1: SPECIFICATIONS, FEDERAL: Delete the following:

"PPP-F-320 - Fiberboard: Corrugated and Solid, Sheet Stock (Container Grade), and Cut Shapes".

2.1: SPECIFICATIONS, MILITARY: Change the title of MIL-R-16743 to "Refrigerating Plants and Systems, Mechanical; and Refrigerating System Components - Dichlorodifluoromethane (R-12) and Tetrafluoroethane (R-134a) - Naval Shipboard".

2.1: SPECIFICATIONS, MILITARY: Delete the following:

"MIL-L-19140 - Lumber and Plywood, Fire-Retardant Treated.
MIL-C-81302 - Cleaning Compound, Solvent, Trichlorotrifluoroethane".

2.1: SPECIFICATIONS, MILITARY: Add "MIL-C-29602 - Cleaning Compounds, for Parts Washers and Spray Cabinets".

PAGE 3

2.1: STANDARDS, MILITARY: Delete the following:

"MIL-STD-1186 - Cushioning, Anchoring, Bracing, Blocking and Waterproofing; with Appropriate Test Methods.
MIL-STD-2073-1 - DoD Materiel Procedures for Development and Application of Packaging Requirements."

AMSC N/A FSC 4110
DISTRIBUTION STATEMENT A. Approved for public release distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T01:40Z
Check the source to verify that this is the current version before use.

2.2: Non-Government publications, Add the following:

"AIR-CONDITIONING AND REFRIGERATION INSTITUTE
ARI 700 - Specifications For Fluorocarbon And Other Refrigerants.

(Application for copies should be addressed to Air-Conditioning and Refrigeration Institute, 4301 North Fairfax Drive, Arlington, VA 22203.)

PAGE 4

2.2: Non-Government publications, AMERICAN SOCIETY FOR TESTING MATERIALS (ASTM): Delete "ASTM D 3951 - Standard Practice for Commercial Packaging. (DoD adopted)."

PAGE 6

Table I: Under "Materials" column for "Refrigerant" delete "Type R-12 or R-22" and replace with "R-12 or R-22 for existing systems and R-134a for new or converted systems". Under "Specification" column for "Refrigerant" after BB-F-1421, add ", ARI 700".

PAGE 7

3.4.2: Delete and substitute:

"3.4.2 Liquid refrigerant temperature. For R-12 and R-22 coil and expansion valve sizing, the liquid refrigerant temperature at the inlet of the expansion valve shall be taken as 103°F with a corresponding pressure of 123 lb/in^2 gauge. For R-134a coil and expansion valve sizing, the liquid refrigerant temperature at the inlet of the expansion valve shall be taken as 103°F with a corresponding pressure of 130 lb/in^2 gauge. The unit shall be sized for a saturated evaporating temperature of minus 20°F and plus 25°F."

PAGE 8

3.10: First sentence, delete and substitute: "The cooling coil shall be a direct expansion, extended surface type for use with the refrigerant specified (see 6.2)."

PAGE 22

4.7: Delete in its entirety.

PAGES 22 - 24

Section 5: Delete the entire Section 5 and substitute:

"5. PACKAGING

5.1 Packaging. For acquisition purposes, the packaging requirements shall be as specified in the contract or order (see 6.2). When actual packaging of materiel is to be performed by DoD personnel, these personnel need to contact the responsible packaging activity to ascertain requisite packaging requirements. Packaging requirements are maintained by the Inventory Control Point's packaging activity with the Military Department or Defense Agency, or within the Military Department's System Command. Packaging data retrieval is available from the managing Military Department's or Defense Agency's automated packaging files, CD-ROM products, or by contacting the responsible packaging activity.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T01:40Z
Check the source to verify that this is the current version before use.

PAGE 25

6.2: Ordering data: Delete

"(o) When lumber and plywood do not require fire-retardant treatment (see 5.1.1).
(p) Level of preservation required (see 5.2 and 5.3.3).
(q) If container selection is not at the contractor's option (see 5.2.1.1 and 5.3.2).
(r) Level of packing required (5.3 and 5.3.2).
(s) Whether shipping containers should be provided with waterproofing (see 5.3.2.1.3).
(t) Special marking required (see 5.4)."

PAGE 27

6.8: Renumber to paragraph 6.9.

6.8: Add as new paragraph:

"6.8 Preservation. Preservation should be level A, C, or commercial and cleaned as follows or by an equivalent commercial process as approved by NAVSEA.

(a) Cleaning.

(1) The refrigerant system circuit shall be cleaned internally in accordance with the manufacturers' standard practice.
(2) After the refrigerant system circuit has been cleaned, evacuate and then pressurize with a holding charge of nitrogen to 2 lb/in^2. Seal for shipping."

Preparing activity:
Navy - SH
(Project 4110-N507)

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T01:40Z
Check the source to verify that this is the current version before use.