


NOTE: 1. CHECK ROTATION OF UNIT IS AS PER LABEL ON FAN (OR WARRANTY IS VOID)
 2. PLEASE ENSURE THERMAL OVERLOAD IS CONNECTED (OR WARRANTY IS VOID)
 3. BRIDGE IS FACTORY PRE-WIRED
 4. CAPACITOR IS FACTORY PRE-WIRED (IT IS LOCATED UNDERNEATH THE CAP OF THE MOTOR WEATHERPROOF PLATE)

REV.	DESCRIPTION	DATE	BY	 CFMAIRSYSTEMS AUSTRALASIA 106 FAIRBANK ROAD CLAYTON SOUTH, VICTORIA 3169 ph: +61 3 9551 4878 email: mail@cfmairsystems.com.au web: www.cfmairsystems.com.au		MAT'L / FINISH:	MODEL:
A	ISSUED FOR CONSTRUCTION	04.10.2020	CFM			N/A	
				THE INFORMATION CONTAINED HEREIN IS CONFIDENTIAL TO CFM FANS AND SHALL NOT BE REPRODUCED, COPIED OR DISCLOSED IN WHOLE OR IN PART, OR USED FOR MANUFACTURE OR FOR ANY OTHER PURPOSE WITHOUT THE WRITTEN PERMISSION OF CFM FANS. THIS PRINT IS TO BE RETURNED UPON DEMAND DESTROY OLD REVISIONS		DRAWN: CFM Airsystems	DIAGRAM # 13 DESCRIPTION: ELECTRICAL DIAGRAM No.13
						DATE: October 2020	
				UNLESS OTHERWISE STATED DIMENSIONS ARE OUTSIDE DIMS, IN MILLIMETRES AND TO TOLERANCES LINEAR: ±1 ANGLE: ±10' (MIN) HOLES: WITHIN 0.5 OF TRUE POSITION		CHECKED: M.KOTSIKAS	REV A
						SCALE: NTS	
						SHEET: A4	