

Figure 1: Typical Detail of a Single-Ended Bolted Flange Connection. The diagram shows a cross-section of a vertical assembly. At the top is a 10" wide flange with a 1 3/4" thickness. Below this is a 6 1/2" thick section, followed by a 3" thick section, and then a 3 1/2" thick section. The assembly is labeled 'STRAND' and 'INSULATION'. A 'MIN. RADIUS' is indicated on the left. A '3/4" CHAMFER' is shown on the right. The bottom flange is labeled 'B/F' and has a 'MIN. RADIUS' and a '3/4" CHAMFER'. The bottom flange thickness is 1 7/8". The total height of the assembly is 8'-0 3/4". The bottom flange is labeled '5'-1 1/8"'. The bottom flange is labeled 'FIXED EDGE'.

15'-9"

3"

#30709

(9) @ 1'-6" = 13'-6" SPACE TO AVOID NU-TIES

3"

ST

FM

#30709

PRODUCTION NOTE:
#30709 TIED BELOW
STRAND @ P041

#30709

15'-6"

5'-3"

5'-0"

4'-9"

4'-6"

13'-0"

11'-6"

10'-6"

9'-6"

8'-0"

6'-6"

5'-0"

4'-0"

2'-6"

1'-0"

9"

6"

3" 0"

BIF

2 1/4"

1 1/4"

6 1/2"

10"

NOTES:
1. ALL REBAR IS TO BE 1" CLR. UNO
2. ALL DIMENSIONS ARE TO CENTERLINE UNO
3. SPLIT STRONGBACK C.Y. 50/50 FACE MIX / BACK MIX
4. PLACE REBAR 2" FROM EDGE OF ROUGH OPENINGS
SYMBOLS

S.I.F. = SIDE IN FORM
B.I.F. = BOTTOM IN FORM
T.I.F. = TOP IN FORM
E.O.P. = EDGE OF PLATE

▽ST = STEEL TROWEL

 = FORM FINISH

CONTROL NUMBER
217

PRECAST ENGINEER:



18 KING ST. EAST SUITE 1400,
TORONTO ON M5C 1C4, CANADA
WWW.BUILDINGTHEORY.COM
TEL: +1-647-906-7812

**NORTHEAST
PRECAST**

4081 S. LINCOLN AVE.
VINELAND, NJ 08361

OFFICE: 866-699-2557 FAX: 856-765-9087
www.northeastprecast.com

PROJECT: PROJECT AERIE		
JOB NO. 25-NE1209	PIECE MARK W210	SHEET NO. 1 of 3

STEALTH 100	FLANGE CONNECTOR	4	EA
NU-TIE	7" NU-TIE	18	EA
P041	PL 3/4" x 4" x 7" W/(2) #4 x 1'-6" BAR & (2) #3 x 1'-3" BAR	2	EA
P313	PL 3/8" x 8" x 1'-0" W/(6) 1/2" DIA. x 4 1/8" HCA	2	EA
QLFIP127G	12T SAND PANEL ANCHOR	4	EA
MARK	DESCRIPTION	QTY.	UOM

#30709		35	EA
#51506		4	EA
#5BB001		8	EA
#5BB312		2	EA
#80006		8	EA
1/2 STRAND	1/2 DIAMETER STRAND 31 KIPS	6	EA
MARK		QTY.	UOM

MARK	DESCRIPTION		

CONCRETE MIX		
MIX	CY	B/F
725N	1.51	B
700A	1.37	F

f'c (28 DAYS)	6,000 PSI
f'c (SHIPPING)	4,000 PSI
f'c (RELEASE)	3,500 PSI

PIECES REQ'D:
1


WEIGHT:
11700 LB

DESIGN:
IWP1.00

PC. FOUND ON
E-DRAWING:
E-3.17

REL.	DESCRIPTION	DATE	BY
1	FOR PRODUCTION	08/07/25	PS

DRAWN: NC	CHECKED: RN	ENGR: PP	PLOTTED: 8/7/2025 7:42 PM
--------------	----------------	-------------	------------------------------



FOAM DRAWING

PIECES OF 3" XPS:
A/B: (3) PIECES @ 4'-0" X 8'-0 1/2"
C: (1) PIECE @ 2'-5 1/2" X 8'-0 1/2"

- NOTES:
1. ALL REBAR IS TO BE 1" CLR. UNO
2. ALL DIMENSIONS ARE TO CENTERLINE UNO
3. SPLIT STRONGBACK C.Y. 50/50 FACE MIX / BACK MIX
4. PLACE REBAR 2" FROM EDGE OF ROUGH OPENINGS

SYMBOLS
S.I.F. = SIDE IN FORM
B.I.F. = BOTTOM IN FORM
T.I.F. = TOP IN FORM
E.O.P. = EDGE OF PLATE
ST = STEEL TROWEL
FM = FORM FINISH

REL.	DESCRIPTION	DATE	BY
1	FOR PRODUCTION	08/07/25	PS

DRAWN: NC	CHECKED: RN	ENGR: PP	PLOTTED: 8/7/2025 7:42 PM
-----------	-------------	----------	---------------------------

PRECAST ENGINEER:

**BUILDING
THEORY**


18 KING ST. EAST SUITE 1400,
TORONTO ON M5C 1C4, CANADA
WWW.BUILDINGTHEORY.COM
TEL: +1-647-906-7812

**NORTHEAST
PRECAST**

4081 S. LINCOLN AVE.
VINELAND, NJ 08361
OFFICE: 866-699-2557 FAX: 856-765-9087
www.northeastprecast.com


PROJECT: PROJECT AERIE

JOB NO. 25-NE1209	PIECE MARK W210	SHEET NO. 2 of 3
-------------------	-----------------	------------------



REVEAL DRAWING

SHOP NOTE:
NO REVEALS



SECTION VIEW

- NOTES:
1. ALL REBAR IS TO BE 1" CLR. UNO
 2. ALL DIMENSIONS ARE TO CENTERLINE UNO
 3. SPLIT STRONGBACK C.Y. 50/50 FACE MIX / BACK MIX
 4. PLACE REBAR 2" FROM EDGE OF ROUGH OPENINGS

SYMBOLS

- S.I.F. = SIDE IN FORM
B.I.F. = BOTTOM IN FORM
T.I.F. = TOP IN FORM
E.O.P. = EDGE OF PLATE

ST = STEEL TROWEL

FM = FORM FINISH

REL.	DESCRIPTION	DATE	BY
1	FOR PRODUCTION	08/07/25	PS

DRAWN: NC	CHECKED: RN	ENGR: PP	PLOTTED: 8/7/2025 7:42 PM
-----------	-------------	----------	---------------------------

PRECAST ENGINEER:



**NORTHEAST
PRECAST**

4081 S. LINCOLN AVE.
VINELAND, NJ 08361
OFFICE: 866-699-2557 FAX: 856-765-9087
www.northeastprecast.com

PROJECT:	PROJECT AERIE	SHEET NO.
JOB NO.	25-NE1209	3 of 3
PIECE MARK	W210	