MOORE & BRUGGINK, INC.
Consulting Engineers
2020 Monroe Avenue, N.W.
Grand Rapids, Michigan 49505-6298

July 31, 2015

Re: 43 North, Phase 2; SP#1312

Ms. Julie Sjogren
Algoma Township
10531 Algoma Avenue, N.E.
Rockford, Michigan 49341

Dear Ms. Sjogren:

On behalf of the Township we have reviewed the Phase 2 construction plans for the 43 North development located on the west side of Wolven Avenue south of 11 Mile Road. The plans that we reviewed were prepared by Roosien and Associates dated July 10, 2015. We also reviewed storm water management plan documents dated July 29, 2015.

Based on our review of the above documentation we recommend approval of the engineering plans with one addition. That is, we recommend that Minimum Building Opening elevations (MBO) be provided on the plan for all homes adjacent to ponds and culvert inlets.

For the record, we note that there has been some dissatisfaction from a property owner downstream of the Phase 1 detention pond regarding nuisance storm water runoff generated from the slow pond release. The developer intends to address this complaint by eliminating the slow pond release and changing the pond from a retention pond (slow release) to a retention pond (no release for 100 year event). Part of Phase 2 work is to make necessary changes to the outlet structure and increasing the pond volume. There will still be runoff from the site after large rain events, however the long duration low flow rate runoff will be mitigated.

We recommend a bond amount of $400,000.

Sincerely,

Robert E. Bruggink, P.E.

REB/mll
cc. Paul Henderson, Roosien & Associates

Phone: (616) 363-9801 Fax: (616) 363-2480 e-mail: mailbox@mbce.com www.mbce.com