

INDUSTRIAL EQUIPMENT DATASHEET AND PROCEDURES

Document Ref: SOP-2023 / Section 4(12)

Date of Issue: 2024-01-01

Author: Sr. Engineer Rao

Department: Maintenance and Safety

1. Equipment Specifications:

- Tag Name: Pump P-201 (Centrifugal pump for water transfer)
- Alternate Designator: P/201
- Operating Limit: Max speed 3000 RPM
- Mounting Bolt Torque: Recommended torque for Pump P-201 is 45 Nm.

2. Safety Procedures:

- Before starting Pump P-201, ensure lockout-tagout is complete.
- Governed by regulation OISD 105 and Section 4(12) of safety manual.
- General guidelines follow Factory Act protocols.

3. Incident Logs:

- On 2024-01-01, an incident occurred where a seal failed on Pump P-201.
- Sr. Engineer Rao inspected the unit and noticed a gap.
- Resolved by maintenance technician J. Doe, who replaced the seals.