



SLD-Management view

Automated Proof Test


Here we have an overview of all the devices in the unit / site. we see when they were tested, testing interval, Auto/Manual, when is the next test is scheduled... Most of the information are via API from SLM. some columns are intern HMI from other pictures.

API from SLM, projection of current month test + 5 months
red is overdue and green is on schedule

Test groups

Test group	Object description	Test group type	Test interval	Last test	Due date	Overdue
TEST_50-SIF-VALVES	Automatic Partial Stroke Test of the SIF Valves	Automated test - during operation	3 mo	10.04.2024	10.07.2024	No
TEST_60-FZT-002A	Proof test of the flow transmitter Promass 300	Automated test - during operation	3 mo	26.03.2024	27.06.2024	No
TEST_60-TZT-002	Proof test of the temperature transmitter 3144P	Automated test - during operation	3 mo	19.03.2024	20.06.2024	Yes
TEST_50-P0001_B	Proof test for pressure transmitter 3051P - 50-P0001_B	Manual test	1 yr	14.04.2024	14.04.2025	No
TEST_50-P0001_A	Proof test for pressure transmitter 3051P - 50-P0001_A	Manual test	1 yr	31.08.2023	01.09.2024	No
TEST_60-XV-003	Proof test of the ball valve AKH2	Automated test - during operation	2 mo	28.05.2024	28.07.2024	No
TEST_60-XV-002A	Proof test of the ball valve AKH2	Automated test - during operation	4 mo	02.02.2024	02.06.2024	Yes
TEST_60-XV-001A	Proof test of the ball valve AKH2	Automated test - during operation	4 mo	10.02.2024	20.06.2024	Var

Projection



TEST_60-XV-003

Proof test of the ball valve AKH2

Test group scope items

Open details	Tag number	Type	Generic model	Bypass active	Start auto test	Test started	Test result	Test date
Open details	60-XV-003	Valve - Ball - /	GM-0004	Yes	Start	No	Pass	09.06.2024 10:29:09

When we select a device, we see its details and can start a test and get the result, duration, etc...

some information are via API from SLM and other via OPC to and from HIMA.

API from SLM, total number of tests

Test group information

Test type: Automated test - during operation
Affected SIF: 60-CSC-SIF-06, 60-CSC-SIF-11
Last approved test date: 27.05.2024
further details about the device, we might merge this part to the table. Interesting info here is: in which SIFs the device is used.

Test overview



Logs

Time	Event type	Status	Result	Note	Object ID	Approved	Log type
25.06.2024 16:41:54	Prooftest	Created	Pass	-	60-XV-003-prooftest-20240625142352		Event
25.06.2024 16:07:16	Prooftest	Created	Pass	-	60-XV-003-prooftest-20240625142352		Event
25.06.2024 16:02:13	Prooftest	Created	Pass	-	60-XV-003-prooftest-20240625142352		Event
25.06.2024 15:56:37	Prooftest	Created	Pass	-	60-XV-003-prooftest-20240625142352		Event
25.06.2024 15:39:23	Prooftest	Created	Pass	-	60-XV-003-prooftest-20240625142352		Event
25.06.2024 15:33:54	Prooftest	Created	Pass	-	60-XV-003-prooftest-20240625142352		Event
25.06.2024 15:04:56	Prooftest	Created	Pass	-	60-XV-003-prooftest-20240625142352		Event

in the log we have our performed tests and their results, these info will be posted in SLM via API.

Test results will then update in SLM some calculations.

Save

26.06.2024 15:37

MESALOGIC