

PRV Calibration & Test Record - 2022

Document ID: CALIB-PRV-2022-89

Test Date: October 15, 2022

Calibration Due Date: October 15, 2023

Equipment Tag: PRV-201 (Pressure Relief Valve - Storage Tank T-102)

Inspector: S. A. Khan (PESO Certified Inspector)

Inspection Details:

- Regulation Clause: OISD-118 Section 4.3: Pressure relief valves must be inspected and tested at intervals not exceeding 12 months.
- Set Pressure: 150 psi (10.3 bar)
- Re-seat Pressure: 142 psi (9.8 bar)
- Hydrostatic Testing: Ok

Status: Certified and Sealed

Note: The PRV-201 is certified for operation. Next calibration testing must be performed before October 15, 2023.

Signed: S. A. Khan