

OISD-118 Regulation Standard - Selected Clauses

Regulatory Document: OISD-118 (Oil Industry Safety Directorate)

Title: Layout, Safety, and Inspection of Piping and relief Systems

OISD-118 Selected Key Clauses:

- Clause 4.3: Pressure relief valves must be inspected and tested at intervals not exceeding 12 months. All records must be certified by a competent authority.
- Clause 7.1: Portable fire extinguishers must be inspected every 6 months and serviced annually. Maintenance tags must show inspection history.
- Clause 9.2: Emergency shutdown (ESD) systems and safety instrumented systems (SIS) must be tested every 6 months to ensure emergency response readiness.
- Clause 5.1: Hot work permits must be issued for all welding, cutting, or grinding operations in hazardous areas. Fire watch is mandatory.