

Operating Procedure: Feed Pumps (P-101A/B) - v3.0

Document ID: SOP-OPS-042-V3

Doc Type: Operating Instruction

Effective Date: January 15, 2024

Author: Operations Engineering Committee

1.0 Purpose and Scope

This Standard Operating Procedure (SOP) governs the startup, operation, and shutdown sequences of the Unit-4 primary feed pumps P-101A and P-101B.

2.0 Operational Parameters

- Normal discharge pressure: 12 bar (1.2 MPa).
- Startup sequence: Ensure suction valve is 100% open. Start motor. Slowly open discharge valve to maintain pressure.
- Maximum casing temperature: 77F (25 C) above ambient.
- Inspection Interval: Feed pumps must be inspected every 6 months.

3.0 Safety & Maintenance

In case of bearing wear or seal leakage, immediately isolate the pump and switch over to stand-by pump.

Verify lubrication levels before startup.