

# Notice of variation with introductory note

The Environmental Permitting (England & Wales) Regulations 2010

---

Severn Trent Water Limited

Bowers Hall Combined Sewer Overflow  
Bakewell  
Derbyshire  
DE45 1LA

Variation application number

T/39/45884/O/V001

Permit number

T/39/45884/O

# **Bowers Hall Combined Sewer Overflow**

## **Permit number T/39/45884/O**

### **Introductory note**

#### **This introductory note does not form a part of the notice**

The following notice gives notice of the variation of an environmental permit.

This variation is to reduce the pass forward flow volume to reflect the actual performance of the combined sewer overflow. A maximum screened flow figure is also being added to the permit.

The schedules specify the changes made to the original permit.

The status log of a permit sets out the permitting history, including any changes to the permit reference number.

<b>Status log of the permit</b>		
<b>Description</b>	<b>Date</b>	<b>Comments</b>
Permit issued T/39/45884/O	06/01/2004	
Application T/39/45884/O/V001	Duly made 11/07/2011	Application to vary the pass forward flow volume and add a maximum screened flow.
Variation determined T/39/45884/O	02/09/2011	Varied permit issued.

End of introductory note

## Notice of variation

The Environmental Permitting (England and Wales) Regulations 2010

The Environment Agency in exercise of its powers under regulation 20 of the Environmental Permitting (England and Wales) Regulations 2010 varies

**Permit number**  
**T/39/45884/O**

**issued to:**

**Severn Trent Water Limited** ("the operator")

whose registered office is

**Severn Trent Centre**  
**2 St John's Street**  
**Coventry**  
**CV1 2LZ**

company registration number 2366686

to operate a regulated facility at

**Bowers Hall Combined Sewer Overflow**  
**Bakewell**  
**Derbyshire**  
**DE45 1LA**

to the extent set out in the schedules.

The notice shall take effect from 2<sup>nd</sup> September 2011

Name

Date

**Christopher Hall**

**2<sup>nd</sup> September 2011**

Authorised on behalf of the Environment Agency

**Schedule 1 – conditions to be deleted**

None.

**Schedule 2 – conditions to be amended**

The following conditions are amended as a result of the application made by the operator:

**VOLUME, RATE & FLOW**

- 4        The Discharge shall occur only when the rate of flow in the sewer at the combined sewage overflow exceeds 92.0 litres per second due to rainfall and/or snow melt, and shall consist only of flows in excess of this figure.

**COMPOSITION**

- 5        The Discharge shall not:
- a)       contain, for flows up to 400 litres per second, a significant quantity of solid matter having a size greater than 6 millimetres in more than one dimension.
  - b)       be comminuted or macerated to achieve the standard in a) above.

**Schedule 3 – conditions to be added**

None.