

Module Address									
IP Address		192.168.1.32							
Subnet Mask:		255.255.255.0							
Default gateway		192.168.1.2							
Connection1 (Client)									
Remote Properties(Server)									
IP Address:		192.168.1.12							
Port:		502							
Synchronize interval:		80Milliseconds							
Data transfer:									
ID	Operate	Length	Address (Local)	Address (Remote)	Unit ID				
1	Read	1	VW8	IR19	1				
2	Read	1	VW10	IR1009	1				
3	Write	1	VW0	HR1001	1				
4	Write	1	VW4	HR1003	1				
5	Write	1	VW6	HR1004	1				
Creator:	cavan					Project:			
Checked:						Installation:			
Date:	8/20/24 10:52 AM/9/10/25 11:27 AM					File:	LOG01.8.4_1 Diagramme.lsc		
						Customer:			
						Diagram No.:			
						Page:	1/16		

Connection3 (Client)

Local Properties(Client)
TSAP: 22.00
Remote Properties(Server)
IP Address192.168.1.16
TSAP: 03.00

Data Transfer (Read: Local<-Remote; Write: Local->Remote)

ID	Operate	Length (Bytes)	Address (Local)	Address (Remote)
1	Read	1	VB0	DB49.DBB4
2	Read	1	VB0	DB49.DBB4
3	Read	1	VB0	DB49.DBB4
4	Read	1	VB0	DB49.DBB5
5	Read	1	VB0	DB49.DBB5
6	Read	1	VB1	DB49.DBB6
7	Read	1	VB1	DB49.DBB6
8	Read	1	VB1	DB49.DBB6
9	Read	1	VB1	DB49.DBB6
10	Read	1	VB1	DB49.DBB7
11	Read	1	VB1	DB49.DBB7
12	Read	1	VB1	DB49.DBB7
13	Read	1	VB2	DB49.DBB7


ID	Operate	Length (Bytes)	Address (Local)	Address (Remote)
14	Read	1	VB2	DB49.DBB8
15	Read	1	VB2	DB49.DBB8
16	Read	1	VB0	DB49.DBB4
17	Read	1	VB0	DB49.DBB5
18	Read	1	VB1	DB49.DBB5
19	Read	1	VB12	DB24.DBB2
20	Read	1	VB14	DB2.DBB10
21	Write	1	VB0	DB3.DBB0
22	Write	1	VB0	DB44.DBB0

Connection2 (Client)


Remote Properties(Server)
IP Address:192.168.1.17
Port: 502
Synchronize interval: 80Milliseconds

Data transfer:





ID	Operate	Length	Address (Local)	Address (Remote)	Unit ID
1	Write	1	VW2	HR32001	1
2	Write	1	VW10	HR32002	1
3	Write	1	VW8	HR32003	1



**IF an error occurs,
We block the circuit until restart is called**



Timer count management








Creator:	cavan				
Checked:					
Date:	8/20/24 10:52 AM	9/10/25 11:27 AM			
			Project:		Customer:
			Installation:		Diagram No.:
			File:	LOGO18.4.1 Diagramme.lsc	Page:
					6 / 16

Block Number (Type)			Parameter		
B002(OR) : ONE OF BOTH HAS STARTED					
B003(Latching Relay) :			Rem = off		
B005(Analog Comparator) :			On =0 Off =0 Gain =1.0+ Offset =0 Point=0		
B006(Analog Comparator) :			On =0 Off =0 Gain =1.0+ Offset =0 Point=0		
B008(Latching Relay) :			Rem = off		
B009(AND) : BOTH HAS STARTED					
B011(Message texts) : PRINT_ERROR_COMPRESSOR			Prio = 3 Quit = off Text1: enabled Text2: disabled		
<div><div><div>ERROR :</div><div>COMPRESSOR</div><div>- - - - -</div><div>PRESS RESTART</div><div>COMPRESSOR</div></div><div>--></div><div>Ticker setting - CBC - Line1: N - Line2: N - Line3: N - Line4: N - Line5: N - Line6: N Message Destination - Both</div></div>					
B012(Analog Comparator) :			On =0 Off =0 Gain =1.0+ Offset =0 Point=0		
B013(Analog Comparator) :			On =0 Off =0 Gain =1.0+ Offset =0 Point=0		
Creator:	cavan		Project:		Customer:
Checked:			Installation:		Diagram No.:
Date:	8/20/24 10:52 AM/9/10/25 11:27 AM		File:	LOGO! 8.4_1 Diagramme.lsc	Page:

Block Number (Type)			Parameter		
B014(Message texts) : PRINT_ERROR_ELECTROLYSER			Prio = 2 Quit = off Text1: enabled Text2: disabled		
<div><div><div>ERROR :</div><div>ELECTROLYSER</div><div>- - - - -</div><div>PRESS RESTART</div><div>ELECTROLYSER</div></div><div></div></div> -->			Ticker setting - CBC - Line1: N - Line2: N - Line3: N - Line4: N - Line5: N - Line6: N Message Destination - Both		
B019(OR) : ERRORS EHC					
B020 Open bottle(On-Delay) :			Rem = off 15:00s+		
B022(On-Delay) : DELAY_EL_EHC			Rem = off 15:00m+		
B023(On-Delay) :			Rem = off 03:00m+		
B024(Analog MUX) :			V1 =0+ V2=0 V3=2 V4=1 Point =0		
B025(Mathematic instruction) :			V1=250+ V2=0 V3=0 V4=0 Point=0 ((250+0)+0)+0		
B026(Analog MUX) :			V1 =500+ V2=1200 V3=0 V4=2000 Point =0		
B027(On-Delay) :			Rem = off 30:00s+		
B028(On-Delay) :			Rem = off 05:00m+		
B029(Asynchronous Pulse Generator) :			Rem = off 00:05s+ 09:00s		
Creator:	cavan		Project:		Customer:
Checked:			Installation:		Diagram No.:
Date:	8/20/24 10:52 AM/9/10/25 11:27 AM		File:	LOGO! 8.4_1 Diagramme.lsc	Page: 8 / 16

Block Number (Type)			Parameter		
B030(Analog Comparator) : ERROR_EL			On =3 Off =4 Gain =1.0+ Offset =0 Point=0		
B032(On-Delay) :			Rem = off 10:00s+		
B034(On-Delay) :			Rem = off 10:00s+		
B036(On-Delay) :			Rem = off 10:00s+		
B038(On-Delay) :			Rem = off 60:00s+		
B039(Analog Comparator) : WARNING_EL			On =2 Off =3 Gain =1.0+ Offset =0 Point=0		
B040(Analog MUX) :			V1 =1+ V2=0 V3=0 V4=0 Point =0		
B041(OR) : ERRORS					
B042(OR) : ERRORS EL					
B045(Message texts) : PRINT_ERROR_BOTH			Prio = 127 Quit = off Text1: enabled Text2: disabled		
<div><div><div>ERROR :</div><div>COMPRESSOR</div><div>AND</div><div>ELECTROLYSER</div><div>- - - - -</div><div>PRESS RESTART</div></div><div>--></div></div>			Ticker setting - CBC - Line1: N - Line2: N - Line3: N - Line4: N - Line5: N - Line6: N Message Destination - Both		
B046(NOT) : OFF					
Creator:	cavan		Project:		Customer:
Checked:			Installation:		Diagram No.:
Date:	8/20/24 10:52 AM/9/10/25 11:27 AM		File:	LOGO! 8.4_1 Diagramme.lsc	Page: 9 / 16

Block Number (Type)			Parameter		
B047(Message texts) : PRINT_READY			Prio = 0 Quit = off Text1: enabled Text2: disabled		
<div></div>			--> Ticker setting - CBC - Line1: N - Line2: N - Line3: N - Line4: N - Line5: N - Line6: N Message Destination - Both		
B048(Message texts) : PRINT_START_BOTH			Prio = 123 Quit = off Text1: enabled Text2: disabled		
<div></div> <div>Line6.3 ScaleTime: B050-Cnt;s</div>			--> Ticker setting - CBC - Line1: N - Line2: N - Line3: N - Line4: N - Line5: N - Line6: N Message Destination - Both		
B049(Message texts) : PRINT_WARNING			Prio = 1 Quit = off Text1: enabled Text2: disabled		
<div></div>			--> Ticker setting - CBC - Line1: N - Line2: N - Line3: N - Line4: N - Line5: N - Line6: N Message Destination - Both		
Creator: cavan		Project:		Customer:	
Checked:		Installation:		Diagram No.:	
Date: 8/20/24 10:52 AM/9/10/25 11:27 AM		File: LOGO! 8.4_1 Diagramme.lsc		Page: 10 / 16	

Block Number (Type)	Parameter
B050(Up/Down counter) : STOPWATCH	Rem = off On=1+ Off=0 Start=0
B051(Asynchronous Pulse Generator) :	Rem = off 00:50s+ 00:50s
B052(Analog Comparator) : EL_OFF	On =0 Off =1 Gain =1.0+ Offset =0 Point=0
B053(OR) : REBOOT STOP WATCH	
B058(Message texts) : PRINT_ELECTROLYSER_START	<div> <div> Prio = 125 Quit = off Text1: enabled Text2: disabled </div> <div> --> <div> <div>  </div> <div> Ticker setting - CBC - Line1: N - Line2: N - Line3: N - Line4: N - Line5: N - Line6: N Message Destination - Both </div> </div> </div> </div> <div>Line6.4 ScaleTime: B050-Cnt;s</div>
B059(Message texts) : PRINT_COMPRESSOR_START	<div> <div> Prio = 126 Quit = off Text1: enabled Text2: disabled </div> <div> --> <div> <div>  </div> <div> Ticker setting - CBC - Line1: N - Line2: N - Line3: N - Line4: N - Line5: N - Line6: N Message Destination - Both </div> </div> </div> <div>Line6.4 ScaleTime: B050-Cnt;s</div> </div>
NAI1(Network analog input) : CHOICE OF PROD. RATE	VW30

Block Number (Type)			Parameter			
NAI2(Network analog input) : ON/OFF Only EHC			VW10			
NAI3(Network analog input) : REBOOT COMPRESSOR			VW20			
NAI5(Network analog input) : Status EL			EL PORT: 502 ModBus-compatible device Unit ID: 1 IR: 19			
NAI6(Network analog input) : Prod_rate EL			EL PORT: 502 ModBus-compatible device Unit ID: 1 IR: 1009			
NAI7(Network analog input) : Status EHC			EHC_PLC TSAP: 22.00,03.00 DB24.DBW2			
NAI8(Network analog input) : Prod_rate EHC			EHC_PLC TSAP: 22.00,03.00 DB2.DBW10			
NAI9(Network analog input) : REBOOT ELECTROLYSER			VW25			
NAI10(Network analog input) : ON/OFF Only EL			VW15			
NAI11(Network analog input) : Status of the electrolyser			IP: 192.168.1.12 PORT: 502 ModBus-compatible device Unit ID: 1 IR: 19			
NAQ1(Network analog output) : START EL			EL PORT: 502 ModBus-compatible device Unit ID: 1 HR: 1001			
NAQ2(Network analog output) : START_EHC			ECH_POWER PORT: 502 ModBus-compatible device Unit ID: 1 HR: 32001			
NAQ3(Network analog output) : PRODUCTION RATE			EL PORT: 502 ModBus-compatible device Unit ID: 1 HR: 1003			
Creator:	cavan		Project:		Customer:	
Checked:			Installation:		Diagram No.:	
Date:	8/20/24 10:52 AM/9/10/25 11:27 AM		File:	LOGO! 8.4_1 Diagramme.lsc	Page:	12 / 16

Block Number (Type)			Parameter			
NAQ5(Network analog output) : VOLTAGE_EHC			ECH_POWER PORT: 502 ModBus-compatible device Unit ID: 1 HR: 32003			
NAQ6(Network analog output) : CURRENT_EHC			ECH_POWER PORT: 502 ModBus-compatible device Unit ID: 1 HR: 32002			
NI2(Network input) : Emergency stop			EHC_PLC TSAP: 22.00,03.00 DB49.DBX4.1			
NI3(Network input) : Bubbler too high			EHC_PLC TSAP: 22.00,03.00 DB49.DBX4.3			
NI4(Network input) : Bubbler too low			EHC_PLC TSAP: 22.00,03.00 DB49.DBX4.5			
NI5(Network input) : Pipe temp5 to low			EHC_PLC TSAP: 22.00,03.00 DB49.DBX4.7			
NI6(Network input) : Pipe6_temp to low			EHC_PLC TSAP: 22.00,03.00 DB49.DBX5.1			
NI7(Network input) : Stack temp to high			EHC_PLC TSAP: 22.00,03.00 DB49.DBX5.3			
NI8(Network input) : Stack temp to low			EHC_PLC TSAP: 22.00,03.00 DB49.DBX5.5			
NI10(Network input) : Output pressure to high			EHC_PLC TSAP: 22.00,03.00 DB49.DBX6.1			
NI11(Network input) : Stack water flow			EHC_PLC TSAP: 22.00,03.00 DB49.DBX6.3			
NI12(Network input) : Anode purge off			EHC_PLC TSAP: 22.00,03.00 DB49.DBX6.5			
NI13(Network input) : Hydrogen flow to low			EHC_PLC TSAP: 22.00,03.00 DB49.DBX6.7			
NI14(Network input) : Humidification valve			EHC_PLC TSAP: 22.00,03.00 DB49.DBX7.1			
Creator:	cavan		Project:		Customer:	
Checked:			Installation:		Diagram No.:	
Date:	8/20/24 10:52 AM/9/10/25 11:27 AM		File:	LOGO! 8.4_1 Diagramme.lsc	Page:	13 / 16

Block Number (Type)	Parameter
NI15(Network input) : Voltage cell 1 too high	EHC_PLC TSAP: 22.00,03.00 DB49.DBX7.3
NI16(Network input) : Voltage cell 2 too high	EHC_PLC TSAP: 22.00,03.00 DB49.DBX7.5
NI17(Network input) : Voltage cell 3 too high	EHC_PLC TSAP: 22.00,03.00 DB49.DBX7.7
NI18(Network input) : Voltage cell 4 too high	EHC_PLC TSAP: 22.00,03.00 DB49.DBX8.1
NI19(Network input) : Voltage cell 5 too high	EHC_PLC TSAP: 22.00,03.00 DB49.DBX8.3
NQ1(Network output) : NEXT_BUTTON_EHC	EHC_PLC TSAP: 22.00,03.00 DB3.DBX0.2
NQ2(Network output) : PURGE_M	EHC_PLC TSAP: 22.00,03.00 DB44.DBX0.1
Q2(Output) : V1	



Connection		Label					
NAI1							
NAI2							
NAI3							
NAI4							
NAI5							
NAI6							
NAI7							
NAI8							
NAI9							
NAI10							
NAI11							
NI2							
NI3							
NI4							
NI5							
NI6							
NI7							
NI8							
NI9							
NI10							
NI11							
NI12							
NI13							
NI14							
NI15							
NI16							
NI17							
NI18							
NI19							
AM2							
AM3							
AM4							
M25		LOGO! displays white backlight					
M28		LOGO! displays the amber backlight					
M29		LOGO! displays red backlight					
Creator:	cavan			Project:		Customer:	
Checked:				Installation:		Diagram No.:	
Date:	8/20/24 10:52 AM/9/10/25 11:27 AM			File:	LOGO! 8.4_1 Diagramme.lsc	Page:	15 / 16

Connection		Label								
NAQ1										
NAQ2										
NAQ3										
NAQ4										
NAQ5										
NAQ6										
NAQ7										
NAQ8										
NAQ9										
NAQ10										
NQ1										
NQ2										
Q2										
X1										
X2										
X3										
X4										
X5										
X6										
X9										
X10										
X11										
X12										
X13										
X16										
Creator:		cavan			Project:			Customer:		
Checked:					Installation:			Diagram No.:		
Date:		8/20/24 10:52 AM/9/10/25 11:27 AM			File:		LOGO! 8.4_1 Diagramme.lsc		Page:	